

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month July, 2022				Day : Saturday				Date : 23.07.22				
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 12758 MW				Rule Curve = 87.52 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 91.10 ft				Today = 91.10 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.07.22 (Yesterday)		23.07.22 (Today)		22.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0		180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	300	310	310			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	89	89	89			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	324	338	320	330	22	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	407	409	410	410			
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	55	55			
15	Gagnagarj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	24	16	16			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.87+1x7.73	80	80	45	52	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.73	33	33	25	17	25	25			
19	Rugganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x7.73	33	33	33	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	39	49	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105			
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	143	140	140	140			
23	Kamelehghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	260	286	275	286			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	141	142	142	142			
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0			
27	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern powe	HFO (IPP)	3x19.3	55	55	0	35	0	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	50	87	54	104			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	42	144	35	162			
33	Manikganj 35MW Solar PP (Inspectra	Solar (IPP)	1x35	35	35	34	0	30	0			
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Siddhirganj 100 MW PP(Dutch Bangla	HFO (NENP)	12x8.9	100	100	8	8	8	8			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	7	7	7			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2612	2874	2653	2931	1127	660		
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	80	127	82	127		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	38	38	38			
44	Sikalbaha 105 MW PP (Baraka Sikab	HFO (IPP)	6x18.415	105	105	105	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	177	285	175	285			
48	Julda 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	30	21	30	30			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	51			
50	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	42	50	42	51			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			28	40	15	25			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	79	80	81	90			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	92	110	110			
55	Julda unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	10	10	10			
56	Julda 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	10	10	10	10			
57	Chattogram 116 MW PP (Anima Ener	HFO (IPP)	6x21.06	116	116	90	107	108	108			
Chattogram Zone Total			2442	2382	999	1145	1011	1220	80	555		
58	a) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	0	0	0	0	0		Contract Expired	
	b) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	33	41	42	42			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	206	212	160	180			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	305	260	300	55	Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	315	280	300	45	Gas Shortage	
	Ashuganj 420 MW CCPP(East)	Gas (APSCL)				0	0	0	0	300	Gas Shortage	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	24	55	24	55	245	Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	40	8	8	155	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	143	130	140			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	47	48	48	48			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	48	90	47	90			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	100	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.315+15x1.358	200	200	0	0	0	0			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	34	17	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	113	8	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	76	54	75			
**	Impoport (Tripura)	India		160	160	148	170	83	113			
Cumilla Zone Total			2885	2885	1532	2019	1438	1955	934	0		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	82	104	85	104	98	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	22	22			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	105	106	105	105			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	176	200	176	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutikhabari 50 MW Solar PP	Solar (IPP)	1x50	50	50	23	0	50	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total			622	614	429	452	462	453	98	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.07.22 (Yesterday)		23.07.22 (Today)		22.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42		48	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	5	8		46	Gas Shortage	
90	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0		109	54	ST under maint.
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0		11		Gas Shortage
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	61				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0			330	Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	65	20		50		
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	220	220		220		
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0		20		Gas shortage
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	7	8		18		Gas shortage
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	300		330		
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	406	404	400		400		
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	400	400		400		
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0		100		Under project work
103	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	5	6		45		Gas Shortage
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	5	5		45		Gas Shortage
Sylhet Zone Total					2522	2477	1490	1569	1523	1583	294	559
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0		0		
106	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	210	205	225		215		Gas Shortage
107	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	0		44		
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	72	55		60		
109	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0		0		
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0		0		
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17		17		
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	89	105	105		105		
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	99	0	100		0		
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	112	32		115		
115	Noapara 40 MW PP (Kharajahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	8		40		
**	Bheramara (HVDC)	India		1000	1000	870	856	883		867		
Khulna Zone Total					2388	2384	1325	1447	1425	1463	205	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16		32		
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	33	23		33		
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	82	82	82		112		Gas Shortage
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	880	1060	1100		1100		
120	Potlakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17		17		
121	Bhola 220MW CCPP (Nutan Bidyut Bt)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220		220		
Barisal Zone Total					1958	1958	1215	1427	1458	1484	112	0
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0		71		Gas Shortage
122	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0		100		Gas Shortage
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	32	34		34		
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0		0		
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	16		30		
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	81	87	88		88		
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	5	30	32		32		
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34		34		
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	29	35	35		35		
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	156	155	170		170		Gas Shortage
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	208	0		220		Gas Shortage
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	154	145	160		160		Gas Shortage
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	383	350		380		Gas Shortage
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22		22		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11		11		
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8		52		
137	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	56	113	55		95		
138	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	70		113		
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6		0		
Rajshahi Zone Total					2129	2129	1142	1448	1091	1256	552	0
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85		Coal Shortage
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85		Under Overloading
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	199	200	200		200		
142	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	84	105	84		105		
144	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
145	Majpara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8		0		
146	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	115	115	34	108	52		108		
Rangpur Zone Total					800	720	322	413	344	413	85	85
Sub-total: Plants in operation					21924	21396	11066.0	12794	11405	12758	3487	1859
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10922	12216	11257	12592		
(B) Plants under long term maintenance/ contract expired												
147	Jamtalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		Contract Expired
148	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0		0		Contract Expired
149	Bosila 108MW PP(CLO)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0		Forced Outage
150	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0		0		Contract expired
151	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0		0		Contract Expired on 12/11/2020
152	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0		0		Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0		0		
Gross Total					22348	21396	11066	12794	11405	12758	3487	1859
(C) Actual data of 22.07.22 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)		13206	MW, at = 21:00 hrs								
02.	Max. Demand at eve. peak (Sub-station end)		12628	MW, at = 21:00 hrs								
03.	Highest Generation (Generation end)		12866	MW, at = 23:00 hrs								
04.	Minimum Generation (Generation end)		10615	MW, at = 9:00 hrs								
05.	Day-peak Generation (Generation end)		11066	MW, at = 12:00 hrs								
06.	Evening-peak Generation (Generation end)		12794	MW, at = 21:00 hrs								
07.	Evening Peak Load-shed (Sub-station end)		412	MW, at = 21:00 hrs								
08.	Minimum Generation Forecast up to 8:00 hrs.		11010	MW, at = 5:00 hrs								
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation		3402	MW								
d)	Coal supply Limitation		85	MW								
b)	Low water level in Kaptai lake		0	MW								
c)	Plants under shut down/ maintenance		1859	MW								
10.	Total Energy (Generation + India Import)		279.95	MKWh								
	By Gas =	135.009	MKWh	By Oil =	87.400	MKWh						
	By Coal =	29.844	MKWh	By Hydro =	2.288	MKWh						
	By Solar =	1.243	MKWh									
11.	Total Gas Supplied		1003.20	MMCFD								
(D) Forecast of 23.07.22 (Today) Saturday :												
01.	Maximum Demand		14000	MW (Generation end)								
02.	Maximum Generation		12758	MW (Generation end)								
03.	Reserve / Shortage		-1242	MW (Generation end)								
04.	Maximum Load-shed		1205	MW At evening peak (Sub-station end)								
05.	Total Generation		304.62	MKWh								
06.	Probable Max. Temperature in Dhaka		34.5° C									

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation