

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022					Day : Monday				Date : 25.07.22				
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 11831 MW					Rule Curve = 87.84 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 91.07 ft.				Today = 90.99 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.07.22 (Yesterday)		25.07.22 (Today)		24.07.22 (Yesterday)		25.07.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Actual Peak Generation (MW)		Probable Peak Generation (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0			180	Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1x 254+1x 126	365	365	180	60	0	0				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	180	60	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	92	92	92				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	292	300	330	68		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	408	403	400	405				
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	7	7	7	7				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+4x8.73	80	80	44	45	53	53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	51	50	51				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	90	90	90				
22	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	132	148	132	148				
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	295	290	295				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	130	144	135	144				
26	Karanganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
27	Bramanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	90				
33	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	12	0	30	0				
34	Kanchan Purbachal Power Generation	HFO (IPP)	3x19.404	55	55	55	55	55	55				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8				
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	8	8	8				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total			6004	5847	2404	2541	2256	2457	1173	660			
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	127	126	127	127			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
41	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	0	25	25				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	100	281	175	285				
48	Jaldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	11	11	11				
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51				
50	Hatibazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	50	51	51	51				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			4	24	5	25				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	12	12	12				
53	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36				
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	92	92	110				
55	Jaldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10				
56	Jaldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10				
57	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	108	108	108	108				
Chattogram Zone Total			2442	2382	848	1062	937	1111	80	555			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	42	10	10				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	199	145	200	150	76		Gas Shortage	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	320	280	300				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	315	360	280	300				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	57	10	5	5	45		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	118	131	130	140				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	48	48				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	30	79	80	80				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	100	100	100				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	10	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	25	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	21	20	20				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+40x1.315+1x1.398	200	200	0	0	0	0				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	98	17	114				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	107	8	107				
79	Bhairat 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	94	54	95				
**	Import (Tripura)	India		160	160	136	156	125	165				
Cumilla Zone Total			3193	3169	1524	1902	1522	1834	308	0			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	93	103	108	108	99		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20				
83	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	39	87	40	105				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	195	200	200				
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	4	0	50	0				
87	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	23	24	22	22				
Mymensingh Zone Total			622	614	380	429	442	455	99	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.07.22 (Yesterday)		25.07.22 (Today)		24.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT-1 Under maint.			
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	42		48	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	5	8	8	46	Gas Shortage			
91	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	Gas Shortage		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage		
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	62	61	62					
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	45	10	10	41		Gas shortage		
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	195	210	210					
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas shortage		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas shortage		
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	255	300	300					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	401	400	400					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	384	400	400					
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	6	6	6	44		Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	10	5	5	40		Gas Shortage		
Sylhet Zone Total						2522	2477	1446	1466	1503	1504	328	559	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	215	165	200	200	245			Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	46	0	44					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	73	40	73					
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17					
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	85	105					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	31	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	82	33	115					
116	Noapara 40 MW PP (Kharajahan Ali)	HFO (NENP)	5*8.5	40	40	8	32	8	32					
**	Bheramara (HVDC)	India		1000	1000	903	869	877	862					
Khulna Zone Total						2388	2384	1311	1389	1360	1448	245	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	22	2	22					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	82	0	66	66	194			Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	870	1060	910	1100					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17					
122	Bhola 220MW CCPP (Nutan Bidyut Bt)	Gas/HSD (IPP)	2x75+1x70	220	220	182	186	182	220					
Barishal Zone Total						1958	1958	1162	1300	1176	1457	194	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	16	16	16					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	32	16	32					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	88	88					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	16	16					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	34	25	34					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	35	35					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	173	135	178	150	75			Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	155	0	0	220			Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	152	127	164	164	93			Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	399	312	330	350	102			Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	25	8	8					
138	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	75	113	75	113					
139	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	70	113	70	113					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0					
Rajshahi Zone Total						2129	2129	1065	1234	1060	1152	661	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200					
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2.3	113	113	85	106	92	105					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Malpara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	40	108	108	108					
Rangpur Zone Total						800	720	327	414	408	413	85	85	
Sub-total: Plants in operation						22058	21680	10467.0	11737	10664	11831	3173	1859	
(B) Plants under long term maintenance/ contract expired														
148	Jamtirur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				Contract Expired	
149	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				Contract Expired	
150	Bosila 108MW PP(CLO)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Forced Outage	
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				Contract expired	
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22482	21680	10467	11737	10664	11831	3173	1859	
(C) Actual data of 24.07.22 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	12579	MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	:	11997	MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	:	11737	MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	:	10428	MW, at = 8:00 hrs										
05.	Day-peak Generation (Generation end)	:	10467	MW, at = 9:00 hrs										
06.	Evening-peak Generation (Generation end)	:	11737	MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	:	842	MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10096	MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :													
	a) Gas limitation	:	3088	MW										
	d) Coal supply Limitation	:	85	MW										
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	1859	MW										
10.	Total Energy (Generation + India Import)	:	263.15	MKWh										
	By Gas = 127.971 MKWh	By Oil =		77.281 MKWh										
	By Coal = 29.487 MKWh	By Hydro =		2.988 MKWh										
	By Solar= 0.723 MKWh													
11.	Total Gas Supplied	:	969.36	MMCFD										
(D) Forecast of 25.07.22 (Today) Monday :														
01.	Maximum Demand	:	14000	MW	(Generation end)									
02.	Maximum Generation	:	11831	MW	(Generation end)									
03.	Reserve/Shortage	:	-2169	MW	(Generation end)									
04.	Maximum Load-shed	:	1998.7519	MW	At evening peak (Sub-station end)									
05.	Total Generation	:	313.89	MKWh										
06.	Probable Max. Temperature in Dhaka :													