

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2022					Day : Sunday					Date : 31.07.22				
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 12935 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 91.96 ft					Today = 91.98 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.07.22 (Yesterday)		31.07.22 (Today)		30.07.22 (Yesterday)		31.07.22 (Today)			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	82	82	82					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	347	300	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	409	408	400	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	95	92	0	0	118		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	0	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	94	24	94					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power(Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	52	52	52					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	100	147	100	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35	19		Fuel Oil Shortage		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	260	200	270					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	102	117	100	117					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0					
27	Brannhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	18	91	17	91					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	12	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	38	55	55	55					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	1	24	92					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	25	88	25	88					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0	102		S/D after fire incident		
Dhaka Zone Total				6004	5847	2564	3061	2455	3114	1032	762			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	92	81	115	115			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	34	37	35	37					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	87	85	87					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	0	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	88	290	150	290					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	90	21	90					
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	51	51	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	52	55	51	55			Problem in transformer set		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			6	20	10	15					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	87	81	80	81					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	36	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	92	100	92					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	20	100					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	80	80	80	80					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108					
Chattogram Zone Total				2442	2382	1033	1368	1109	1397	0	555			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	41	35	41					
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	210	211	200	211					
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	350	320	300	330					
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	360	360	300	360					
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	56	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	26	100	75	169		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	43	43					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	134	140	125	140					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	48	40	40	40					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	135	135	135	135					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	200	50	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+68x1.05+15x1.08	200	200	0	0	0	0					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	114	17	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	106	116	107	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	18	53	17	53	62		Fuel Oil Shortage		
**	Import (Tripura)	India		160	160	148	106	143	166					
Cumilla Zone Total				3193	3169	1869	2121	1792	2236	231	0			
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	99	98	100	100	104		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	105	50	105					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	87	189	180	189					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	18	18	18					
Mymensingh Zone Total				622	614	277	430	420	432	104	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.07.22 (Yesterday)		31.07.22 (Today)		30.07.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation			
						Day	Evening	Day	Evening	MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	33	53	33	51				
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.	
92	Hobigarij 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	60	64				
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	77	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	16	24				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	300	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	401	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Minor Inspection	
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	34	25	34	16		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	30	45	30	45				
Sylhet Zone Total				2522	2477	1335	1417	1376	1434	16	943		
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	160	160	160	250		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	45				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	65		44	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	72	35	72				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	88	105	105	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	79	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	16	16	16	99		Fuel Oil Shortage	
116	Noapara 40 MW PP (Kharjahan Ali)	HFO (NENP)	5'8.5	40	40	8	8	8	8	32		Fuel Oil Shortage	
**	Bheramara (H/DC)	India		1000	1000	894	839	861	876				
Khulna Zone Total				2388	2384	1316	1310	1285	1347	381	44		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32			Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	32	23	32				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	52	56	60	60	138		Gas Shortage	
120	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	950	1080	970	1100				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	183	222	225	220				
Barishal Zone Total				1958	1958	1222	1422	1294	1461	138	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24		18	Turbocharger problem	
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	41	0	41		30	Maintenance ongoing	
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	81	88	85	88				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	31	32	32	32				
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	35	30	35		15	1 Engine TIC problem, 1 engine has high temperature.	
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	144	134	140	140		76	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	215	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	148	137	140	140	83		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	286	300	300	128		Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	113	75	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	70	113	70	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total				2129	2129	1089	1303	919	1111	678	63		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	201	200	200				
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	75	113	92	113				
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	52	90	90	90				
Rangpur Zone Total				800	720	331	404	390	403	85	85		
Sub-total: Plants in operation				22058	21680	11036.0	12836	11040	12935	2665	2452		
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			Contract expired	
152	Bogra 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	11036	12836	11040	12935	2665	2452		
(C) Actual data of 30.07.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13500	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13240	MW, at =	21:00 hrs	Zone Demand Supply Load Shed Zone Demand Supply Load Shed							
03.	Highest Generation (Generation end)	:	12893	MW, at =	22:00 hrs	Dhaka 4701 4434 267 Mymensingh 1140 973 167							
04.	Minimum Generation (Generation end)	:	10748	MW, at =	7:00 hrs	Chattogram 1397 1361 36 Sylhet 567 567 0							
05.	Day-peak Generation (Generation end)	:	11036	MW, at =	9:00 hrs	Khulna 1663 1518 145 Barishal 410 410 0							
06.	Evening-peak Generation (Generation end)	:	12836	MW, at =	21:00 hrs	Rajshahi 1371 1234 137 Rangpur 743 666 77							
07.	Evening Peak Load-shed (Sub-station end)	:	981	MW, at =	21:00 hrs	Cumilla 1248 1096 152							
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10816	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				Total 13240 12259 981							
a)	Gas limitation	:	2580	MW		13. Fuel cost : (a) Gas = 156278155 Taka (c) Coal = 264548449 Taka							
d)	Coal supply Limitation	:	85	MW		b) Oil = 1086679393 Taka Total = 1507505998 Taka							
b)	Low water level in Kapitai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2452	MW									
10.	Total Energy (Generation + India Import)	:	274.05	MKWh		14. Maximum Temperature in Dhaka was : 34.6° C							
	By Gas = 135.242 MKWh			By Oil = 79.352 MKWh		15. Export through East-West interconnections :							
	By Coal = 31.366 MKWh			By Hydro = 2.246 MKWh		At evening peak-hour : 11036 MW, at 21:00 hrs							
	By Solar= 1.211 MKWh					Maximum : 336 MW, at 19:00 hrs							
11.	Total Gas Supplied	:	1034.20	MMCFD		Energy : 0 MKWh							
(D) Forecast of 31.07.22 (Today) Sunday :													
01.	Maximum Demand	:	14000	MW (Generation end)		04.	Maximum Load-shed	:	981	MW At evening peak (Sub-station end)			
02.	Maximum Generation	:	12935	MW (Generation end)		05.	Total Generation	:	297.58	MKWh			
03.	Reserve / Shortage	:	-1065	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.3° C				