

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date :		31-Jul-22				Page -2	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4331250	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	300	6993909	Gas shortage
4	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	82	1951863	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	399	9760770	
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	260	7442000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	5010700	Gas shortage & GT-2 S/D.
9	Meghnaghat 100 MW(IEIL)	NENP	12'8.9	100	87	869760	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1201974	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	420192	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	612000	Gas shortage
17	Siddiganj 100 PP(Dutch Bangla)	NENP	12'8.9	100	89	879360	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	0	0	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	94	736848	Engine problem
20	Katpotti 52 MW PP (Sinha)	IPP	17'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	504360	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	147	2160000	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	330829	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	265244	
25	Bosila 108MW PP(CLC)	IPP	12'8.75+1'13.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'18.73	80	52	1214880	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	586900	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	29	657600	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	49	1124482	#REF!
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	195	3879053	Engine problem
32	Keraniganj 300 MW PP (APRI)	IPP	256'1.4	300	0	0	Fuel conservation
33	Bramhangaoon 100 MW PP (Aggreko)	IPP	114'0.959	100	0	0	Fuel conservation
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	144	2894400	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2170308	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	96	1040640	Fuel shortage
38	Manikgonj 162MW PP(MRGL)	IPP	9'18	162	162	2178720	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	112789	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	52	1208880	
Dhaka area Total				5847	2991	60539711	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	590194	
43	Teknaf 20MW PP (Solarteck)	IPP	20	20	0	118530	
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	37	838090	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	114	2729324	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2304181	
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	43	457440	Engine problem
50	Dohazari-Kaishah 100 MW Peaking	PDB	8'17	102	68	1317662	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	56	1530120	Engine problem
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	90	880320	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	17	382992	Engine problem
*	Malancha, Ctg. EPZ (Unlited)		5'8.73+3'9.34	0	27	459360	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	86	2049600	Engine problem
55	Kaptai 7 MW. Solar PP	PDB	7.4	7	0	32279	
56	Anwara 300 MW PP (Unlited)	IPP	17'17+24	300	215	2549236	Engine problem
57	Jodica Power	IPP	3'18.55+1'3.6	54	54	1054437	
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	92	2455552	Engine problem
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	100	961920	
60	Anilma Energy Ltd.	IPP	6'21.2	116	108	2512855	Engine problem
Chattogram area Total				2382	1337	25524082	
61	Ashuganj TPP Unit-3	APSCOL	1'150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCOL	1'150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCOL	1'150	134	0	0	Gas shortage
63	Ashuganj 225 MW CCPP	APSCOL	1'142+1'75	221	184	4707000	#REF!
64	Ashuganj 450 MW CCPP(North)	APSCOL	1'360	360	350	4199000	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCOL	1'360	360	320	8085000	FGMO
65	Ashuganj 420 MW CCPP(East)	APSCOL	284'1+136'1	284	0	0	On test.
65	Ashuganj 50 MW PP	APSCOL	14'3.68	45	41	940536	Gas shortage
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	55	1161120	
67	Ashuganj 195MW PP (APSCOL-Unlited)	IPP	20'9.73+1'16	195	16	2525818	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	1029557	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	137	3134690	Engine problem
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	30	891928	Engine problem
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	128	3186710	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	200	2536320	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	448704	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	237420	
**	Impoport (Tripura)	Imported power	0	160	162	3691200	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	731700	
76	Jangalia 52 MW PP (Lakshnaw)	IPP	6'8.98	52	34	3876714	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	494160	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Fuel conservation
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	104	976980	
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	115	2606520	
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	887760	33 kV feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5+22.5	115	35	908150	Fuel shortage
Cumilla Area Total				3169	2072	43768157	
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	100	2040960	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	465300	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	6550	
87	Mymensingh 200 MW PP (Unlited)	IPP	9.78'21	200	144	2390400	
88	Jamalpur 115 MW PP (Unlited)	IPP	9.78'12	115	77	1335600	Engine problem
89	Sutiahal 50 MW Solar PP	IPP	50	0	0	119550	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	18	437280	Engine problem
Mymensingh Area Total				614	361	6795640	
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	1027000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	41	959960	Machine problem
93	Kushazari 163 MW CCPP (KP)	IPP	1'109+1'54	163	110	2632663	ST under maint.
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	928800	
96	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	43	872136	Engine problem
96	Hobiganj 11MW PP Colidence-E	SIPP, REB	4'2.90	11	11	264000	
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	62	1463136	
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	81	967680	Engine problem
99	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	220	5328950	
101	Sylhet. 20 MW GTPP	PDB	1'20	20	0	0	
102	Sylhet 50MW PP (EPL)	NENP	27'2	50	34	787700	Gas shortage
103	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	551736	Gas shortage
104	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	7621500	FGMO
105	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	402	9522000	
105	Sylhet 10MW PP (Desh)	RPP	8'1.95	10	9	228780	
106	Bibiyana South 400 MW	PDB	400 MW	383	0	0	Under maint.
Sylhet Area Total				2477	1413	33158041	
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2'500	1000	844	21052363	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	16	383040	Engine problem
109	Fandpur 50 MW Peaking PP	PDB	6'8.99	54	35	377290	Engine problem
110	Khulna 225 MW CCPP	NWPQCL	1'150+1'75	230	0	0	Fuel conservation
111	Gopalganj 100 MW Peaking PP	PDB	16'6.88	109	62	623104	Line OIL
112	Bheramara 410 MW CCPP	NWPQCL	1'278+1'132	410	160	3924576	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	8	194250	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	54	853920	Fuel shortage
115	Madhumati 100 MW PP	NWPQCL	6'18	105	105	2326032	
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	570980	
	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
Khulna Area Total				2477	1413	33158041	
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	32	565056	Line OIL
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	34	640086	Engine problem
119	Bhola 225 MW CCPP	PDB	2'63+1'68	194	60	1429	