

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022				Day : Friday				Date : 05.08.22				
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 12580 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 92.31 ft				Today = 92.73 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.08.22 (Yesterday)		05.08.22 (Today)		04.08.22 (Yesterday)		05.08.22 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation	Machines shut down	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	77	80	80			
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	333	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	408	411	412	412			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	94	8	94			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19			
17	Summit Power,(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	52	52	51	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	28	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	51	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	50	132	50	132			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	35	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	112	275	110	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	96	134	100	134			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0			
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	88	17	70			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	70	162			
33	Manikgonj 39MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	14	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	36	55	17	55			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	89	8	89			
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	86	8	86			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	2499	3105	2401	3100	1105	660	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	111	113	111	113			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0			
41	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	31	32	30	32			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	52	214	51	214			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	90	21	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	51	51	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	25	25	25			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			7	18	40	40			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	76	6	6	88			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	20	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	56	56	55	56			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108			
Chattogram Zone Total				2442	2382	830	1151	881	1255	0	555	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	37	34	37			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	206	209	200	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	295	260	300	300	100		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	310	280	300	300	80		Gas Shortage
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	56	30	30	30			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	133	130	133			
68	Titao 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	40	48	40	48			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	142	139	142			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	100	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	21	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	19	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+68x1.05+15x1.085	200	200	0	0	0	0			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	98	114	105	113			
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	75	56	60	60			
**	Import (Tirupura)	India		160	160	154	158	143	166			
Cumilla Zone Total				3193	3169	1830	2003	1783	2075	367	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	80	101	80	100	101		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	18	20			
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	79	47	79			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	180	48	180			
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	0	0	0			
Mymensingh Zone Total				622	614	209	380	245	379	101	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.08.22 (Yesterday)		05.08.22 (Today)		04.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation			
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	44		26	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	53	33	53				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.	
92	Hobigari 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	61				
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	50	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	221	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	8	8	8				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	295	300	300				
101	Bibiyaan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	403	400	400				
102	Bibiyaan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Minor Inspection	
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	33	33	33	17		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	49	49	30	49				
Sylhet Zone Total				2522	2477	1368	1409	1338	1410	37	942		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	140	135	150	150	275		Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	15	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	76	50	75		33	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	28	0	20				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16	99		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	908	907	925	925				
Khulna Zone Total				2388	2384	1277	1314	1361	1339	406	33		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32			Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	30	23	30				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	88	85	88	106		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	880	1040	1110	1100				
121	Potuaakali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas:HSD (IPP)	2x75+1x70	220	220	220	219	225	220				
Barishal Zone Total				1958	1958	1221	1409	1459	1470	106	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	24	32	24	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	41	0	40		30	Maintenance ongoing	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	90	50	90				
128	Katakhat 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	24	32				
129	Katakhat 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	33	33	30	33		17	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	178	182	150	182		28	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	211	218	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	143	142	145	145	78		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	275	260	300	300	154		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	21	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total				2129	2129	1126	1346	916	1170	651	65		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	66	92	56	92				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	52	90	52	90				
Rangpur Zone Total				800	720	321	382	316	382	85	85		
Sub-total: Plants in operation				22058	21680	10681.0	12499	10700	12580	2858	2340		
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	Taka
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	10681	12499	10700	12580	2858	2340		
(C) Actual data of 04.08.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	13800	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13060	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12549	MW, at =	22:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	10656	MW, at =	8:00 hrs	Dhaka	4455	4210	245	Mymensingh	1088	888	200
05.	Day-peak Generation (Generation end)	:	10681	MW, at =	9:00 hrs	Chattogram	1444	1340	104	Sylhet	567	492	75
06.	Evening-peak Generation (Generation end)	:	12499	MW, at =	21:00 hrs	Khulna	1544	1394	150	Barishal	386	386	0
07.	Evening Peak Load-shed (Sub-station end)	:	1199	MW, at =	21:00 hrs	Rajshahi	1430	1275	155	Rangpur	831	731	100
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10621	MW, at =	5:00 hrs	Cumilla	1317	1147	170				
09.	Generation shortfall at evening peak due to :	:				Total				13060	11861	1199	
	a) Gas limitation	:	2773	MW		13.	Fuel cost :	(a) Gas = 152376091 Taka			(c) Coal = 254290062 Taka		
	d) Coal supply Limitation	:	85	MW			(b) Oil = 1078616214 Taka	Total = 1485282367 Taka					
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2340	MW		14.	Maximum Temperature in Dhaka was : 34.8° C						
10.	Total Energy (Generation + India Import)	:	270.10	MW		15.	Export through East-West interconnections :						
	By Gas = 132.570 MKWH			By Oil = 77.700 MKWH		At evening peak-hour			:	10681	MW, at	21:00 hrs	
	By Coal = 30.224 MKWH			By Hydro = 2.693 MKWH		Maximum			:	400	MW, at	22:00 hrs	
	By Solar= 1.170 MKWH					Energy			:	0	MW		
11.	Total Gas Supplied	:	1006.36	MMCFD									
(D) Forecast of 05.08.22 (Today) Friday :													
01.	Maximum Demand	:	13000	MW	(Generation end)	04.	Maximum Load-shed : 387 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	12580	MW	(Generation end)	05.	Total Generation : 279.81 MKWh						
03.	Reserve / Shortage	:	-420	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 34.1° C						

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)