

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month August, 2022					Day : Sunday				Date : 07.08.22					
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 12380 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 93.01 ft				Today = 93.54 ft					
									Rule Curve = 90.92 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.08.22 (Yesterday)		07.08.22 (Today)		06.08.22 (Yesterday)		06.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation		Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	0	0	0					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	88	93	90	93					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	343	267	300	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225		225		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	410	394	412	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	97	95	0	0		115		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335		Gas Shortage	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	40	8	50					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.3	80	80	52	49	50	50					
18	Maons 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	33	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	50	51	51					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	50	125	50	132					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	260	110	275					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	99	149	100	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0					
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	17	104					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	70	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	4	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	50	8	50					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	50	8	50					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total				6004	5847	2546	2657	2084	2727	1010	660			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	111	111	111	111				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	0	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	25	25	32					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	87	68	90					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	16	214	50	214					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	90	21	90					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	24	26	26					
51	Barabakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	15	17	17					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	32	10	30					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	89	81	90	95					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	20	100					
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	56	56	56	56					
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108					
Chattogram Zone Total				2442	2382	795	1185	860	1236	0	555			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	37	37	37					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*175	221	221	208	202	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	305	305	320					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	325	280	310	330		80		Gas Shortage	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0				On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	55	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8		187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	132	127	128	132					
68	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	40	32	40					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	142	135	142	142					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	68	100	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	9	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	20	20	20					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.036	200	200	0	0	0	0					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	78	113	78	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	58	75	60	60					
**	Impoport (Tripura)	India		160	160	110	164	143	166					
Cumilla Zone Total				3193	3169	1765	1936	1804	2141	267	0			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	103	101	102	102		101		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	20	20					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	78	49	79					
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	171	48	180					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	4</								

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.08.22 (Yesterday)		07.08.22 (Today)		06.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	50	33	53				
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	61	61				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	221	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	8	16				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	290	290				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	399	403	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Minor Inspection	
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	32	31	32	18		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	30	49	30	49				
Sylhet Zone Total				2522	2477	1300	1420	1298	1417	38	943		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	170	150	180	185	260		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	15	32				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	19	65	20	70		44	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	35	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	0	35				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	105	105	105	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	49	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16	99		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8	32		Fuel Oil Shortage	
**	Bheramara (HVDG)	India		1000	1000	913	914	930	930				
Khulna Zone Total				2388	2384	1272	1379	1366	1381	391	44		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32			Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	32	23	30				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	86	88	88	108		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	930	1060	1110	1100				
121	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	219	220	225	220				
Barishal Zone Total				1958	1958	1275	1430	1462	1470	108	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	24	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	41	0	40		30	Maintenance ongoing	
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	79	90	80	86				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	32	32				
129	Katakhal 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	34	42	42	42				
130	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	33	33	33	33		17	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	189	178	188	190				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	140	216	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	160	145	162	167	75		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	330	296	350	350	118		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	21	21				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total				2129	2129	1141	1371	1062	1245	584	65		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Storage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	92	56	92				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatulia 8 MW Solar PP (Sympha Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
147	Thakurgonj 115MW PP (Energyrac)	HFO (IPP)	6*20	115	115	52	90	52	90				
Rangpur Zone Total				800	720	310	382	316	382	85	85		
Sub-total: Plants in operation				22058	21680	10629.0	12132	10523	12380	2584	2352		
(B) Plants under long term maintenance/ contract expired													
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Kalpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	10629	12132	10523	12380	2584	2352		
(C) Actual data of 06.08.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13800	MW	at =	21:00 hrs							
02.	Max. Demand at eve. peak (Sub-station end)	:	12991	MW	at =	21:00 hrs							
03.	Highest Generation (Generation end)	:	12170	MW	at =	22:00 hrs							
04.	Minimum Generation (Generation end)	:	10552	MW	at =	8:00 hrs							
05.	Day-peak Generation (Generation end)	:	10629	MW	at =	9:00 hrs							
06.	Evening-peak Generation (Generation end)	:	12132	MW	at =	21:00 hrs							
07.	Evening Peak Load-shed (Sub-station end)	:	1537	MW	at =	21:00 hrs							
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10290	MW	at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	2499	MW									
	d) Coal supply Limitation	:	85	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2352	MW									
10.	Total Energy (Generation + India Import)	:	269.55	MKWh									
	By Gas =	135.237	MKWH	By Oil =	73.994	MKWh							
	By Coal =	30.919	MKWH	By Hydro =	2.599	MKWh							
	By Solar=	1.042	MKWH										
11.	Total Gas Supplied	:	1000.91	MMCFD									
(D) Forecast of 07.08.22 (Today) Sunday :													
01.	Maximum Demand	:	14000	MW	(Generation end)								
02.	Maximum Generation	:	12380	MW	(Generation end)								
03.	Reserve / Shortage	:	-1620	MW	(Generation end)								
04.	Maximum Load-shed	:	1493.404638	MW	At evening peak (Sub-station end)								
05.	Total Generation	:	310.09	MKWh									
06.	Probable Max. Temperature in Dhaka :	:	35.8° C										

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation