

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022					Day : Tuesday					Date : 09.08.22				
Probable Maximum Demand : 13600 MW					Probable Maximum Generation : 13615 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 94.17 ft		Today = 94.92 ft		Rule Curve = 91.56 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.08.22 (Yesterday)		09.08.22 (Today)		08.08.22 (Yesterday)		08.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	300	305	305					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	83	82	86	86					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	214	310	320	146			Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	393	410	412					
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335			Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	32	8	32					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	19	19					
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	52	48	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	28	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	49	51	51					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	128	50	132					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	258	110	275					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	90	149	90	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	246	300	250	300					
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	98	97	97	96					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	93	97	50	100					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	32	17	52					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	18	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	35	55					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	48	8	48					
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	7	31	8	32					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total					6004	5847	2459	3240	2750	3446	1251	660		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	117	115	118	118				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	105	105	105					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	1	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	37	25	35					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	68	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		Awaiting for HGI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	214	52	210					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	90	21	90					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	34	26	34					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	21	5	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	77	12	80					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	17	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	20	100					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108					
Chattogram Zone Total					2442	2382	740	1197	747	1220	0	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	38	39	39					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	198	190	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	320	305	320					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	320	320	320					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0				On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	49	52	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	128	123	145					
68	Titao 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	38	38	38					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	135	121	142	142					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	17	34					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	9	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+68x1.05+15x1.08	200	200	196	200	120	200					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	115	38	113					
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	72	68	71	71					
**	Import (Tirupura)	India		160	160	154	158	143	166					
Cumilla Zone Total					3193	3169	1908	2117	1825	2189	187	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	70	96	95	100	106			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	78	48	78					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	180	48	180					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	21	0	50	0					
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	11	12	12	12					
Mymensingh Zone Total					622	614	221	388	277	392	106	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.08.22 (Yesterday)		09.08.22 (Today)		08.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance							
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation	Machines shut down for : (MW)	Description/ Remarks	Probable start-up date						
						Day	Evening	Day	Evening										
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	GT-1 Under maint.							
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.							
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	53	22	53										
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.							
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11										
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	62	62										
94	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.							
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81										
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	221	220	220										
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage							
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10										
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16										
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	280	310										
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	404	400	400										
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Minor Inspection							
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work							
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	31	31	31	19		Gas Shortage							
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	30	49	20	49										
Sylhet Zone Total				2522	2477	1296	1431	1276	1437	39	943								
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0										
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	150	155	150	170	255		Gas Shortage							
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	21	38	15	38										
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	60	63	60	70		46	Maintenance ongoing							
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	237	229	225	225										
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	55	79	60	96										
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	0	70										
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	89	89	105	105										
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	100	0										
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	22	16	32	93		Fuel Oil Shortage							
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	8	8	32		Fuel Oil Shortage							
**	Bheramara (HVDC)	India		1000	1000	915	914	928	928										
Khulna Zone Total				2388	2384	1617	1650	1667	1742	380	46								
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	48	64	64			Line Overload							
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	30	23	30										
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	88	87	88	88	107		Gas Shortage							
120	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	600	570	620	620										
121	Potuaakali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	90	54	0	54			Line Overload							
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas:HSD (IPP)	2x75+1x70	220	220	220	222	225	220										
Barishal Zone Total				1958	1958	1064	1011	1020	1076	107	0								
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage							
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage							
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	32	32	32		18	Turbocharger problem							
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	169	179	100	188										
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	17	0	40		54	Maintenance ongoing							
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	51	80	80	86										
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	32	32	32		18	Under maint.							
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42										
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	33	33	33	33		17	Under maint.							
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	179	167	188	190										
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	215	180	210	210	220		Gas Shortage							
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	149	160	165	71		Gas Shortage							
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	297	287	315	315	127		Gas Shortage							
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	21	21										
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52										
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	50	95	55	95										
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94										
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0										
Rajshahi Zone Total				2129	2129	1300	1429	1343	1606	589	107								
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	70	75	75	15		Coal Shortage							
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling							
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250										
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	97	70	92										
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
146	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0										
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	34	90	52	90										
Rangpur Zone Total				800	720	341	507	455	507	15	85								
Sub-total: Plants in operation				22058	21680	10946.0	12970	11360	13615	2674	2396								
(B) Plants under long term maintenance/ contract expired																			
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0										
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0										
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0										
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0										
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020							
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022							
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0										
Gross Total				22482	21680	10946	12970	11360	13615	2674	2396								
(C) Actual data of 08.08.22 (Yesterday) Monday :																			
01.	Max. Demand at eve. peak (Generation end)	:	13900	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
02.	Max. Demand at eve. peak (Sub-station end)	:	13374	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed						
03.	Highest Generation (Generation end)	:	13047	MW, at =	22:00 hrs		MW	MW	MW		MW	MW	MW						
04.	Minimum Generation (Generation end)	:	10946	MW, at =	9:00 hrs	Dhaka	4788	4565	223	Mymensingh	1042	901	141						
05.	Day-peak Generation (Generation end)	:	10946	MW, at =	9:00 hrs	Chattogram	1274	1274	0	Sylhet	621	621	0						
06.	Evening-peak Generation (Generation end)	:	12970	MW, at =	21:00 hrs	Khulna	1663	1535	128.4208834	Barishal	380	380	0						
07.	Evening Peak Load-shed (Sub-station end)	:	857	MW, at =	21:00 hrs	Rajshahi	1487	1340	147	Rangpur	855	738	117						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10442	MW, at =	5:00 hrs	Cumilla	1264	1164	100.2162239										
09.	Generation shortfall at evening peak due to :	:				Total		13374		12517		857							
a)	Gas limitation	:	2659	MW		13. Fuel cost :		(a) Gas = 148589814	Taka	(c) Coal = 168140565		Taka							
d)	Coal supply Limitation	:	15	MW				(b) Oil = 1510365860	Taka	Total = 1827096240		Taka							
b)	Low water level in Kaptai lake	:	0	MW															
c)	Plants under shut down/ maintenance	:	2396	MW		14. Maximum Temperature in Dhaka was :		34.5° C											
10.	Total Energy (Generation + India Import)	:	278.45	MKWh		15. Export through East-West interconnections :													
	By Gas = 129.916 MKWH			By Oil =	97.393 MKWh	At evening peak-hour		10946		MW, at		21:00 hrs							
	By Coal = 21.304 MKWH			By Hydro =	2.727 MKWh	Maximum		454		MW, at		5:00 hrs							
	By Solar= 1.262 MKWH					Energy		0		MKWh									
11.	Total Gas Supplied	:	991.46	MMCFD															
(D) Forecast of 09.08.22 (Today) Tuesday :																			
01.	Maximum Demand	:	13600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)								
02.	Maximum Generation	:	13615	MW	(Generation end)	05.	Total Generation	:	290.25	MKWh									
03.	Reserve / Shortage	:	15	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.6° C										