

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022					Day : Wednesday					Date : 10.08.22				
Probable Maximum Demand : 13800 MW					Probable Maximum Generation : 13200 MW					Rule Curve = 91.56 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 94.92 ft.					Today = 95.34 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.08.22 (Yesterday)		10.08.22 (Today)		09.08.22 (Yesterday)		10.08.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	305	300	300	300					
4	Ghorasah 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	82	83	83	83					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	288	251	260	260	109		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	396	282	270	280					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	32	8	32	70		Fuel Oil Shortage		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	49	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	50	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	49	128	50	128					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	260	100	260					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	43	149	90	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	301	224	250	300					
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	98	90	100					
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	91	90	50	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	33	17	33	71		Fuel Oil Shortage		
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	35	55					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	50	8	50	50		Fuel Oil Shortage		
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	32	8	32	68		Fuel Oil Shortage		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	2697	3112	2531	3200	1473	660				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	118	118	118			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	102	107	105	107					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0					
41	Racozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	24	44	25	44					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	68	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	69	212	52	210					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	90	21	90					
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51		Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	26	26	26					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			12	27	5	21					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	83	12	83					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	20	100					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33	67		Fuel Oil Shortage		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108					
Chattogram Zone Total			2442	2382	719	1235	747	1227	118	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	34	37	37	37					
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	207	209	190	210					
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	280	355	300	355					
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	280	365	300	360					
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	52	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	125	123	125					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	38	38	38					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	128	135	130	135					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	34	17	34					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	20	20					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+68x1.05+15x1.08	200	200	196	200	0	200					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	88	17	88					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	114	38	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	57	75	71	75					
**	Import (Tripura)	India		160	160	112	70	90	80					
Cumilla Zone Total			3193	3169	1738	2119	1593	2127	187	0				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	68	98	80	100	104		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	78	48	78					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	180	48	180					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	10	12	12	12					
Mymensingh Zone Total			622	614	255	390	262	392	104	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.08.22 (Yesterday)		10.08.22 (Today)		09.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : r Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening					
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	0	0	0					
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110		54	ST under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	64	62	64					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	221	220	220					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	12	12	12					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	280	300					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	230	200	230		153	Minor Inspection		
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	29	30	30	30	20		Gas Shortage		
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	30	30	0	0					
Sylhet Zone Total				2522	2477	1286	1580	1429	1552	40	713			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	150	150	150	150	260		Gas Shortage		
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	10	43					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	45	30	50		64	Maintenance ongoing		
110	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	230	230	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	68	80	60	90					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	51	0	50					
113	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	105	105	105	105					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	32	16	32	83		Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	8	8	8	32		Fuel Oil Shortage		
**	Bheramara (HVDC)	India		1000	1000	911	909	924	924					
Khulna Zone Total				2388	2384	1605	1653	1628	1677	375	64			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16			Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	20	15	20					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	88	88	88	88	106		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	600	620	620					
121	Potashkhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	50			Line Overload		
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	70	215	225	220					
Barishal Zone Total				1958	1958	742	939	964	1014	106	0			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	32	32	32		18	Turbocharger problem		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	175	180	100	180					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40		71	Maintenance ongoing		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	23	80	50	80					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	32	40		10	Under maint.		
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	33	34		16	Under maint.		
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	173	168	170	170	42		Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	160	35	210	210	220		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	146	148	150	150	72		Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	281	296	300	300	118		Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	21	21					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52					
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	2	0	6	0					
Rajshahi Zone Total				2129	2129	1165	1285	1228	1509	623	115			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	82	75	82					
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250					
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	64	98	70	98					
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	17	72	20	72					
Rangpur Zone Total				800	720	411	502	423	502	0	85			
Sub-total: Plants in operation				22058	21680	10618.0	12815	10805	13200	3026	2192			
(B) Plants under long term maintenance/ contract expired														
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	Taka	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0					
Gross Total				22482	21680	10618	12815	10805	13200	3026	2192			
(C) Actual data of 09.08.22 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	:	13400	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12830	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12815	MW,	at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	10292	MW,	at =	9:00 hrs	Dhaka	4504	4395	109	Mymensingh	1054	914	140
05.	Day-peak Generation (Generation end)	:	10618	MW,	at =	12:00 hrs	Chattogram	1316	1316	0	Sylhet	614	614	0
06.	Evening-peak Generation (Generation end)	:	12815	MW,	at =	21:00 hrs	Khulna	1477	1407	70	Barishal	299	299	0
07.	Evening Peak Load-shed (Sub-station end)	:	539	MW,	at =	21:00 hrs	Rajshahi	1367	1292	75	Rangpur	907	852	55
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10360	MW,	at =	5:00 hrs	Cumilla	1292	1202	90				
09.	Generation shortfall at evening peak due to :	:					Total							
a)	Gas limitation	:	3026	MW			(a) Gas = 148168816 Taka							
d)	Coal supply Limitation	:	0	MW			(c) Coal = 172007914 Taka							
b)	Low water level in Kaptai lake	:	0	MW			(b) Oil = 1419331503 Taka							
c)	Plants under shut down/ maintenance	:	2192	MW			Total = 1739508233 Taka							
10.	Total Energy (Generation + India Import)	:	271.63	MW			14. Maximum Temperature in Dhaka was : 33.6° C							
	By Gas = 129.174 MKWH	By Oil =	91.632 MKWh				15. Export through East-West interconnections :							
	By Coal = 22.245 MKWH	By Hydro =	2.824 MKWh				At evening peak-hour	:	10618	MW,	at	21:00 hrs		
	By Solar= 1.194 MKWH						Maximum	:	262	MW,	at	21:00 hrs		
11.	Total Gas Supplied	:	1015.22	MMCFD			Energy	:	0	MW				
(D) Forecast of 10.08.22 (Today) Wednesday :														
01.	Maximum Demand	:	13800	MW	(Generation end)		04.	Maximum Load-shed	:	553	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13200	MW	(Generation end)		05.	Total Generation	:	292.51	MW			
03.	Reserve / Shortage	:	-600	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34° C				