

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022					Day : Monday				Date : 15.08.22			
Probable Maximum Demand : 13600 MW					Probable Maximum Generation : 13830 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 95.95 ft				Today = 95.95 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.08.22 (Yesterday)		15.08.22 (Today)		Rule Curve = 93.48 ft		14.08.22 (Yesterday)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down (MW)	
					Day	Evening	Day	Evening	MW			Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	80	80	80			
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	336	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	407	407	412	412			
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	93	37	95	95	173		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	50	8	50	52		Fuel Oil Shortage
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19			
17	Summit Power (Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	45	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	30	30	30			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105			
22	Kodde 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	128	16	128			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	18	35	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	278	80	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	142	43	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	11	303	300	300			
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	91	30	60	96			
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	94	70	50	100			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	50	51		Fuel Oil Shortage
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	3	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	49	8	50	51		Fuel Oil Shortage
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	8	50	30	50	50		Fuel Oil Shortage
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2464	3363	2747	3579	1272	660		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	101	101	101	101			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	42	19	42			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	17	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGI
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	123	214	118	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	90	21	90			
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51		Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	26	26	26	72		Fuel Oil Shortage
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			6	26	30	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	85	12	85			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	35	55	55	55			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	100	20	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	33	33	33	67		Fuel Oil Shortage
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
Chattogram Zone Total			2442	2382	712	1221	787	1311	190	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	35	35	35			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	195	211	200	211			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	270	280	300	90		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	325	300	325			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	53	52	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	132	100	132			
68	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	39	40	40			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	30	136	130	136			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+68x1.05+15x1.08	200	200	52	30	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	0	0	0			
78	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	29	57	30	57			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	61	73	74	75			
**	Import (Tirupur)	India		160	160	128	162	143	166			
Cumilla Zone Total			3193	3169	1687	1901	1866	2112	277	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	65	99	100	100	103		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	69	79	78	100			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	78	186	48	180			
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	37	0	50	0			
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	9	12	12	12			
Mymensingh Zone Total			622	614	278	398	312	414	103	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.08.22 (Yesterday)		15.08.22 (Today)		14.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	30	30		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	11	0	0				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	62	64				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	78	25	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	200	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	9	9				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	270	300	300				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	402	400	400				
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	375	391	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	17	11	17	33		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	10	10	10	10	40		Gas Shortage	
Sylhet Zone Total				2522	2477	1436	1523	1498	1581	110	710		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	170	165	170	170	245		Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	0	36				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	70		39	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	229	231	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	20	10	90	90				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	10	53	17	52	52		Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	89	70	90	105				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	24	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	66	99		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khenjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	32	32	32		Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	895	892	912	912				
Khulna Zone Total				2388	2384	1437	1551	1652	1758	428	39		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	23	15	23				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	55	87	144	144	107		Gas Shortage	
120	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	460	490	620	620				
121	Potuaakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	50	110				
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas:HSD (IPP)	2x75+1x70	220	220	206	70	0	0				
Barishal Zone Total				1958	1958	733	753	939	1007	107	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	32	32		18	Turbocharger problem	
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	127	30	80	175				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	0	40				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	80	50	80				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	16	40		10	Under maint.	
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	33	33		17	Under maint.	
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	152	153	150	160	57		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	130	130	220	220	220		Gas Shortage	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	156	147	150	150	73		Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	333	328	330	330	86		Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	21	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2129	2129	1140	1265	1254	1532	607	45		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	70	83	70	83				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	240	250	250				
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	69	112	70	113				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Wajpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	72	17	90				
Rangpur Zone Total				800	720	392	507	415	536	0	85		
Sub-total: Plants in operation				22058	21680	10279.0	12482	11470	13830	3094	2094		
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	10279	12482	11470	13830	3094	2094		
(C) Actual data of 14.08.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	12750	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12331	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12486	MW, at =	23:00 hrs	Dhaka	4348	4288	60	Mymensingh	1117	930	187
04.	Minimum Generation (Generation end)	:	10268	MW, at =	8:00 hrs	Chattogram	1329	1329	0	Sylhet	601	601	0
05.	Day-peak Generation (Generation end)	:	10279	MW, at =	9:00 hrs	Khulna	1343	1343	0	Barishal	268	268	0
06.	Evening-peak Generation (Generation end)	:	12482	MW, at =	20:00 hrs	Rajshahi	1250	1250	0	Rangpur	853	853	0
07.	Evening Peak Load-shed (Sub-station end)	:	247	MW, at =	20:00 hrs	Cumilla	1223	1223	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9926	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				Total							247
	a) Gas limitation	:	3094	MW		(a) Gas = 153530052 Taka							156299393 Taka
	d) Coal supply Limitation	:	0	MW		(b) Oil = 1217483632 Taka							1527313077 Taka
	b) Low water level in Kaptai lake	:	0	MW		(c) Coal =							
	c) Plants under shut down/ maintenance	:	2094	MW		Total =							
10.	Total Energy (Generation + India Import)	:	266.61	MW		Maximum Temperature in Dhaka was :							31.8° C
	By Gas = 135.699 MKWH	By Oil =	82.349 MKWH			Export through East-West interconnections :							
	By Coal = 20.262 MKWH	By Hydro =	2.417 MKWH			At evening peak-hour	:	10279	MW, at	20:00 hrs			
	By Solar= 0.691 MKWH					Maximum	:	182	MW, at	20:00 hrs			
11.	Total Gas Supplied	:	1014.68	MMCFD		Energy	:	14654.487	MW				
(D) Forecast of 15.08.22 (Today) Monday :													
01.	Maximum Demand	:	13600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13830	MW	(Generation end)	05.	Total Generation	:	290.40	MW			
03.	Reserve / Shortage	:	230	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.0° C				