

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022					Day : Thursday				Date : 18.08.22					
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 14423 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 95.90 ft				Today = 95.81 ft					
					Rule Curve = 94.44 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.08.22 (Yesterday)		18.08.22 (Today)		17.08.22 (Yesterday)		18.08.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Machines shut down (MW)			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	290	300	300					
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	79	92	92					
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	326	255	330	330					
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	280	450	450					
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	404	412	412					
12	Siddhirgonj 2'120 MW GTTP	Gas (EGCB)	2 x 105	210	210	93	95	100	100		115		Gas Shortage	
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335		Gas Shortage	
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		335		Gas Shortage	
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	24	8	32		78		Fuel Oil Shortage	
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	22	22					
18	Summit Power,(Madhabdi+Ashulla)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	50	50	50	50					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	22	25	25					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	41	41	41					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	107	16	126					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	293	95	285					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	33	149	35	149					
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	11	302	100	300					
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	85	70	96					
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	70	85	86	100					
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	24	17	34		80		Fuel Oil Shortage	
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162					
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	30	0					
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55					
36	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	16	8	16		84		Fuel Oil Shortage	
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	17	8	50		83		Fuel Oil Shortage	
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total				6004	5847	2575	3326	2785	3719	1110	660			
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	150	150	150				Unit 1 under rehabilitation	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	105	105					
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
42	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0						
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25					
44	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0					
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	37	6	42					
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	17	105					
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		Awaiting for HGPI	
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	215	123	210					
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	21	21	21		79		Fuel Oil Shortage	
51	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	50	17	51		52		Fuel Oil Shortage	
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	26	26	26		72		Fuel Oil Shortage	
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	13	15	15					
54	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	29	7	30					
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	93	12	95					
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36					
57	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	17	55					
58	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	20	20	100		80		Fuel Oil Shortage	
59	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33		67		Fuel Oil Shortage	
60	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
Chattogram Zone Total				2442	2382	747	1077	762	1206	350	555			
61	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
62	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	30	38	35	35					
63	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x175	221	221	207	202	205	210					
64	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	315	320	325	325					
65	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	350	330	330	330					
66	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0				On test	
67	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	55	55	55	55					
68	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8		187		Gas Shortage	
69	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
70	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	115	125	133					
71	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	38	40	40					
72	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	141	128	60	130					
73	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	155	200	200	200					
74	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
75	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	10	10	10					
76	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
77	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	0		44		Fuel Oil Shortage	
78	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	14	20	21					
79	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+49x1.515+1x1.596	200	200	195	197	200	200					
80	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	17	114					
81	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	59	9	57		54		Fuel Oil Shortage	
82	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
83	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	73	96	96	100					
84	** Impoport (Tripura)	India		160	160	156	162	143	166					
Cumilla Zone Total				3193	3169	2013	2235	2027	2275	285	0			
85	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	62	97	80	10					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.08.22 (Yesterday)		18.08.22 (Today)		17.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	8	5	5	5					
91	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	62	64					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	214	220	220					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	8	8	25		Gas Shortage		
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	300	300					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	405	400	400					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	398	387	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage		
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5	45		Gas Shortage		
Sylhet Zone Total						2522	2477	1487	1512	1493	1565	140	680	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	160	150	170	180	260		Gas Shortage		
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	16	38	15	36					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	40	60	35	65		49	Maintenance ongoing		
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	222	222	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	94	93	90	90					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	36	17	52	69		Fuel Oil Shortage		
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	90	105					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	70	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	31	16	16	84		Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage		
**	Bheramara (HVDC)	India		1000	1000	905	909	924	924					
Khulna Zone Total						2388	2384	1629	1644	1682	1693	453	49	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	48	32	48					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	30	19	30					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	150	145	151	151					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	520	1070	1110	1110					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	150	17	150	150					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0					
Barishal Zone Total						1958	1958	886	1310	1462	1489	0	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	30	30	32	32		18	Turbocharger problem		
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	169	162	100	175					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	38	0	40					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	37	77	50	80					
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	40		18	Under maint.		
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	50					
131	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	26	32	33	33		18	Under maint.		
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	166	164	170	165	46		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	216	215	220	220	220		Running on HSD		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	148	160	150	72		Gas Shortage		
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	318	310	400	380	104		Gas Shortage		
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	20	21	22					
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95					
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0					
Rajshahi Zone Total						2129	2129	1255	1436	1374	1595	613	54	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	82	80	80					
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250					
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	55	86	55	90					
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Majpara, Tatulia 8 MW Solar PP (Sympha Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0					
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	68	0	68					
Rangpur Zone Total						800	720	386	486	393	488	0	85	
Sub-total: Plants in operation						22058	21680	11231.0	13413	12292	14423	3056	2083	
(B) Plants under long term maintenance/ contract expired														
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22482	21680	11231	13413	12292	14423	3056	2083	
(C) Actual data of 17.08.22 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	14200	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13562	MW,	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13584	MW,	at =	22:00 hrs	Dhaka	4798	4798	0	Mymensingh	1078	908	170
04.	Minimum Generation (Generation end)	:	11212	MW,	at =	6:00 hrs	Chattogram	1347	1347	0	Sylhet	555	500	55
05.	Day-peak Generation (Generation end)	:	11231	MW,	at =	9:00 hrs	Khulna	1714	1549	165	Barishal	418	418	0
06.	Evening-peak Generation (Generation end)	:	13413	MW,	at =	21:00 hrs	Rajshahi	1467	1312	155	Rangpur	923	848	75
07.	Evening Peak Load-shed (Sub-station end)	:	725	MW,	at =	21:00 hrs	Cumilla	1263	1158	105				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10556	MW,	at =	5:00 hrs					Total	13562	12837	725
09.	Generation shortfall at evening peak due to :	:					13.	Fuel cost :	(a) Gas = 156458014 Taka	(c) Coal = 205560442 Taka				
	a) Gas limitation	:	3056	MW				(b) Oil = 1366717902 Taka	Total = 1728736358 Taka					
	d) Coal supply Limitation	:	0	MW										
	b) Low water level in Kaptila lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2083	MW										
10.	Total Energy (Generation + India Import)	:	283.20	MKWh			14.	Maximum Temperature in Dhaka was : 35.4° C						
	By Gas = 137.383 MKWh			By Oil = 89.224 MKWh			15.	Export through East-West interconnections :						
	By Coal = 25.993 MKWh			By Hydro = 3.447 MKWh				At evening peak-hour	:	11231	MW,	at	21:00 hrs	
	By Solar= 1.376 MKWh							Maximum	:	238	MW,	at	19:00 hrs	
11.	Total Gas Supplied	:	1023.03	MMCFD				Energy	:	0	MKWh			
(D) Forecast of 18.08.22 (Today) Thursday :														
01.	Maximum Demand	:	14000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14423	MW	(Generation end)		05.	Total Generation	:	291.88	MKWh			
03.	Reserve / Shortage	:	423	MW	(Generation end)		06.							

* Cative Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00