

Page -1

21:00 Hrs on 16-Apr-22

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Level of Kaptai Lake at 6:00 A.M on	19-Aug-22	Actual :	95.69	Fl.(MSL) :		Rule curve :	94.76	Fl.(MSL) :	
-------------------------------------	-----------	----------	-------	------------	--	--------------	-------	------------	--

HSD :	Liter
FO :	Liter

Area	Yesterday		Estimated Demand (S/S end)	Today		Rates of Shedding (On Estimated Demand)
	MW			Estimated Shedding (S/S end)	MW	
Dhaka	118	0:00	4355	0	-2%	
Chittagong Area	0	0:00	1233	0	0%	
Khulna Area	36	0:00	1628	0	1%	
Rajshahi Area	82	0:00	1445	0	1%	
Cumilla Area	61	14:20	1230	0	1%	
Mymensingh Area	89	0:00	1016	0	1%	
Sylhet Area	36	0:00	454	0	0%	
Barisal Area	0	0:00	370	0	3%	
Rangpur Area	42	0:00	802	0	1%	
Total	464		12533	0		

Planned Shut- Down	Forced Shut-Down	
	1) Barapukuria ST: Unit-2	
	2) Ghorasal-3,4	
	3) Ashuganj-5	
	4) Baghabari-71,100 MW	
	5) Raozan unit-2	
	6) Siddhirganj 210 MW .	
	7) Sikalbaha 225 MW	
	8) Shajibazar 330 MW	
	9) Sirdighraonl 335 MW	

<p>a) Saidpur 132/33 kV unit Tr transformer was shut down at 10:35 for oil centrifuge.</p> <p>b) Kabirpur-Kodda 132 kV Ckt-1 tripped at 12:05 from Kodda end showing O/C relays and was switched on at 12:11.</p> <p>c) Kabirpur-Kodda 132 kV Ckt-2 tripped at 12:05 from both end showing Dist. SOTF relays and was switched on at 01:06(19-08-2022).</p> <p>d) Kabirpur-Kaliakoir 132 kV Ckt-2 tripped at 12:05 from Kaliakoir end showing Dist. Z1 relay and was switched on at 18:01.</p> <p>e) Bogura 230/132 kV T-2 transformer was switched on at 09:12.</p> <p>f) Mithapukur 132/33 kV T-2 transformer was switched on at 08:08.</p> <p>g) Shariatpur 132/33 kV T-1 transformer with 33 kV Bus-1 were under shut down from 08:37 to 09:56 for C/M.</p> <p>h) Mirpur 132/33 kV T-1 transformer was shut down at 15:21 due to oil leakage maintenance.</p> <p>i) Bhola-Barisal(N) 230 kV Ckt-1 tripped at 15:55 from both end showing Dist. Z1, AB-phase relays and was switched on at 16:39.</p> <p>j) BSRRM-GPH 230 kV Ckt was under shut down from 17:24 to 18:38 due to tree trimming by GPH.</p> <p>k) Cumilla(S) 132/33 kV T-3 & T4 transformers tripped at 18:28 due to 33 kV Kotbari feeder fault and were switched on at 19:07, 19:01 respectively.</p> <p>l) Niamatpur 132/33 kV T2 transformer tripped at 20:20 due to low voltage and was switched on at 20:34.</p> <p>m) Madaripur 132/33 kV T2 transformer tripped at 15:47 due to R/H at 33 kV end and was switched on at 16:49.</p> <p>n) Bhandaria-Barisal 132 kV Ckt tripped at 16:40 from Bhandaria end showing Dist. Z1 relays and was switched on at 16:45.</p> <p>o) Bhandaria-Barisal 132 kV Ckt again tripped at 16:46 from Bhandaria end showing Dist. Z1 relays and was switched on at 20:49.</p> <p>u) Khulna© 132/33 kV T3 transformer tripped at 17:40 from 33 kV end showing O/C relay & 3 kV feeder fault and was switched on at 18:11.</p> <p>v) Siddhirganj 335 MW GT was synchronized at 19:01.</p> <p>w) Raozan unit-1 was synchronized at 17:32.</p> <p>x) Chandpur 225 MW ST was synchronized at 16:30.</p> <p>y) Kabirpur-Kodda 132 kV Ckt-2 was switched on at 01:06(19-08-2022).</p> <p>z) Hasnabad-Sitalakha 132 kV Ckt was under shut down from 06:05(19-08-2022) to 08:42(19-08-2022) for C/M.</p> <p>aa) Manikganj 230/132 kV T02 transformer was shut down at 06:28(19-08-2022) for C/M.</p> <p>ab) Manikganj 132 kV reserve Bus was shut down at 06:45(19-08-2022) for C/M.</p> <p>ac) Rajshah(ohd) 132/33 kV T3 transformer was shut down at 06:25(19-08-2022) for D/W.</p> <p>ad) Chapainawabganj-Rohanpur 132 kV Ckt tripped at 23:54 due to bad weather & showing Dist relay at Chapainawabganj end and was switched on at 00:50(19-08-222).</p> <p>ae) Siddhirganj GT-1 was shut down at 07:41(19-08-2022) due to gas pressure low.</p>	<p>About 120 MW power interruption occurred under Kodda, Rajendrapur S/S area from 12:05 to 12:11.</p> <p>About 10 MW power interruption occurred under Shariatpur S/S area from 08:37 to 09:56.</p> <p>About 52 MW power interruption occurred under Cumilla(S) S/S area from 18:28 to 19:01.</p> <p>About 21 MW power interruption occurred under Madaripur S/S area from 15:47 to 16:49.</p> <p>About 30 MW power interruption occurred under Khulna© S/S area from 17:40 to 18:11</p>
--	---

Superintendent Engineer
Load Despatch Circle