

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022				Day : Friday				Date : 19.08.22				
Probable Maximum Demand : 13600 MW				Probable Maximum Generation : 13613 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.81 ft				Today = 95.69 ft				
								Rule Curve = 94.76 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.08.22 (Yesterday)		19.08.22 (Today)		18.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation			
					Day	Evening	Day	Evening	MW	(MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	290	300	300			
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	86	86	86			
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	308	257	260	260			
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	400	380	400			
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	404	412	412			
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	91	37	0	0	173	Gas Shortage	
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	79	72	72	256	Gas Shortage	
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	16	8	16	86	Fuel Oil Shortage	
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
18	Summit Power (Madhabdi-Ashulla)	Gas (SIPP, REB)	6x3.67+8.73	80	80	25	45	50	50			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	28	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	41	24	41			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	88	52	105			
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	122	16	126			
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	82	278	110	285			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	26	149	35	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	102	108	100	300			
28	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	65	93	70	93			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	93	25	70			
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17	87	Fuel Oil Shortage	
33	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162			
34	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	30	0			
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55			
36	Siddhirgonj 100 MW PP(Dutch Bangle)	HFO (NENP)	12x8.9	100	100	8	16	8	16	84	Fuel Oil Shortage	
37	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	7	7	8	93	Fuel Oil Shortage	
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	2643	3300	2502	3485	1114	660	
39	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	150	115	115		Unit 1 under rehabilitation	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	100	100	100			
41	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
42	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
43	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25			
44	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0			
45	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	37	6	37			
46	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	17	105			
47	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
48	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI	
49	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	117	214	123	215			
50	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	10	10	10	90	Fuel Oil Shortage	
51	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51	Fuel Oil Shortage	
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	25	25	25	73	Fuel Oil Shortage	
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13			
54	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			9	27	10	35			
55	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	93	12	93			
56	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
57	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	59	55	55			
58	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	30	10	10	10	90	Fuel Oil Shortage	
59	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	10	10	10	90	Fuel Oil Shortage	
60	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	45	107	107	107			
Chattogram Zone Total				2442	2382	559	1072	716	1042	394	555	
61	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
62	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	37	35	35			
63	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x175	221	221	203	209	210	210			
64	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	305	305	305			
65	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	325	315	320	320			
66	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test	
67	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	54	55	55			
68	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	45	16	16	150	Gas Shortage	
69	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	51	51			
70	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	140	132	140			
71	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	37	35	35			
72	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	143	145	145			
73	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	155	200	200	200			
74	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
75	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
76	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
77	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	0	0	0	52	Fuel Oil Shortage	
78	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	14	20	21			
79	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+49x1.515+1x1.596	200	200	195	100	100	200			
80	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	90	17	114			
81	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	29	9	26	84	Fuel Oil Shortage	
82	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
83	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	96	96	96			
84	Impoport (Tripura)	India		160	160	154	118	143	166			
Cumilla Zone Total				3193	3169	1889	2075	1989	2235	286	0	
85	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	64	100	100	100	102	Gas Shortage	
86	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
87	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	79	68	79			
88	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	77	182	80	180			
89	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
90	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	40	0	50	0			
91	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	285	395	334	393	102	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.08.22 (Yesterday)		19.08.22 (Today)		18.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation				
						Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5					
91	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	62	62					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	221	208	210	210					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage		
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	270	300					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	404	400	400					
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	383	400	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage		
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5	45		Gas Shortage		
Sylhet Zone Total				2522	2477	1490	1534	1453	1553	132	680			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	165	165	175	175	245		Gas Shortage		
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	15	43	20	43					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	41	43	40	50		66	Maintenance ongoing		
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	218	228	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	90	50	50	95					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	35	17	52	70		Fuel Oil Shortage		
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	102	15	0	0					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16	99		Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage		
**	Bheramara (HVDC)	India		1000	1000	904	907	924	924					
Khulna Zone Total				2388	2384	1620	1502	1567	1580	454	66			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	0	35					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	23	15	25					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	143	151	151	151					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1080	1020	1110	1110					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0					
Barishal Zone Total				1958	1958	1260	1226	1293	1338	0	0			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	24	30	30	30		18	Turbocharger problem		
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	164	100	100	170					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	35	0	35					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	80	35	80					
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.		
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
131	Sanlahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	25	32	0	32		18	Under maint.		
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	165	166	170	170	44		Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	212	213	130	220	220		Running on HSD		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	151	150	150	69		Gas Shortage		
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	316	328	350	350	86		Gas Shortage		
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	21	21					
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95					
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94					
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0					
Rajshahi Zone Total				2129	2129	1232	1396	1116	1498	590	54			
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	83	81	81					
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	240	240	250	250					
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	91	55	90					
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Majpara, Tatulia 8 MW Solar PP (Sympha Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	32	0	68					
Rangpur Zone Total				800	720	378	446	394	489	0	85			
Sub-total: Plants in operation				22058	21680	11356.0	12946	11364	13613	3072	2100			
(B) Plants under long term maintenance/ contract expired														
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0					
Gross Total				22482	21680	11356	12946	11364	13613	3072	2100			
(C) Actual data of 18.08.22 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	13450	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12885	MW,	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12982	MW,	at =	22:00 hrs	Dhaka	4964	4846	118	Mymensingh	1041	952	89
04.	Minimum Generation (Generation end)	:	10556	MW,	at =	7:00 hrs	Chattogram	1309	1309	0	Sylhet	548	512	36
05.	Day-peak Generation (Generation end)	:	11356	MW,	at =	9:00 hrs	Rajshahi	1398	1362	36	Barishal	310	310	0
06.	Evening-peak Generation (Generation end)	:	12946	MW,	at =	21:00 hrs	Rajshahi	1426	1344	82	Rangpur	835	793	42
07.	Evening Peak Load-shed (Sub-station end)	:	464	MW,	at =	21:00 hrs	Cumilla	1055	994	60.5973501				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10433	MW,	at =	5:00 hrs					Total	12885	12421	464
09.	Generation shortfall at evening peak due to :	:					13.	Fuel cost :	(a) Gas = 151188791 Taka	(c) Coal = 288845090 Taka				
	a) Gas limitation	:	3072	MW				(b) Oil = 1226688443 Taka		Total = 1668722324 Taka				
	d) Coal supply Limitation	:	0	MW										
	b) Low water level in Kaptila lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	2100	MW										
10.	Total Energy (Generation + India Import)	:	279.22	MKWh			14.	Maximum Temperature in Dhaka was : 37.1° C						
	By Gas = 133.895 MKWh			By Oil = 80.022 MKWh			15.	Export through East-West interconnections :						
	By Coal = 35.139 MKWh			By Hydro = 3.422 MKWh				At evening peak-hour	:	11356	MW,	at	21:00 hrs	
	By Solar= 1.421 MKWh							Maximum	:	530	MW,	at	20:00 hrs	
11.	Total Gas Supplied	:	1007.49	MMCFD				Energy	:	0	MKWh			
(D) Forecast of 19.08.22 (Today) Friday :														
01.	Maximum Demand	:	13600	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13613											

* Cative Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation