

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022					Day : Monday				Date : 22.08.22					
Probable Maximum Demand : 14300 MW					Probable Maximum Generation : 13663 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 95.30 ft				Today = 95.01 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.08.22 (Yesterday)		22.08.22 (Today)		Rule Curve = 95.72 ft		21.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Machines shut down		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	(MW)				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	87	92	94	94					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	246	237	320	275					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	240	240	240	240					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	407	412	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	198	205	50	200		130		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0		335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	30	30	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8		94		Fuel Oil Shortage	
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	0	22	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	48	52	52					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	40	24	40					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	52	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	47	122	16	120					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	98	260	110	262					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	16	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	233	302	230	300					
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	92	60	10					
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	70	92	80	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	18	55	17	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17		87		Fuel Oil Shortage	
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	52	162	35	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	0	8		92		Fuel Oil Shortage	
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	7	0	8		93		Fuel Oil Shortage	
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total					6004	5847	2586	3385	2568	3369	1041	660		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	152	150	150				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	110	110					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0					
41	Raczan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	38	25	37					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	69	105					
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	86	179	85	178					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10		90		Fuel Oil Shortage	
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51		51		Fuel Oil Shortage	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	41	43	40	40		55		Fuel Oil Shortage	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	28	10	25					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	83	12	93					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10		90		Fuel Oil Shortage	
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	10	10	10	10		90		Fuel Oil Shortage	
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	108	108	108	108					
Chattogram Zone Total					2442	2382	834	1104	863	1127	376	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	29	38	38	38					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	206	206	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	300	300	310					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	300	300	320					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0				On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	55	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	36	8	8	8		187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	130	140	140					
68	Titao 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	47	37	45					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	137	136	136					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	200	100	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8		44		Fuel Oil Shortage	
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	18	18					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+69x1.55+15x1.585	200	200	196	197	200	200					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	86	17	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	29	9	29		84		Fuel Oil Shortage	
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	26	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	91	96	96					
**	Import (Tirupura)	India		160	160	166	162	143	165					
Cumilla Zone Total					3193	3169	1962	2156	1957	2242	315	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	102	106	106	105		96		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	68	48	68					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	77	107	80	180					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0					
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total					622	614	296	315	320	387	96	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.08.22 (Yesterday)		22.08.22 (Today)		21.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	42	42	42		48	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	0	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	63	62	62				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	193	193	193	193				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	8	8		17	Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	300	300	310				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	404	400	400				
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	395	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0		50	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0		50	Gas Shortage	
Sylhet Zone Total						1406	1550	1468	1559	137	668		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	145	164	165	165		246	Gas Shortage	
108	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	31	20	43				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	39	40	50		70	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	222	225	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	44	85	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	35		88	Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	67				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	108	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16		99	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khenjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	0		32	Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	887	895	904	904				
Khulna Zone Total						2388	2384	1438	1547	1552	1600	465	70
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	32	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	31	16	31				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	160	152	151	151				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	990	1170	1170	1170				
121	Potuaakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17				
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas:HSD (IPP)	2x75+1x70	220	220	0	0	0	0				
Barishal Zone Total						1958	1958	1201	1402	1369	1417	0	0
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	32	32	32		18	Turbocharger problem	
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	133	164	120	170				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	40				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	35	80				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	175	174	180	180		36	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	178	210	220	220		220	Running on HSD	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	145	150	150	150		70	Gas Shortage	
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	307	322	305	305		92	Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	21	21				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	1107	1431	1193	1470	589	54
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	83	80	80				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	251	250	250	250				
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	92	55	90				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Wajpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	72	0	72				
Rangpur Zone Total						800	720	394	497	393	492	0	85
Sub-total: Plants in operation						22058	21680	11224.0	13387	11683	13663	3019	2092
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22482	21680	11224	13387	11683	13663	3019	2092
(C) Actual data of 21.08.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	14100	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13400	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13387	MW, at =	21:00 hrs	Dhaka	4834	4764	70	Mymensingh	1091	871	220
04.	Minimum Generation (Generation end)	:	10977	MW, at =	8:00 hrs	Chattogram	1345	1345	0	Sylhet	565	525	40
05.	Day-peak Generation (Generation end)	:	11224	MW, at =	12:00 hrs	Khulna	1540	1403	137	Barishal	410	410	0
06.	Evening-peak Generation (Generation end)	:	13387	MW, at =	21:00 hrs	Rajshahi	1378	1308	70	Rangpur	897	847	50
07.	Evening Peak Load-shed (Sub-station end)	:	657	MW, at =	21:00 hrs	Cumilla	1341	1271	70				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11011	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 156109114 Taka (c) Coal = 301006694 Taka							
	a) Gas limitation	:	3019	MW									
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2092	MW									
10.	Total Energy (Generation + India Import)	:	287.48	MW									
	By Gas = 138.589 MKWH	By Oil =	81.784 MKWH										
	By Coal = 36.611 MKWH	By Hydro =	3.643 MKWH										
	By Solar= 1.406 MKWH												
11.	Total Gas Supplied	:	1044.39	MMCFD									
(D) Forecast of 22.08.22 (Today) Monday :													
01.	Maximum Demand	:	14300	MW	(Generation end)	04.	Maximum Load-shed	:	597	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13663	MW	(Generation end)	05.	Total Generation	:	307.09	MW	At evening peak (Sub-station end)		
03.	Reserve / Shortage	:	-637	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.2° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation