

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022					Day : Thursday				Date : 25.08.22				
Probable Maximum Demand : 14100 MW					Probable Maximum Generation : 14372 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 95.15 ft		Today = 95.27 ft		Rule Curve = 96.69 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.08.22 (Yesterday)		25.08.22 (Today)		24.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation				
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	87	91	91	91				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	332	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	400	400	400				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	92	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	338	335	335				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	40	8	40	62	Fuel Oil Shortage		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	35	52	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	31	24	40				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	35	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	46	125	16	126				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	243	278	210	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	140	149	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	225	122	225	225				
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	50	90				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	81	90	80	90				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	55	17	54	49	Fuel Oil Shortage		
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	40	162	35	162				
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	19	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	7	40	7	40	60	Fuel Oil Shortage		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	41	7	41	59	Fuel Oil Shortage		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total			6004	5847	2908	3648	3161	3782	775	660			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	152	150	150		Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	38	25	38				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	87	69	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	88	52	51	51	248	Fuel Oil Shortage		
48	Judhah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51	Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	43	40	40	55	Fuel Oil Shortage		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	16	16				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	30	10	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	95	12	95				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
55	Judhah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90	Fuel Oil Shortage		
56	Judhah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total			2442	2382	817	963	814	975	624	555			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	30	40	40	40				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	207	209	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	305	300	305				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	330	330	330				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	56	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	133	125	140				
68	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	42	46	42	42				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	144	136	143	143				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	180	100	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	25	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8	44	Fuel Oil Shortage		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	17	18	18				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+69x1.05+15x1.08	200	200	160	0	100	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0	114	Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	115	57	110				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	68	77	96	96				
**	Import (Tripura)	India		160	160	150	148	143	165				
Cumilla Zone Total			3193	3169	1835	1951	1918	2213	345	0			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	68	107	68	105	95	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	69	109	109	100				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	96	97	96	95				
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0				
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	50	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	10	12	12	12				
Mymensingh Zone Total			622	614	296	325	337	312	95	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.08.22 (Yesterday)		25.08.22 (Today)		24.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation	Machines shut down for : (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	41	42	42		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	64	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	194	193	190	190				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8		17	Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	290	295	295				
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	403	400	400				
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	401	401	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	6	6		44	Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0		50	Gas Shortage	
Sylhet Zone Total				2522	2477	1438	1545	1469	1539	131	669		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	250	280	280	280		130	Gas Shortage	
108	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	26	0	50				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	62	30	70		47	Maintenance ongoing	
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	150	226	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	55	93				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17		88	Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	67				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	27	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16		99	Fuel Oil Shortage	
116	Noapara 40 MW PP (Khenjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0		40	Fuel Oil Shortage	
**	Bheramara (HVDC)	India		1000	1000	894	887	910	910				
Khulna Zone Total				2388	2384	1336	1581	1643	1728	357	47		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	22	20	30				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	112	86	100	151		108	Gas Shortage	
120	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	890	1090	1170	1170				
121	Potuaakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	115	191	220	220				
Barisal Zone Total				1958	1958	1131	1421	1542	1636	108	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	32	32	32		18	Turbocharger problem	
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	20	0	120	180				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	26	0	40				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	35	80				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	192	214	200	214				
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	204	216	220	220		220	Running on HSD	
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	202	190	190	190				
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	419	410	410				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	90				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total				2129	2129	1253	1550	1401	1733	391	54		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	81	80	80				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	245	250	250				
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	55	90	55	90				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Wajpara, Talidia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	72	0	34				
Rangpur Zone Total				800	720	387	488	393	454	0	85		
Sub-total: Plants in operation				22058	21680	11401.0	13472	12678	14372	2826	2070		

(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	11401	13472	12678	14372	2826	2070		

(C) Actual data of 24.08.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14100	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13556	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	13472	MW,	at =	21:00 hrs	Dhaka	4849	4699	150	Mymensingh	1222	902
04.	Minimum Generation (Generation end)	:	10753	MW,	at =	8:00 hrs	Chattogram	1320	1320	0	Sylhet	608	529
05.	Day-peak Generation (Generation end)	:	11401	MW,	at =	12:00 hrs	Khulna	1581	1581	0	Barishal	356	356
06.	Evening-peak Generation (Generation end)	:	13472	MW,	at =	21:00 hrs	Rajshahi	1439	1439	0	Rangpur	924	924
07.	Evening Peak Load-shed (Sub-station end)	:	579	MW,	at =	21:00 hrs	Cumilla	1258	1228	30			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11115	MW,	at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	2826	MW									
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2070	MW									
10.	Total Energy (Generation + India Import)	:	289.93	MW									
	By Gas = 148.128 MKWH			By Oil =		77.800 MKWH							
	By Coal = 34.047 MKWH			By Hydro =		3.545 MKWH							
	By Solar= 1.322 MKWH												
11.	Total Gas Supplied	:	1110.59	MMCFD									

(D) Forecast of 25.08.22 (Today) Thursday :													
01.	Maximum Demand	:	14100	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14372	MW	(Generation end)		05.	Total Generation	:	303.44	MW		
03.	Reserve / Shortage	:	272	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.3° C			

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation