

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022				Day : Sunday				Date : 28.08.22					
Probable Maximum Demand : 14100 MW				Probable Maximum Generation : 14186 MW				Rule Curve = 97.68 ft					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.27 ft				Today = 95.55 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.08.22 (Yesterday)		28.08.22 (Today)		27.08.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation	28.08.22 (Today) Probable Peak Generation (MW)	27.08.22 (Yesterday) Gen. shortfall for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	100	100	100				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	260	300	300				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	323	288	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	330	280	270	280				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	401	412	412				
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	97	90	95	95	120		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	332	335	335	335				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	93	50	94				
16	Narshingsi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x6.73	80	80	52	51	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	16	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	25	28	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	41	8	42				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	88	17	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	22	90	15	110				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	275	260	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	128	149	149	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	245	59	240	240				
27	Branghangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	93	55	90				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	35	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	55	55				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	7	97	60	100				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	7	90	7	90				
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	3211	3701	3450	4071	563	480		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	153	151	144	144			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	38	25	38				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	52	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	51	51	248		Fuel Oil Shortage	
48	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10	90		Fuel Oil Shortage	
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	8x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	26	26	34				
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	28	20	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	77	12	95				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	96	110	110	110				
55	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90		Fuel Oil Shortage	
56	Juddah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10	90		Fuel Oil Shortage	
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total				2442	2382	791	981	825	1001	518	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	42	40	40				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	203	208	205	205				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	325	305	270	310				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	330	310	330	310				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	55	55	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	45	26	8	8	169		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	124	115	145				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	37	32	42				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	32	30	90	90				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	100	17	100				
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	22	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	6	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	25	25	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8	44		Fuel Oil Shortage	
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	17	17	18	18				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.586	200	200	200	100	100	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	104	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	88	115	98	115				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	56	96	96	96				
**	Impoport (Tripura)	India		160	160	140	160	143	165				
Cumilla Zone Total				3193	3169	1891	1980	1777	2067	213	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	71	105	105	140	97		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0				
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	107	87	78	107				
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	107	115	124	124				
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	22	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Myensingh Zone Total				622	614	321	319	371	383	97	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.08.22 (Yesterday)		28.08.22 (Today)		27.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	MW	Machines shut down (MW)				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	41	30	30		49	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	11	50	50						
91	Kushlira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	56	60	60						
94	Shajibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	81	81						
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	193	193	193	194						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x3.34	25	25	0	0	16	16	25		Gas Shortage			
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	270	290	300						
101	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	401	0	80						
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	398	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	19	19	44		Gas Shortage			
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3x3'5'2	50	50	5	10	43	44	40		Gas Shortage			
Sylhet Zone Total						2522	2477	1460	1522	1235	1327	129	669		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	275	315	280	285	95		Gas Shortage			
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	0	41						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	0	55						
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	220	226	225	225						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	30	10	93	93						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	18	18	17	17	87		Fuel Oil Shortage			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	85	15	67						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	31	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	0	99		Fuel Oil Shortage			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage			
**	Bheramara (HVDC)	India		1000	1000	888	796	906	906						
Khulna Zone Total						2388	2384	1477	1561	1636	1689	321	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	48						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	25	20	30						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	83	85	85	85	109		Gas Shortage			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	820	990	1170	1170						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17						
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	165	219	220	220						
Barishal Zone Total						1958	1958	1107	1368	1511	1570	109	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	31	0	32		18	Turbocharger problem			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	26	120	150	160						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	40	0	40						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	0	80						
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.			
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0						
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0		50	Under maint.			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	167	200	200						
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	212	215	220	220	220		Running on HSD			
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	206	209	210	200						
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	419	410	410						
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	21	22	22						
137	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11						
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95						
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94						
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0						
Rajshahi Zone Total						2129	2129	1008	1542	1342	1624	391	86		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	74	80	80						
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250						
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	50	91	55	90						
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
149	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6'20	115	115	91	72	0	34						
150	Intraco Solar 30 MW	Solar (IPP)				15	0	0	0						
Rangpur Zone Total						800	720	493	393	454	0	85			
Sub-total: Plants in operation						22058	21680	11759.0	13461	12540	14186	2341	1875		
(B) Plants under long term maintenance/ contract expired															
151	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0				
Gross Total						22482	21680	11759	13461	12540	14186	2341	1875		
(C) Actual data of 27.08.22 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	13915	MW	at =	20:00	hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13436	MW	at =	20:00	hrs	Zone	Demand MW	Supply MW	Load Shed MW	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13466	MW	at =	22:00	hrs	Dhaka	4907	4761	146	Mymensingh	1232	960	272
04.	Minimum Generation (Generation end)	:	11367	MW	at =	9:00	hrs	Chattogram	1134	1134	0	Sylhet	537	537	0
05.	Day-peak Generation (Generation end)	:	11759	MW	at =	12:00	hrs	Khulna	1634	1634	0	Barisal	374	374	0
06.	Evening-peak Generation (Generation end)	:	13461	MW	at =	20:00	hrs	Rajshahi	1488	1488	0	Rangpur	900	900	0
07.	Evening Peak Load-shed (Sub-station end)	:	418	MW	at =	20:00	hrs	Cumilla	1230	1230	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11101	MW	at =	5:00	hrs								
09.	Generation shortfall at evening peak due to :	:													
a)	Gas limitation	:	2341	MW											
d)	Coal supply Limitation	:	0	MW											
b)	Low water level in Kaptai lake	:	0	MW											
c)	Plants under shut down/ maintenance	:	1875	MW											
10.	Total Energy (Generation + India Import)	:	313.34	MKWh											
	By Gas =	154.318	MKWh	By Oil =	97.478	MKWh									
	By Coal =	32.555	MKWh	By Hydro =	3.453	MKWh									
	By Solar=	0.879	MKWh												
11.	Total Gas Supplied	:	1099.25	MMCFD											
(D) Forecast of 28.08.22 (Today) Sunday :															
01.	Maximum Demand	:	14100	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14186	MW	(Generation end)			05.	Total Generation	:	328.09	MKWh			
03.	Reserve / Shortage	:	86	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	32.2° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalul Rahman)
Deputy Secretary, Generation