

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP-Unit-4	PDB	1'210	180	110	2543000	Machine problem
3	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	250	6162716	Machine problem
4	Ghorasal 78.5 MW PPI(MAX)	ORPP	2'40	0	0	0	Contract Expired
5	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	0	0	Gas shortage
6	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
7	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	411	9947140	
8	Haripur 360 MW CAPP(HPL)	IPP	1'235+1'125	360	273	6412000	Machine problem
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	240	5715600	Dirty gas
10	Meghnaghat 100 MW(IEI)	NENP	1'28.9	100	92	1108900	Engine problem
11	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage
12	Madanganj 102 PPI(Summit)	NENP	6'17	102	0	0	Under maint.
13	Madanganj-55 MW PPI(Summit)	IPP	3'17.08+1'111.3	55	55	1330388	
14	Keraniganj 100 MW PP (Powerpac)	GRPP	8'13.45	0	0	0	Contract Expired
15	Narsingh 22 MW PP (Doreen)	SIPP, REB	9'22.90	22	22	412452	
16	210 MW Siddhirganj TPP	PDB	1'210	115	0	0	Under maint.
17	Siddhirganj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
18	Siddhirganj 100 PPI(Dutch Bangla)	NENP	12'8.9	100	90	1621440	Engine problem
19	Siddhirganj 335 MW CAPP	EGCB	1'217+1'118	335	335	8087849	
20	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	92	1446192	Engine problem
21	Katpott 52 MW PP (Sinha)	IPP	3'77.9	0	0	0	Fuel shortage
22	Karnalaghat 54 MW PPI(Banco Energy)	IPP	3'18	54	54	773280	
23	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	106	1267200	Fuel shortage
24	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	892743	
25	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	809960	
26	Bosila 108MW PPI(OLC)	IPP	12'8.75+1'3.5	0	0	0	
27	Summit Power (Machhad-Ashulia)	SIPP, REB	33.67+18.73	80	49	1144860	Engine problem
28	Masona 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	0	757900	Engine problem
29	Rupganj 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	24	607200	Engine problem
30	Gazipur 52 MW PP	RPCL	6'9.9	52	41	378240	#REF!
31	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	276	6154798	Engine problem
33	Keraniganj 300 MW PP (APR)	IPP	250'1.4	300	253	4688633	
34	Bramharganj 100 MW PP (Aggreko)	IPP	14'0.969	100	90	1753031	Engine problem
35	Aurahat 100MW PP (Aggreko)	IPP	0.85+23+0.95'91	100	90	1737832	Engine problem
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	2138260	
37	Gazipur 100 MW PP	RPCL	6'17.5	105	105	1041600	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	92	1514880	Engine problem
39	Manikganj 162MW PPI(MPL)	IPP	9'18	162	162	1975680	
40	Spectra Solar Plant Ltd.	IPP	35	35	0	147921	
41	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	55	905040	
Dhaka area Total				5847	3796	77695837	
42	Chattogram TPP-1	PDB	1'210	180	110	2600000	Machine problem
43	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
44	Raozan 25 MW PP	RPCL	3'8.9	25	25	621162	
45	Teknaf 20MW PP (Solartech)	IPP	20	20	0	131110	
46	Patenga 50MW PP (Baraka)	IPP	8'9.98	50	38	686800	Engine problem
47	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	146	3513207	Low water level
48	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI for 30 days.
49	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	87	1841672	Engine problem
51	Hathazari 100 MW peaking PP	PDB	11'8.9	98	26	567336	Fuel shortage
52	Dahazari-Kalash 100 MW Peaking	PDB	8'17	102	51	615565	Fuel shortage
53	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	10	257800	Fuel shortage
54	Juidah 100 MW Unit-3 (Acorn)	IPP	8'13.5	100	10	251520	Fuel shortage
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	17	405408	Engine problem
56	Malancha, Ctg. EPZ (United)		5'8.73+3'9.34	0	30	530880	
57	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	92	615360	Engine problem
58	Kaptai 7 MW Solar PP	PDB	7.4	7	0	29008	
59	Arwara 300 MW PP (United)	IPP	17'14.24	300	52	1239491	Fuel shortage
60	Jodac Power	IPP	3'18.55+1'3.6	54	54	1368867	
61	Karnaphuli Power Ltd.	IPP	18.4'5+6+6.5	110	110	2688097	
62	Juidah unit-2 (Acorn)	IPP	8'13.6	100	10	252480	Engine problem
63	Anilma Energy Ltd.	IPP	6'21.2	116	107	2561782	Engine problem
64	Mirshara 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
Chattogram area Total				2382	975	20789736	
65	Ashuganj TPP Unit-3	APSCCL	1'150	0	0	0	Contract Expired
66	Ashuganj TPP Unit-4	APSCCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-5	APSCCL	1'150	134	0	0	Gas shortage
68	Ashuganj 225 MW CAPP	APSCCL	1'142+1'175	221	191	4881000	#REF!
69	Ashuganj 450 MW CAPP(North)	APSCCL	1'360	360	310	7732800	Gas shortage
70	Ashuganj 450 MW CAPP(South)	APSCCL	1'360	360	305	7286000	FGMO
71	Ashuganj 420 MW CAPP(East)	APSCCL	284'136'1	0	284	0	On test.
72	Ashuganj 50 MW PP	APSCCL	14'3.968	45	44	1008144	Engine problem
73	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	56	1297440	
74	Ashuganj 195MW PP (APSCCL-United)	IPP	20'9.73+1'116	195	8	200727	Gas shortage
75	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1133601	
76	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	135	2785900	Engine problem
77	Titas 50 MW Peaking PP	PDB	6'8.62	50	28	898736	Engine problem
78	Chandpur 150 MW CAPP	PDB	11'106+1'157	163	30	574220	Machine problem
79	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	65	800160	Fuel shortage
80	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	501300	
81	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	232920	
82	Impport (Tripura)	Imported power	0	160	156	3456000	
83	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	658600	
84	Jangalia 52 MW PP (Lakshmi)	IPP	6'8.92	52	8	53616	Fuel shortage
85	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	17	459070	Engine problem
86	Daudkandi 200 MW PP (B.Trac)	IPP	15'4'1.4	200	196	3583296	
87	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	305520	Fuel shortage
88	Chowmahani 113 MW	IPP	12'9.78+2'3.1	113	115	2420040	
89	Bharob 54.5 MW	IPP	3'18.2	54	35	861480	33 KV feeder problem.
90	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	92	2188640	Fuel shortage
Cumilla Area Total				3169	1908	43298400	
91	RPCL 210MW CAPP	IPP	4'35+1'70	202	133	2494080	Gas shortage
92	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	0	Gas shortage
93	Jamapur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
94	Sarishabari 3 MW Solar Plant	IPP	1'3	0	0	11000	
95	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	159	3028900	Fuel shortage
96	Jamapur 115 MW PP (United)	IPP	9'78'12	115	97	2026800	Engine problem
97	Sutakhal 50 MW Solar PP	IPP	50	50	0	197300	
98	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	238560	Engine problem
Mymensingh Area Total				614	401	799630	
99	Fenchuganj CAPP Phase-1	PDB	2'32+1'33	70	43	1022000	Machine problem
100	Fenchuganj CAPP Phase-2	PDB	2'35+1'35	90	41	874200	Machine problem
101	Kushnara 163 MW CAPP (KP)	IPP	1'109+1'154	163	0	0	Gas shortage
102	Shajibazar 330 MW CAPP	PDB	3'110	330	0	0	Under maint.
103	Fenchuganj 51 MW PP (Barakatullah)	RPP	18'2.90	51	50	1222800	
104	Fenchuganj 44MW (Energyptima)	NENP	12'3.3+5'2	50	50	1131552	
105	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	101000	
106	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	61	1481184	
107	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	81	1817280	
108	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
109	Sylhet 225 MW CAPP	PDB	1'142+1'189	231	193	4688320	Machine problem
110	Sylhet 20 MW GTPP	PDB	1'20	20	18	212000	
111	Sylhet 50MW PP (EPL)	NENP	27'2	50	26	549540	Gas shortage
112	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	485832	
113	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	300	723000	FGMO
114	Bibiana-III 400 MW CAPP	PDB	400	400	51	580000	Synchronized at 18:09
115	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	247680	
116	Bibiana South 400 MW	PDB	400 MW	383	400	9522500	
Sylhet Area Total				2477	1359	31174888	
117	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
118	Bheramara (HVDC)	Imported power	2'500	1000	891	21474909	
119	Khuila 115 PP MW (KPCL-2)	NENP	7'17	115	16	71040	Fuel shortage
120	Fardpur 50 MW Peaking PP	PDB	8'6.99	54	33	211200	Engine problem
121	Khuila 225 MW CAPP	NWPGCL	1'150+1'175	230	225	5374080	
122	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	64	690816	Engine problem
123	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	185	5808960	Gas shortage.
124	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
125	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	95	1359360	
126	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	70	624860	Fuel shortage
127	Madhumati 100 MW PP	NWPGCL	6'18	105	67	869600	Fuel shortage
128	Mongla Orion 100 MW Solar PP	IPP	100	100	0	535680	
129	Khuila 330 MW CAPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
130	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	
Khuila Area Total				2384	1646	36820605	
131	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	32	601056	Line O/L
132	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	30	594212	Engine problem
133	Bhola 225 MW CAPP	PDB	2'63+1'69	194	86	2953144	Gas shortage
134	Bhola 95 MW PP (Aggreko)	ORPP	96'11.00	0	0	0	Contract Expired
135	Payra 1320 MW	BCPCL	2'622	1244	1080	25515300	Line O/L
136	Bhola Nulan Biddut BD LTD	IPP	220	220	224	5298573	
137	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	17	132000	Line O/L
Barisal Area Total				1958	1469	34194285	
138	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
139	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
140	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	32	203344	Engine problem
141	Bera 70 MW Peaking PP	PDB	9'8.29	71	40	342891	Engine problem
142	Amnura 50 MW PPI(Sinha)	QRPP	7'7.79	0	0	0	Contract Expired
143	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	0	0	Fuel shortage
144	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	32	203600	Engine problem
145	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	192	5013382	Gas shortage
146	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	216	5280564	
147	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	152	4428300	Gas shortage
148	Sirajgonj 400 MW CAPP Unit-4	NWPGCL	1'282+1'132	414	421	9963600	
149	Santahar 50 MW Peaking PP	PDB	6'8.7	50	0	0	Under maint.
150	Bogra 22 MW PP (GBB)	RPP	6'4	22	22	478080	