

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022				Day : Monday				Date : 29.08.22					
Probable Maximum Demand : 14200 MW				Probable Maximum Generation : 13735 MW				Rule Curve = 98.01 ft					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.55 ft				Today = 96.03 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.08.22 (Yesterday)		29.08.22 (Today)		28.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation				
					Day	Evening	Day	Evening	MW	(MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	110	110				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	250	270	270				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	290	273	250	250				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	240	225	225				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	411	411	412	412				
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	337	335	335	335				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage		
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	92	50	92				
16	Narshingsi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	22	22	22				
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x3.73	80	80	49	49	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	0	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	25	24	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	41	16	42				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	34	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	30	106	15	106				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	245	276	275	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	16	149	149	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	252	253	250	250				
27	Branganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	81	90	90	90				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	70	90	80	90				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	92	55	92				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	35	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	55	55	55				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	60	90	60	90				
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	58	92	60	90				
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	3154	3796	3298	3809	653	480		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	146	146	144	144		Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	38	25	38				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	52	87	69	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	0	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52	248	Fuel Oil Shortage		
48	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage		
49	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	8x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	26	26	26				
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	30	5	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	92	11	92				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
55	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90	Fuel Oil Shortage		
56	Juddah 100 MW Unit-1 (Acom)	HFO (QRPPI)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total				2442	2382	804	975	827	981	518	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	44	35	40				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	204	191	205	205				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	310	305	275	275				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	315	310	280	280				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	51	56	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	8	8	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	105	135	125	140				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	29	29	29				
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	30	140	140				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	65	17	50				
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	22	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	25	33	31	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8	44	Fuel Oil Shortage		
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	17	17	17	17				
76	Daudkandi 200 MW PP (B.Tec)	HSD (IPP)	88x1.4+40x1.515+15x1.588	200	200	194	196	100	196				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	17	0	0	0	114	Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	99	115	100	115				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	85	92	96	96				
**	Impoport (Tripura)	India		160	160	144	156	143	165				
Cumilla Zone Total				3193	3169	1777	1908	1774	1970	345	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	71	133	70	110	69	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	78	97	106	106				
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	133	159	95	150				
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	29	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	12	12	12				
Myensingh Zone Total				622	614	318	401	335	378	69	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.08.22 (Yesterday)		29.08.22 (Today)		28.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	50	50	50					
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIIPP, REB)	4x2.90	11	11	0	11	11	11					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	60	60					
94	Shajibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 96MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81					
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	192	193	192	192					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	0	10					
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	24	24	16	24					
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	290	300					
101	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	51	90	90					
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	396	400	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	25	26	26	26	24		Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	49	50	44	44					
Sylhet Zone Total						1291	1359	1362	1390	24	669			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CAPP	Gas (NWPQGCL)	1 x 278+1 x 132	410	410	235	185	175	175	225		Gas Shortage		
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	33					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	0	64					
110	Khulna 225 MW CAPP	HSD (NWPQGCL)	1 x 150+1x75	230	230	219	225	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	10	95	95	95					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	70	35	70	35		Fuel Oil Shortage		
113	Madhumati 100 MW PP	HFO (NWPQGCL)	6x18.415	105	105	15	67	15	67					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16	99		Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage		
**	Bheramara (HVDC)	India		1000	1000	890	891	913	913					
Khulna Zone Total						2388	2384	1461	1646	1558	1658	399	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	30	22	22					
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	86	86	86	86	108		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	880	1080	1150	1150					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17					
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	224	224	220	220					
Barisal Zone Total						1958	1958	1229	1469	1494	1527	108	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32		18	Turbocharger problem		
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	71	131	150	160					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	40	0	40					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	80					
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.		
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0		50	Under maint.		
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPQGCL)	1x150+1x75	210	210	192	192	192	192					
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPQGCL)	1x150+1x75	220	220	213	216	220	220	220		Running on HSD		
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPQGCL)	1x141+1x79	220	220	178	152	152	152	68		Gas Shortage		
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	421	410	410					
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22					
137	Ullapara 11 MW PP (Summit)	Gas (SIIPP, REB)	4x2.90	11	11	11	11	11	11					
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	55	95					
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94					
141	Sirajgonj 6.55 MW Solar	Solar (NWPQGCL)	1x6	6	6	3	0	6	0					
Raishahi Zone Total						2129	2129	1204	1528	1276	1568	459	86	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80					
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	249	250	250					
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	92	55	90					
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Majpara, Talatila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	34	0	34					
150	Intraco Solar 30 MW	Solar (IPP)				10	0	12	0					
Rangpur Zone Total						800	720	401	455	405	454	0	85	
Sub-total: Plants in operation						22058	21680	11639.0	13537	12329	13735	2575	1875	
(B) Plants under long term maintenance/ contract expired														
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22482	21680	11639	13537	12329	13735	2575	1875	
(C) Actual data of 28.08.22 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	14150	MW	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13557	MW	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13696	MW	at =	22:00 hrs	Dhaka	4860	4762	98	Mymensingh	1202	1040	162
04.	Minimum Generation (Generation end)	:	11101	MW	at =	8:00 hrs	Chattogram	1235	1235	0	Sylhet	561	561	0
05.	Day-peak Generation (Generation end)	:	11639	MW	at =	12:00 hrs	Khulna	1678	1569	109	Barisal	397	397	0
06.	Evening-peak Generation (Generation end)	:	13537	MW	at =	21:00 hrs	Rajshahi	1507	1399	108	Rangpur	831	813	18
07.	Evening Peak Load-shed (Sub-station end)	:	565	MW	at =	21:00 hrs	Cumilla	1286	1216	70	Total	13557	12992	565
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11108	MW	at =	5:00 hrs	13. Fuel cost : (a) Gas = 165197780 Taka (c) Coal = 273199157 Taka (b) Oil = 1332191078 Taka Total = 1770588015 Taka							
09.	Generation shortfall at evening peak due to :	:					14. Maximum Temperature in Dhaka was : 32.6° C							
10.	a) Gas limitation	:	2575	MW			15. Export through East-West interconnections : At evening peak-hour : 11639 MW, at 21:00 hrs Maximum : 170 MW, at 21:00 hrs Energy : 0 MKWh							
	c) Coal supply Limitation	:	0	MW										
	b) Low water level in Kaptai lake	:	0	MW										
	c) Plants under shut down/ maintenance	:	1875	MW										
	d) Total Energy (Generation + India Import)	:	294.46	MKWh										
	By Gas = 143.083 MKWh			By Oil = 88.311 MKWh										
	By Coal = 33.510 MKWh			By Hydro = 3.513 MKWh										
	By Solar= 1.112 MKWh													
11.	Total Gas Supplied	:	1089.46	MMCFD										
(D) Forecast of 29.08.22 (Today) Monday :														
01.	Maximum Demand	:	14200	MW	(Generation end)		04.	Maximum Load-shed	:	429	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13735	MW	(Generation end)		05.	Total Generation	:	305.30	MKWh			
03.	Reserve / Shortage	:	-465	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.8° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalul Rahman)
Deputy Secretary, Generation