

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022				Day : Tuesday				Date : 30.08.22					
Probable Maximum Demand : 14300 MW				Probable Maximum Generation : 13664 MW				Rule Curve = 98.01 ft					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.03 ft				Today = 96.40 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.08.22 (Yesterday)		30.08.22 (Today)		29.08.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation (MW)	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	110	110				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	250	260	270	270				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	168	197	200	190	163	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	230	225	225	225	225	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	394	390	380				
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	328	270	300	300				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	13	105	110	110	230	Gas Shortage		
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	92	58	92				
16	Narshingsi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	19	22	22				
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x6.73	80	80	50	51	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x6.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x6.73	33	33	21	24	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	41	16	42				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	34	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	110	15	106				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	255	276	275	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	0	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	233	245	150	150				
27	Branganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	90	90				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	56	94	55	92				
32	Manikganj 162MW PP(MPCL)	HFO (IPP)	9x18	162	162	72	162	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	12	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	55	0	55				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	63	87	24	100				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	51	83	60	92				
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	3109	3736	3006	3704	936	480		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	148	146	144	144		Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	37	25	38				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	69	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	0	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52	248	Fuel Oil Shortage		
48	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	10	10	10	90	Fuel Oil Shortage		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	8x17.0	102	102	17	49	17	51	53	Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	26	26	26	72	Fuel Oil Shortage		
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	25	10	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	10	98	11	92				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	35	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	89	110	92	110				
55	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90	Fuel Oil Shortage		
56	Juddah 100 MW Unit-1 (Acom)	HFO (QRPPI)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage		
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	107	107	107				
Chattogram Zone Total				2442	2382	784	991	795	981	643	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	33	42	35	40				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	201	209	170	170				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	310	320	310				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	330	310	325	310				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	48	55	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	8	8	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	113	128	132	140				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	28	29	29				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	123	123	123				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	50				
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	21	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	9	9	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	25	33	30	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	7	0	8	45	Fuel Oil Shortage		
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	12	14	14	14				
76	Daudkandi 200 MW PP (B.Tec)	HSD (IPP)	88x1.4+40x1.515+15x1.588	200	200	190	194	190	195				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	0	0	0	114	Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	98	106	95	113				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	96	55	55	96				
**	Impoport (Tripura)	India		160	160	116	150	143	165				
Cumilla Zone Total				3193	3169	1881	1940	1859	1977	346	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	65	117	60	110	85	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	109	105	106	106				
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	95	151	95	150				
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutiakehal 50 MW Solar PP	Solar (IPP)	1x50	50	50	21	0	50	0				
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	6	12				
Myensingh Zone Total				622	614	303	385	319	378	85	0		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.08.22 (Yesterday)		30.08.22 (Today)		29.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Cool/Oil/Water Limitation		Machines shut down (MW)	Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening	MW				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	17	17	50						
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIIPP, REB)	4x2.90	11	11	0	11	11	11						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	59	60	60						
94	Shajibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 96MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81						
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	193	193	192	192						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	0	16	16	16						
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	300	300	300						
101	Bibiyan-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	140	140	140	140						
102	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	393	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	16	26	26	34		Gas Shortage			
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	20	20	20						
Sylhet Zone Total				2522	2477	1308	1365	1375	1408	34	669				
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CAPP	Gas (NWPQGCL)	1 x 278+1 x 132	410	410	165	205	180	190	205		Gas Shortage			
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	33						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	62	0	64						
110	Khulna 225 MW CAPP	HSD (NWPQGCL)	1 x 150+1x75	230	230	216	224	225	225						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	70	70	90	95						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	46	72	53	70	33		Fuel Oil Shortage			
113	Madhumati 100 MW PP	HFO (NWPQGCL)	6x18.415	105	105	15	67	15	67						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	102	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16	99		Fuel Oil Shortage			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage			
**	Bheramara (HSDC)	India		1000	1000	897	896	912	912						
Khulna Zone Total				2388	2384	1511	1650	1575	1672	377	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	48						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	33	22	22						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	81	83	83	86	111		Gas Shortage			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	940	1110	1150	1150						
121	Potua Khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload			
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220						
Barisal Zone Total				1958	1958	1284	1478	1507	1543	111	0				
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32		18	Turbocharger problem			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	133	162	150	160						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	2	0	40						
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	80						
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	32		26	Under maint.			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42						
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0		50	Under maint.			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPQGCL)	1x150+1x75	210	210	188	192	190	190						
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPQGCL)	1x150+1x75	220	220	219	217	220	220	220		Running on HSD			
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPQGCL)	1x141+1x79	220	220	140	174	165	165	46		Gas Shortage			
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	267	285	300	147		Gas Shortage			
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22						
137	Ullapara 11 MW PP (Summit)	Gas (SIIPP, REB)	4x2.90	11	11	11	11	11	11						
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage			
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95						
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94						
141	Sirajgonj 6.55 MW Solar	Solar (NWPQGCL)	1x6	6	6	2	0	6	0						
Rajshahi Zone Total				2129	2129	1242	1424	1204	1511	628	94				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	78	80	80						
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250						
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	92	55	90						
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
148	Majpara, Talatila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0						
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	34	0	70						
150	Intraco Solar 30 MW	Solar (IPP)				33	0	12	0						
Rangpur Zone Total				800	720	419	454	405	490	0	85				
Sub-total: Plants in operation				22058	21680	11841.0	13423	12045	13664	3160	1883				
(B) Plants under long term maintenance/ contract expired															
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0	0	0				
Gross Total				22482	21680	11841	13423	12045	13664	3160	1883				
(C) Actual data of 29.08.22 (Yesterday) Monday :															
01.	Max. Demand at eve. peak (Generation end)	:	14300	MW	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13537	MW	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply		
03.	Highest Generation (Generation end)	:	13423	MW	at =	21:00 hrs		MW	MW	MW		MW	MW		
04.	Minimum Generation (Generation end)	:	11108	MW	at =	8:00 hrs	Dhaka	4853	4676	177	Mymensingh	1173	998		
05.	Day-peak Generation (Generation end)	:	11841	MW	at =	12:00 hrs	Chattogram	1312	1312	0	Sylhet	561	511		
06.	Evening-peak Generation (Generation end)	:	13423	MW	at =	21:00 hrs	Khulna	1546	1426	120	Barisal	410	410		
07.	Evening Peak Load-shed (Sub-station end)	:	808	MW	at =	21:00 hrs	Rajshahi	1404	1314	90	Rangpur	887	821		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11624	MW	at =	5:00 hrs	Cumilla	1390	1260	130					
09.	Generation shortfall at evening peak due to :	:									Total	13537	12729		
a)	Gas limitation	:	3160	MW								281156869	Taka		
d)	Coal supply Limitation	:	0	MW								1778882411	Taka		
b)	Low water level in Kaptai lake	:	0	MW											
c)	Plants under shut down/ maintenance	:	1883	MW											
10.	Total Energy (Generation + India Import)	:	294.10	MKWh											
	By Gas =	141.103	MKWh	By Oil =	88.975	MKWh									
	By Coal =	34.406	MKWh	By Hydro =	3.491	MKWh									
	By Solar =	1.394	MKWh												
11.	Total Gas Supplied	:	1101.10	MMCFD											
(D) Forecast of 30.08.22 (Today) Tuesday :															
01.	Maximum Demand	:	14300	MW	(Generation end)		04.	Maximum Load-shed	:	585	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	13664	MW	(Generation end)		05.	Total Generation	:	313.32	MKWh				
03.	Reserve / Shortage	:	-636	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	35.1° C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalul Rahman)
Deputy Secretary, Generation