

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2022					Day : Wednesday					Date : 31.08.22				
Probable Maximum Demand : 14800 MW					Probable Maximum Generation : 13614 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.40 ft					Today = 96.43 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.08.22 (Yesterday)		31.08.22 (Today)		30.08.22 (Yesterday)		31.08.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	110	110					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	250	270	260					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	201	222	200	250	138		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	393	410	390	410					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	260	260	250	250					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	118	125	125	125	210		Gas Shortage		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	92	58	92					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	22	22					
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	49	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	18	25	25					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	41	16	42					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	34	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	15	95	15	95					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	276	286	275	286					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	129	88	129	136					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	154	150	180	180					
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90					
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	93	55	92					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	35	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	55	55		Fuel Oil Shortage		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	89	24	89					
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	59	84	60	85					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	3048	3555	3111	3728	946	480				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	146	145	144	144			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	110	110	110					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	4	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	31	25	31					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	94	69	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Awaiting for HGPI		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	52	52	52	248		Fuel Oil Shortage		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	11	10	10	89		Fuel Oil Shortage		
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	14	51	17	51	51		Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	26	26	26					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	30	10	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	100	11	100					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	35	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	110	92	110					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90		Fuel Oil Shortage		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10	90		Fuel Oil Shortage		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
Chattogram Zone Total			2442	2382	758	983	795	982	568	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	44	35	44					
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	170	209	170	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	270	270	270					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	340	280	280	280					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	56	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	127	140	130	140					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	40	29	40					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	122	0	0	0					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	50	17	50					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	9	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	33	30	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8	44		Fuel Oil Shortage		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	14	14	14					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+69x1.05+15x1.08	200	200	189	189	190	190					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0	114		Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	100	112	100	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	56	96	55	96					
**	Import (Tripura)	India		160	160	148	164	143	165					
Cumilla Zone Total			3193	3169	1839	1811	1644	1834	345	0				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	64	134	64	110	68		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage		
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	115	106	115					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	95	135	95	135					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	5	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	12	6	12					
Mymensingh Zone Total			622	614	276	396	323	372	90	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.08.22 (Yesterday)		31.08.22 (Today)		30.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation	Machines shut down (MW)		
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	17	11	17	17	40		Gas Shortage	
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	110	110		163	under maint.	
92	Hobganga 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	60	63				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	193	193	193	193				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	16	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	300	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	140	140	0	0				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	397	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	27	22	22	22	28		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.5*2	50	50	20	10	20	20	40		Gas Shortage	
Sylhet Zone Total				2522	2477	1382	1351	1342	1345	125	669		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	230	180	230	180		Gas Shortage	
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	0	41				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	0	55				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	221	223	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	75	93	90	93				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	74	53	74	31		Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	32	15	32				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16	99		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
**	Bheramara (HVC)	India		1000	1000	896	897	912	912				
Khulna Zone Total				2388	2384	1534	1661	1575	1678	350	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	32	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	34	22	34				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	82	84	83	86	110		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1000	1170	1000	1170				
121	Potuaakali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	192	160	220	220				
Barisal Zone Total				1958	1958	1328	1497	1357	1559	110	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
b) Baghabari 100 MW GTPP	Gas (PDB)		1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	130	161	130	161				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	40				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	0	80				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0		50	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	195	205	190	206				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	197	216	220	220	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	165	185	165	185				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	284	421	285	412				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Raishahi Zone Total				2129	2129	1161	1592	1176	1624	435	86		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	78	80	80				
b) Barapukuria TPP Unit-2	Coal (PDB)		1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	92	55	92				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tutulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	72	0	70				
	Intraco Solar 30 MW	Solar (IPP)				4	0	12	0				
Rangpur Zone Total				800	720	391	492	405	492	0	85		
Sub-total: Plants in operation				22058	21680	11717.0	13338	11728	13614	2969	1875		
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
153	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	11717	13338	11728	13614	2969	1875		
(C) Actual data of 30.08.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14700	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13962	MW, at =	21:00 hrs	Zone Demand Supply Load Shed Zone Demand Supply Load Shed							
03.	Highest Generation (Generation end)	:	13422	MW, at =	22:00 hrs	Dhaka 4963 4566 397 Mymensingh 1205 980 225							
04.	Minimum Generation (Generation end)	:	11624	MW, at =	7:00 hrs	Chattogram 1443 1400 43 Sylhet 572 482 90							
05.	Day-peak Generation (Generation end)	:	11717	MW, at =	10:00 hrs	Khulna 1751 1631 120 Barishal 422 422 0							
06.	Evening-peak Generation (Generation end)	:	13338	MW, at =	21:00 hrs	Rajshahi 1412 1302 110 Rangpur 844 754 90							
07.	Evening Peak Load-shed (Sub-station end)	:	1255	MW, at =	21:00 hrs	Cumilla 1350 1170 180							
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11567	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				Total 13962 12707 1255							
a) Gas limitation	:	2969	MW			13. Fuel cost : (a) Gas = 159873107 Taka (c) Coal = 291145314 Taka							
d) Coal supply Limitation	:	0	MW			(b) Oil = 1360433024 Taka Total = 1811451445 Taka							
b) Low water level in Kapitai lake	:	0	MW										
c) Plants under shut down/ maintenance	:	1875	MW			14. Maximum Temperature in Dhaka was : 36.1° C							
10.	Total Energy (Generation + India Import)	:	294.39	MKWh		15. Export through East-West interconnections :							
	By Gas = 138.811 MKWh			By Oil = 89.821 MKWh		At evening peak-hour : 11717 MW, at 21:00 hrs							
	By Coal = 35.487 MKWh			By Hydro = 3.513 MKWh		Maximum : 970 MW, at 20:00 hrs							
	By Solar= 1.492 MKWh					Energy : 0 MKWh							
11.	Total Gas Supplied	:	1077.10	MMCFD									
(D) Forecast of 31.08.22 (Today) Wednesday :													
01.	Maximum Demand	:	14800	MW (Generation end)		04. Maximum Load-shed : 1093 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	13614	MW (Generation end)		05. Total Generation : 324.61 MKWh							
03.	Reserve / Shortage	:	-1186	MW (Generation end)		06. Probable Max. Temperature in Dhaka : 35.7° C							