

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022					Day : Thursday					Date : 01.09.22				
Probable Maximum Demand : 14700 MW					Probable Maximum Generation : 14071 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.43 ft					Today = 96.38 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.08.22 (Yesterday)		01.09.22 (Today)		31.08.22 (Yesterday)		01.09.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	106	110	110					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	250	270	260					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	257	323	320	320					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	408	400	390	400					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	275	332	290	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	138	144	150	150	191			Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	92	58	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	22	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	25	52	50	52					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	18	25	25					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	40	16	40					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	34	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	15	110	15	110					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	276	249	260	286					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	175	218	180	218					
27	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90					
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	93	55	92					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	144	35	144					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	55	55			Fuel Oil Shortage	
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	61	89	24	89					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	57	92	60	92					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total					6004	5847	3182	3832	3301	3948	789	480		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	145	146	144	146				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	37	25	37					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	69	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		Awaiting for HGPI	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	70	52	70	230			Fuel Oil Shortage	
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10	90			Fuel Oil Shortage	
49	Dohazari-Kalesh 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51			Fuel Oil Shortage	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	17	26	26					
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			5	30	10	30					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	91	11	100					
53	Sikalbaha 54 MW PP (Iodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	35	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	92	110					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90			Fuel Oil Shortage	
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10	90			Fuel Oil Shortage	
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
Chattogram Zone Total					2442	2382	803	982	795	1000	551	555		
58	Ashuganj TPP Unit-5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	39	39	35	39					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	203	206	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	305	310	300					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	315	310	300					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0				On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	54	55	55					
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	129	123	122	123					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	36	29	36					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	90	90					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	100	17	100					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	7	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	33	30	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8	44			Fuel Oil Shortage	
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	14	14	14					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.015+15x1.088	200	200	140	190	190	190					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0	114			Fuel Oil Shortage	
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	105	112	105	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	15	17	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	87	55	87					
**	Imphort (Tripura)	India		160	160	148	156	143	166					
Cumilla Zone Total					3193	3169	1693	1883	1841	1990	345	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	68	102	70	110	100			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	97	97	115					
84	Myensingtho 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	87	144	90	144					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	32	0	50	0					
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	6	12					
Myensingtho Zone Total					622	614	316	355	315	381	122	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated / Present Capacity (MW)	31.08.22 (Yesterday)		01.09.22 (Today)		31.08.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening						
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.			
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	17	17	17	34		Gas Shortage			
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	112	112	112		51	under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	63						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	193	193	193	193						
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	300	310						
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	140	0	0	0						
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	398	400	400	400						
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	22	25	25	25	25		Gas Shortage			
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	16	16	16	34		Gas Shortage			
Sylhet Zone Total						2522	2477	1340	1346	1335	1348	110	557		
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	200	175	180	200	235		Gas Shortage			
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	0	41						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	0	55						
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	222	222	225	225						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	20	92	90	93						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	56	74	53	74	31		Fuel Oil Shortage			
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	32	15	32						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16	99		Fuel Oil Shortage			
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage			
**	Bheramara (HVCDC)	India		1000	1000	896	805	912	918						
Khulna Zone Total						2388	2384	1480	1512	1575	1654	405	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	32	48						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	35	22	35						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	85	83	85	109		Gas Shortage			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	970	1120	1000	1170						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload			
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	221	220	220						
Barishal Zone Total						1958	1958	1315	1509	1357	1575	109	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24		18	Turbocharger problem			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	86	160	130	161						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	24	36	0	36						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	80						
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.			
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	34	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	205	191	190	206						
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	216	217	220	220	220		Running on HSD			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	176	183	165	185						
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	416	419	285	412						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage			
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6+18.55	113	113	55	95	55	95						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94						
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0						
Rajshahi Zone Total						2129	2129	1307	1647	1176	1660	435	54		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	83	80	83						
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250						
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	55	92	55	92						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	90	0	90						
	Intraco Solar 30 MW	Solar (IPP)				0	0	12	0						
Rangpur Zone Total						800	720	386	515	405	515	0	85		
Sub-total: Plants in operation						22058	21680	11822.0	13581	12100	14071	2866	1731		
(B) Plants under long term maintenance/ contract expired															
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
153	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0				
Gross Total						22482	21680	11822	13581	12100	14071	2866	1731		
(C) Actual data of 31.08.22 (Yesterday) Wednesday :															
01.	Max. Demand at eve. peak (Generation end)	:	14745	MW,	at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13989	MW,	at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13750	MW,	at =	22:00	hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	11567	MW,	at =	8:00	hrs	Dhaka	5013	4686	327	Mymensingh	1203	997	206
05.	Day-peak Generation (Generation end)	:	11822	MW,	at =	9:00	hrs	Chattogram	1363	1363	0	Sylhet	587	529	58
06.	Evening-peak Generation (Generation end)	:	13581	MW,	at =	21:00	hrs	Khulna	1739	1443	296	Barishal	403	403	0
07.	Evening Peak Load-shed (Sub-station end)	:	1073	MW,	at =	21:00	hrs	Rajshahi	1413	1413	0	Rangpur	823	823	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11508	MW,	at =	5:00	hrs	Cumilla	1446	1260	186				
09.	Generation shortfall at evening peak due to :	:										Total	13989	12916	1073
	a) Gas limitation	:	2866	MW											
	d) Coal supply Limitation	:	0	MW											
	b) Low water level in Kaptai lake	:	0	MW											
	c) Plants under shut down/ maintenance	:	1731	MW											
10.	Total Energy (Generation + India Import)	:	298.93	MKWh											
	By Gas =	141.613	MKWH	By Oil =	92.089	MKWh									
	By Coal =	35.353	MKWH	By Hydro =	3.502	MKWh									
	By Solar=	1.319	MKWH												
11.	Total Gas Supplied	:	1085.51	MMCFD											
(D) Forecast of 01.09.22 (Today) Thursday :															
01.	Maximum Demand	:	14700	MW	(Generation end)			04.	Maximum Load-shed	:	580	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14071	MW	(Generation end)			05.	Total Generation	:	319.58	MKWh			
03.	Reserve / Shortage	:	-629	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	32.9° C				

* Coactive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation