

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667 9551095

Month September, 2022				Day : Friday				Date : 02.09.22				
Probable Maximum Demand : 14200 MW				Probable Maximum Generation : 13967 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.38 ft		Today = 96.30 ft		Rule Curve = 93.23 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.09.22 (Yesterday)		02.09.22 (Today)		01.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	210	210	210	210			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	290	280	290			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	10	56	56	56	52	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	281	210	270	210	150	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	398	400	400			
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	325	282	320	320			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	145	130	145	145	205	Gas Shortage	
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	92	50	92			
16	Narshingsdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	0	19	22	22			
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x3.73	80	80	53	52	50	52			
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	16	14	18	18			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	33	16	33			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	34	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	15	113	15	110			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	250	260	260	260			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	214	225	220	225			
27	Branghangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	60	93	55	92			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	144	35	144			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	13	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	18	55	55	Fuel Oil Shortage	
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	62	90	62	90			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	58	92	60	92			
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	3240	3679	3312	3792	897	670	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	147	144	144	144		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	0	0			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	6	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	24	39	25	37			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	69	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	70	52	70	230	Fuel Oil Shortage	
48	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage	
49	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	8x17.0	102	102	17	51	17	51	51	Fuel Oil Shortage	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	8	25	8	25			
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	17	17	17	17			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	30	15	35			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	99	11	100			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	27	36	35	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	106	110	110	110			
55	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10	90	Fuel Oil Shortage	
56	Juddah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10	90	Fuel Oil Shortage	
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
Chattogram Zone Total				2442	2382	774	998	690	892	551	555	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	47	43	47			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	198	206	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	270	310	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	335	280	310	300			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	53	56	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	128	122	123			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	26	44	26	44			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	80	20	90	90			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	15	190	17	190			
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	7	9	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	15	16	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8	44	Fuel Oil Shortage	
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	14	15	14	15			
76	Daudkandi 200 MW PP (B.Tec)	HSD (IPP)	88x1.6+40x1.515+15x1.588	200	200	185	194	190	190			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	0	0	0	114	Fuel Oil Shortage	
78	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	103	115	105	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	76	77	55	77			
**	Impoport (Tripura)	India		160	160	162	156	143	166			
Cumilla Zone Total				3193	3169	1869	1947	1849	2087	345	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	65	97	70	110	105	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	78	115	78	115			
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	111	125	110	125			
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutiakehal 50 MW Solar PP	Solar (IPP)	1x50	50	50	21	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Myensingh Zone Total				622	614	288	349	322	362	127	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.09.22 (Yesterday)		02.09.22 (Today)		01.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation			
						Day	Evening	Day	Evening	MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	17	5	0	0	46		Gas Shortage	
91	Kushlari 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	0	0		51	STG under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	11	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	59	60	60				
94	Shajibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	0	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	192	193	193	193				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x3.34	25	25	8	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	310	310				
101	Bibiyanali 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	291	290	290				
102	Bibiyanali South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	25	5	0	0	45		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	16	5	0	0	45		Gas Shortage	
Sylhet Zone Total						2522	2477	1335	1573	1365	1446	161	557
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	170	180	200	240		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	41				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	61	0	55				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	217	224	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	93	92	90	93				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	37	57	53	74	48		Fuel Oil Shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	32	15	32				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	16	115		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
**	Bheramara (HVC)	India		1000	1000	902	830	918	918				
Khulna Zone Total						2388	2384	1512	1498	1581	1654	443	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	32	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	29	22	35				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	82	86	83	85	108		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	920	1140	1000	1170				
121	Potuskhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	17			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	217	226	220	220				
Barishal Zone Total						1958	1958	1274	1530	1357	1559	108	0
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	24		18	Turbocharger problem	
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	89	162	130	161				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	36				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	80				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.	
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	0	32		19	Under maint.	
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	196	192	190	206				
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	150	216	220	220	220		Running on HSD	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	187	189	165	185				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	420	285	412				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
137	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	8	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	55	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total						2129	2129	1215	1624	1176	1660	435	55
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	82	80	83				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	92	55	92				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	90	0	90				
150	Intraco Solar 30 MW	Solar (IPP)				19	0	12	0				
Rangpur Zone Total						800	720	407	514	405	515	0	85
Sub-total: Plants in operation						22058	21680	11914.0	13712	12057	13967	3067	1922
(B) Plants under long term maintenance/ contract expired													
151	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
153	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
154	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
155	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
156	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0			
Gross Total						22482	21680	11914	13712	12057	13967	3067	1922
(C) Actual data of 01.09.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	14695	MW	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	14027	MW	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	13732	MW	at =	22:00 hrs	Dhaka	5002	4665	337	Mymensingh	1089	1022
04.	Minimum Generation (Generation end)	:	11508	MW	at =	8:00 hrs	Chattogram	1353	1353	0	Sylhet	586	576
05.	Day-peak Generation (Generation end)	:	11914	MW	at =	12:00 hrs	Khulna	1799	1608	191	Barishal	406	406
06.	Evening-peak Generation (Generation end)	:	13712	MW	at =	21:00 hrs	Rajshahi	1477	1305	172	Rangpur	913	848
07.	Evening Peak Load-shed (Sub-station end)	:	906	MW	at =	21:00 hrs	Cumilla	1401	1337	64	Total	14027	13121
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10835	MW	at =	5:00 hrs						1089	1022
09.	Generation shortfall at evening peak due to :	:										586	576
a)	Gas limitation	:	3067	MW								406	406
b)	Coal supply Limitation	:	0	MW								913	848
c)	Low water level in Kaptai lake	:	0	MW									
d)	Plants under shut down/ maintenance	:	1922	MW									
10.	Total Energy (Generation + India Import)	:	300.81	MKWh									
	By Gas =	145.895	MKWh	By Oil =	90.378	MKWh							
	By Coal =	34.860	MKWh	By Hydro =	3.488	MKWh							
	By Solar =	1.105	MKWh										
11.	Total Gas Supplied	:	1080.11	MMCFD									
(D) Forecast of 02.09.22 (Today) Friday :													
01.	Maximum Demand	:	14200	MW	(Generation end)		04.	Maximum Load-shed	:	289	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	13967	MW	(Generation end)		05.	Total Generation	:	311.07	MKWh		
03.	Reserve / Shortage	:	-233	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.2° C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalul Rahman)
Deputy Secretary, Generation