

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 4-Sep-22				Page 2			
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	230	5503000	
3	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	260	6393200	Machine problem
4	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	86	1979045	Gas shortage
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	373	9142270	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	162	4300000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	210	4389500	GT-2 S/D due to dirty gas
9	Meghnaghat 100 MW(EL)	NENP	12'8.9	100	75	1336320	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	108	2798807	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1330818	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	324504	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	73	1246080	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	262	6309321	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	92	1216656	Engine problem
20	Katpolti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	828360	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	114	1054080	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	890025	Engine problem
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	903005	Engine problem
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	47	1158380	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	703600	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	14	370900	Engine problem
29	Gazipur 52 MW PP	PDB	6'8.9	52	33	527040	#REF!
30	Tongi 80 MW GTPP	RPCL	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	242	4491273	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	258'1.4	300	151	2622526	Low Demand
33	Bramhangonj 100 MW PP (Aggreko)	IPP	114'0.959	100	90	1287481	Engine problem
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	90	1299228	Engine problem
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	140	2932272	
36	Gazipur 100 MW PP	RPCL	6'17.5	105	100	1323600	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	93	1547520	Engine problem
38	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	1765440	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	166501	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	18	441350	Fuel shortage
Dhaka area Total				5847	3456	70582092	
41	Chattogram TPP-1	PDB	1'210	180	105	2600000	Machine problem
42	Chattogram TPP-2	RPCL	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	580426	
43	Teknaf 20MW PP (Solartech)	IPP	20	20	0	99360	Contract Expired
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	39	704640	Engine problem
45	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	151	3563438	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2036536	
49	Hafizhazari 100 MW peaking PP	PDB	11'8.9	98	25	550896	Fuel shortage
50	Dohazari-Katish 100 MW Peaking	PDB	8'17	102	48	406938	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	66	1018680	Engine problem
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	90	1109760	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	15	354048	Engine problem
*	Malancha, Clg. EPZ (Unlited)		5'8.73+3'9.34	0	30	575520	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	94	623040	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25920	
56	Anwara 300 MW PP (Unlited)	IPP	17'17+24	300	52	1247018	Fuel shortage
57	Jodac Power	IPP	3'18.55+1'3.6	54	36	779081	Engine problem
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	110	2524413	
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	100	1233600	Fuel shortage
60	Anlima Energy Ltd.	IPP	6'21.2	116	107	2537945	Engine problem
Mirsharai 150 MW				BPDB-RPCL	18.5'9	0	On test.
Chattogram area Total				2382	1198	22571259	
61	Ashuganj TPP Unit- 3	APSCL	1'1150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 4	APSCL	1'1150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 5	APSCL	1'1150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	199	4853000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	290	7532700	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	290	7091000	FGMO
	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	0	0	On test.
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	45	993960	
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	56	1296960	
67	Ashuganj 195MW PP (APSCL-Unlited)	IPP	20'9.73+1'16	195	8	217454	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1235073	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	137	3143054	Engine problem
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	27	582120	Engine problem
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	48	1439490	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	200	1602240	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	506772	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	217260	
**	Import (Tripura)	Imported power	0	160	146	3206400	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	558300	Engine problem
76	Jangalia 4 MW PP (Lakdorew)	IPP	6'8.92	52	34	158578	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3'67+2'6.97	25	20	449500	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	140	2801856	Low Demand
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	45	273600	Fuel shortage
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	114	2505720	
81	Bhairab 54.5 MW	IPP	3'18.2	54	17	424440	33 kV feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	96	1277760	Engine problem
Cumilla Area Total				3169	2020	42367237	
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	110	2471040	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	0	Gas shortage
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	0	0	12750	
87	Mymensingh 200 MW PP (Unlited)	IPP	9.78'21	200	97	2160000	Fuel shortage
88	Jamalpur 115 MW PP (Unlited)	IPP	9.78'12	115	106	2386800	Engine problem
89	Sutakhalhi 50 MW Solar PP	IPP	50	50	0	189520	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	297600	Engine problem
Mymensingh Area Total				614	325	7517770	
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	1021000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	41	964080	Machine problem
93	Kushihara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	544800	
96	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	49	556056	
97	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	264000	
98	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	61	1472544	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	3'2.90	86	81	1296960	
100	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
101	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	0	0	Machine problem
102	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage
	Sylhet 50MW PP (EPL)	NENP	27'2	50	24	317200	Gas shortage
103	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	24	517104	
104	Bibiiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	7282000	FGMO
104	Bibiyanra 400 MW CCPP	PDB	400 MW	400	401	9459000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	215820	
106	Bibiyanra South 400 MW	PDB	400 MW	383	401	9338300	
Sylhet Area Total				2477	1469	33248864	
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	
**	Bheramara (HVDC)	Imported power	2'500	1000	890	21600727	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	0	0	Fuel shortage
109	Fardpur 50 MW Peaking PP	PDB	8'6.98	54	41	243360	Engine problem
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	224	4607040	
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	58	301952	Engine problem
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	185	4932864	Gas shortage.
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	92	1016640	Engine problem
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	75	1150560	Fuel shortage
115	Madhumathi 100 MW PP	NWPGCL	6'18	105	15	105408	Fuel shortage
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	401040	
	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	