

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667 9551095

Month September, 2022				Day : Monday				Date : 05.09.22				
Probable Maximum Demand :				14200 MW				Probable Maximum Generation : 14075 MW				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.19 ft				Today = 96.17 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.09.22 (Yesterday)		05.09.22 (Today)		04.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation			
					Day	Evening	Day	Evening	MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	260	260	260			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	77	86	90	90	22	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	218	162	200	200	198	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	215	210	225	225	240	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	409	373	400	400			
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	282	262	280	280			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	123	108	120	120	227	Gas Shortage	
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	92	50	92			
16	Narshingsi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	19	19	20	20			
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x3.73	80	80	50	47	51	51			
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	14	14	21	21			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	33	16	41			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	100	50	100			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	114	17	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	163	242	260	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	134	140	112	130			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	150	151	220	220			
27	Branghangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	82	90	90	90			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	93	55	93			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	18	18	18	18	37	Fuel Oil Shortage	
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	45	73	62	90			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	50	75	50	85			
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	3072	3456	3254	3760	934	670	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	105	151	150	150		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	108	105	110	110			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	39	25	38			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	69	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52	248	Fuel Oil Shortage	
48	Jaldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	90	33	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	8x17.0	102	102	0	48	17	47	54	Fuel Oil Shortage	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	25	26	26			
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	15	15	17	17			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			10	30	10	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	94	11	86			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	35	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
55	Jaldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	100	38	100			
56	Jaldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	66	30	80			
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	93	107	107	107			
Chattogram Zone Total				2442	2382	823	1198	890	1199	302	555	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	45	45	43	45			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	200	199	200	190			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	340	290	300	280			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	350	290	330	310			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	56	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	137	130	140			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	27	25	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	48	80	80			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	200	17	200			
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	5	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	8	25	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	34	8	43	18	Fuel Oil Shortage	
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	16	20	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.588	200	200	52	140	100	190			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	45	17	17	69	Fuel Oil Shortage	
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	107	114	105	113			
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	21	96	40	96			
**	Impoport (Tripura)	India		160	160	116	146	143	165			
Cumilla Zone Total				3193	3169	1630	2020	1754	2120	274	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	67	110	60	100	92	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	106	106	115			
84	Mymsensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	86	97	87	95			
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutiakehal 50 MW Solar PP	Solar (IPP)	1x50	50	50	15	0	50	0			
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymsensing Zone Total				622	614	287	325	317	322	114	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.09.22 (Yesterday)		05.09.22 (Today)		04.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	MW	Machines shut down (MW)			
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	53	31	53					
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIIPP, REB)	4x2.90	11	11	11	11	11	11					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	61	60	64					
94	Shajibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 96MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	60	81	81	81					
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	22	24	0	0					
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	270	300	300					
101	Bibiya-I-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400					
102	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	396	401	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	24	24	25	25	26		Gas Shortage		
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	30	49	20	44					
Sylhet Zone Total						2522	2477	1446	1469	1422	1472	26	669	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CAPP	Gas (NWPQGCL)	1 x 278+1 x 132	410	410	215	185	125	125	225		Gas Shortage		
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	0	50					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	58	0	60					
110	Khulna 225 MW CAPP	HSD (NWPQGCL)	1 x 150+1x75	230	230	160	224	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	92	20	94					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	37	75	35	75					
113	Madhumati 100 MW PP	HFO (NWPQGCL)	6x18.415	105	105	0	15	15	15					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	54	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	115		Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage		
**	Bheramara (HVC)	India		1000	1000	891	890	907	907					
Khulna Zone Total						2388	2384	1357	1580	1427	1551	380	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	32					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	34	20	30					
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	84	83	85	85	111		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	880	1090	1110	1110					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload		
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	218	226	220	220					
Barisal Zone Total						1958	1958	1219	1465	1467	1494	111	0	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32		18	Turbocharger problem		
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	132	60	165					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	80					
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24		26	Under maint.		
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32		18	Under maint.		
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPQGCL)	1x150+1x75	210	210	205	192	190	190					
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPQGCL)	1x150 + 1x75	220	220	179	152	220	220	220		Running on HSD		
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPQGCL)	1x141+1x79	220	220	206	188	195	190					
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	419	414	414					
136	Bogra 22 MW PP (BBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22					
137	Ullapara 11 MW PP (Summit)	Gas (SIIPP, REB)	4x2.90	11	11	8	8	10	10					
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	52					
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	55	95	60	95					
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94					
141	Sirajgonj 6.55 MW Solar	Solar (NWPQGCL)	1x6	6	6	3	0	6	0					
Raishahi Zone Total						2129	2129	1149	1514	1235	1645	391	62	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	81	80	80					
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250					
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	55	92	55	92					
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
148	Majpara, Talatila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
149	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	90	0	90					
150	Intraco Solar 30 MW	Solar (IPP)				2	0	12	0					
Rangpur Zone Total						800	720	391	513	405	512	0	85	
Sub-total: Plants in operation						22058	21680	11374.0	13540	12171	14075	2532	2041	
(B) Plants under long term maintenance/ contract expired														
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22482	21680	11374	13540	12171	14075	2532	2041	
(C) Actual data of 04.09.22 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	:	13831	MW	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13293	MW	at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13540	MW	at =	21:00 hrs	Dhaka	4731	4640	91	Mymensingh	1122	945	177
04.	Minimum Generation (Generation end)	:	10301	MW	at =	8:00 hrs	Chattogram	1359	1359	0	Sylhet	499	499	0
05.	Day-peak Generation (Generation end)	:	11374	MW	at =	12:00 hrs	Khulna	1711	1711	0	Barisal	405	405	0
06.	Evening-peak Generation (Generation end)	:	13540	MW	at =	21:00 hrs	Rajshahi	1427	1427	0	Rangpur	805	805	0
07.	Evening Peak Load-shed (Sub-station end)	:	268	MW	at =	21:00 hrs	Cumilla	1235	1235	0	Total	13293	13025	268
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10580	MW	at =	5:00 hrs	13. Fuel cost : (a) Gas = 161433949 Taka (c) Coal = 266169069 Taka							
09.	Generation shortfall at evening peak due to :	:					(b) Oil = 1174907487 Taka Total = 1602510505 Taka							
a)	Gas limitation	:	2532	MW			14. Maximum Temperature in Dhaka was : 30.6° C							
d)	Coal supply Limitation	:	0	MW			15. Export through East-West interconnections :							
b)	Low water level in Kaptai lake	:	0	MW			At evening peak-hour	:	11374	MW	at	21:00 hrs		
c)	Plants under shut down/ maintenance	:	2041	MW			Maximum	:	1100	MW	at	22:00 hrs		
10.	Total Energy (Generation + India Import)	:	284.52	MKWh			Energy	:	0	MKWh				
						By Gas =	141.792	MKWh	By Oil =	80.568	MKWh			
						By Coal =	32.726	MKWh	By Hydro =	3.563	MKWh			
						By Solar =	1.060	MKWh						
11.	Total Gas Supplied	:	1075.43	MMCFD										
(D) Forecast of 05.09.22 (Today) Monday :														
01.	Maximum Demand	:	14200	MW	(Generation end)		04.	Maximum Load-shed	:	115	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14075	MW	(Generation end)		05.	Total Generation		298.38	MKWh			
03.	Reserve / Shortage	:	-125	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :		32.4° C				