

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022					Day : Tuesday					Date : 06.09.22				
Probable Maximum Demand : 13400 MW					Probable Maximum Generation : 14114 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.17 ft					Today = 96.23 ft				
					Rule Curve = 100.15 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.09.22 (Yesterday)		06.09.22 (Today)		05.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Water Limitation	06.09.22 (Yesterday) Probable Peak Generation (MW)	06.09.22 (Today) Probable Peak Generation (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)							
					Day	Evening	Day	Evening	MW	(MW)				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	240	260	260					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	77	90	90	31		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	186	166	200	170	194		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	215	200	200	200	250		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	351	400	360					
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	264	224	280	300	111		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	122	115	120	120	220		Gas Shortage		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	92	50	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	46	49	51	51					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	12	21	21					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	16	16	32					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	85	50	85					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	17	116	17	115					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	192	255	260	285					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	225	226	220	220					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	81	90	80	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	74	55	93					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	9	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	18	18	18	18	37		Fuel Oil Shortage		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	62	80	62	80					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	51	75	50	75					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	3121	3466	3265	3662	1053	670				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	144	150	150			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	105	105					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0					
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	26	38	25	38					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	105	55	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI Ongoing		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	160	160	160	140		Fuel Oil Shortage		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	32	90	33	90					
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	13	47	17	47	55		Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	24	26	26					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			9	23	10	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	7	94	11	94					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	35	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	90	38	90					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	78	33	80					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107					
Chattogram Zone Total			2442	2382	812	1291	980	1298	195	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	45	43	45					
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	205	209	205	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	325	280	330	280					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	345	280	330	280					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	48	56	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	16	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	142	130	145					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	15	30	25	35					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	0	0	0					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	27	150	17	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	29	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	34	8	34	18		Fuel Oil Shortage		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+69x1.05+15x1.085	200	200	185	150	100	190					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	0	52	97		Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	96	106	105	105					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	38	96	40	96					
**	Import (Tirupura)	India		160	160	134	94	143	166					
Cumilla Zone Total			3193	3169	1793	1844	1690	2052	302	0				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	65	93	68	100	109		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage		
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	91	107	90	108					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	91	95	90	95					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	5	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total			622	614	264	307	312	315	131	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.09.22 (Yesterday)		06.09.22 (Today)		05.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for				
						Day	Evening	Day	Evening	MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	47	31	47					
91	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11					
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	60	64					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.		
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	10	24	24	24					
100	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	260	300	300					
101	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	401	400	400					
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	401	400	400					
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	20	25	25	25	25		Gas Shortage		
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	28	37	20	44					
Sylhet Zone Total						2522	2477	1427	1440	1446	1490	45	900	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	250	230	250	250	180		Gas Shortage		
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	50					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	0	60					
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	218	227	225	225					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	50	60	20	94					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	37	75	35	75					
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	15	15					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	24	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	115		Fuel Oil Shortage		
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage		
	Rampal 1320 MW	Coal (BIFPCL)				107	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	892	891	908	908					
Khulna Zone Total						2388	2384	1578	1608	1553	1677	335	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	32					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	28	20	30					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	86	85	85	108		Gas Shortage		
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	820	1080	1110	1110					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload		
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	218	220	220	220					
Barishal Zone Total						1958	1958	1156	1446	1467	1494	108	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32		18	Turbocharger problem		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	50	80	60	165					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	80					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	32	16	32		18	Under maint.		
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33		17	Under maint.		
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	193	192	194	194					
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	204	217	220	220	220		Running on HSD		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	199	178	195	190					
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	428	414	414					
135	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	95	60	95					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94					
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0					
Raishahi Zone Total						2129	2129	1245	1502	1255	1614	391	53	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	82	80	80					
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	249	250	250	250					
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	54	91	55	92					
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	90	0	90					
	Intraco Solar 30 MW	Solar (IPP)				23	0	12	0					
Rangpur Zone Total						800	720	410	513	405	512	0	85	
Sub-total: Plants in operation						22058	21680	11806.0	13417	12373	14114	2560	2263	
(B) Plants under long term maintenance/ contract expired														
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020		
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0				
Gross Total						22482	21680	11806	13417	12373	14114	2560	2263	
(C) Actual data of 05.09.22 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)					:	13522	MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :			
02.	Max. Demand at eve. peak (Sub-station end)					:	13000	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)					:	13417	MW, at =	19:30 hrs					
04.	Minimum Generation (Generation end)					:	10580	MW, at =	8:00 hrs	Dhaka	4711	4711	0	
05.	Day-peak Generation (Generation end)					:	11806	MW, at =	12:00 hrs	Chattoogram	1378	1378	0	
06.	Evening-peak Generation (Generation end)					:	13417	MW, at =	19:30 hrs	Khulna	1551	1551	0	
07.	Evening Peak Load-shed (Sub-station end)					:	97	MW, at =	19:30 hrs	Rajshahi	1325	1325	0	
08.	Minimum Generation Forecast up to 8:00 hrs.					:	10615	MW, at =	5:00 hrs	Cumilla	1268	1268	0	
09.	Generation shortfall at evening peak due to :					:					Total	13000	12903	97
	a) Gas limitation					:	2560	MW		13.	Fuel cost :			
	d) Coal supply Limitation					:	0	MW			(a) Gas = 162471265 Taka			
	b) Low water level in Kaptai lake					:	0	MW			(c) Coal = 264347818 Taka			
	c) Plants under shut down/ maintenance					:	2263	MW			(b) Oil = 1228910641 Taka			
	Total Energy (Generation + India Import)					:	287.47	MKWh		14.	Maximum Temperature in Dhaka was : 34° C			
	By Gas = 141.945 MKWh					By Oil =	83.704	MKWh		15.	Export through East-West interconnections :			
	By Coal = 33.086 MKWh					By Hydro =	3.511	MKWh			At evening peak-hour : 11806 MW, at 19:30 hrs			
	By Solar= 0.874 MKWh										Maximum : 1115 MW, at 21:00 hrs			
11.	Total Gas Supplied					:	1051.99	MMCFD			Energy : 0 MKWh			
(D) Forecast of 06.09.22 (Today) Tuesday :														
01.	Maximum Demand					:	13400	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)			
02.	Maximum Generation					:	14114	MW	(Generation end)	05.	Total Generation : 287.11 MKWh			
03.	Reserve / Shortage					:	714	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 32.6° C			