

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022					Day : Wednesday					Date : 07.09.22				
Probable Maximum Demand : 13800 MW					Probable Maximum Generation : 13805 MW					Rule Curve = 100.38 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.23 ft					Today = 96.27 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.09.22 (Yesterday)		07.09.22 (Today)		06.09.22 (Yesterday)		07.09.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	250	260	260	260					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	83	80	83	25		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	189	190	190	190	170		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	205	190	200	200	260		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	375	360	375					
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	236	240	250	99		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	110	110	110	110	225		Gas Shortage		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	50	92					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	16	16					
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	52	51	52					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	12	10	12					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	18	41	16	41					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	47	50	50					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	17	115	17	115					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	278	260	280					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	128	132	132	132					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	220	225	150	225					
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	90	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	92	55	92					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	11	0	11	44		Fuel Oil Shortage		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	72	62	72					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	41	66	50	66					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	2959	3499	3036	3528	1033	670				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	153	150	153			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	105	105					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	25	25	25					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	55	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI Ongoing		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	161	161	160	161	139		Fuel Oil Shortage		
48	Judhah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	32	90	33	90					
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	11	46	17	46	56		Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	24	24	24					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			10	31	10	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	84	11	84					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	35	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	72	60	72					
55	Judhah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	100	38	100					
56	Judhah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	78	33	78					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	92	107	107	107					
Chattogram Zone Total			2442	2382	883	1255	926	1244	195	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	45	43	45					
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1x75	221	221	200	206	205	206					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	295	280	300					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	340	295	280	295					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	51	56	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	118	130	130	130					
68	Titao 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	34	25	34					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	90	50	80					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	156	17	100					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	35	8	35	17		Fuel Oil Shortage		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+68x1.05+15x1.08	200	200	191	193	100	193					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	50	17	50	64		Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	96	115	105	115					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	35	96	34	96					
**	Import (Tripura)	India		160	160	127	156	143	166					
Cumilla Zone Total			3193	3169	1721	2111	1651	2059	268	0				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	64	111	70	110	91		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage		
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	107	115	90	115					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	98	87	80	90					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	8	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total			622	614	290	325	304	327	113	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.09.22 (Yesterday)		07.09.22 (Today)		06.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for							
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date				
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.					
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	30	30								
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	6	11								
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	63	60	63								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.					
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24								
100	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	300	300	300								
101	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	403	400	400								
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	260	260	400	400								
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	23	23	23	23	27		Gas Shortage					
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	6	6	20	20								
Sylhet Zone Total				2522	2477	1273	1264	1438	1446	47	900						
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	80	180	200	330		Gas Shortage					
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	10	0	40								
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60								
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	145	225	225								
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	85	89	20	90								
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	70	35	70								
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	32	15	32								
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	87	0	100	0								
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	115		Fuel Oil Shortage					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage					
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0								
**	Bheramara (HSDC)	India		1000	1000	891	891	908	908								
Khulna Zone Total				2388	2384	1098	1317	1483	1625	485	0						
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	32								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	38	20	38								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	30	65	65	164		Gas Shortage					
120	Payra 1320 MW TPP	Coal (BCPCL)		1244	1244	60	430	1110	1110								
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	139	220	220								
Barishal Zone Total				1958	1958	83	669	1447	1482	164	0						
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32		18	Turbocharger problem					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	165	164	60	164								
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0								
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	0	80								
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.					
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0								
131	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		24	Under maint.					
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	206	206	194	200								
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	211	219	220	220	220		Running on HSD					
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	204	202	195	202								
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	420	414	414								
136	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	21	22	22	22								
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	10	11								
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	8	8								
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	75	60	75								
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94								
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0								
Raishahi Zone Total				2129	2129	1359	1626	1255	1580	391	60						
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	82	80	82								
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250								
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	92	55	92								
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
148	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0								
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	34	90	0	90								
	Intraco Solar 30 MW	Solar (IPP)				22	0	12	0								
Rangpur Zone Total				800	720	446	514	405	514	0	85						
Sub-total: Plants in operation				22058	21680	10112.0	12580	11945	13805	2696	2270						
(B) Plants under long term maintenance/ contract expired																	
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020					
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022					
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0								
Gross Total				22482	21680	10112	12580	11945	13805	2696	2270						
(C) Actual data of 06.09.22 (Yesterday) Tuesday :																	
01.	Max. Demand at eve. peak (Generation end)	:	13800	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	13294	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	13342	MW, at =	23:00 hrs		Dhaka	4705	4555	150	Mymsensingh	1079	857	222			
04.	Minimum Generation (Generation end)	:	9749	MW, at =	9:00 hrs	Chattogram	1363	1313	50	Sylhet	554	554	0				
05.	Day-peak Generation (Generation end)	:	10112	MW, at =	12:00 hrs	Khulna	1632	1372	260	Barishal	385	385	0				
06.	Evening-peak Generation (Generation end)	:	12580	MW, at =	21:00 hrs	Rajshahi	1335	1175	160	Rangpur	873	743	130				
07.	Evening Peak Load-shed (Sub-station end)	:	1124	MW, at =	21:00 hrs	Cumilla	1368	1216	152								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10924	MW, at =	5:00 hrs												
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :											
	a) Gas limitation	:	2696	MW		(a) Gas = 153633779 Taka				(c) Coal = 184198812 Taka							
	d) Coal supply Limitation	:	0	MW		(b) Oil = 1346424757 Taka				Total = 1684257348 Taka							
	b) Low water level in Kaptai lake	:	0	MW													
	c) Plants under shut down/ maintenance	:	2270	MW													
10.	Total Energy (Generation + India Import)	:	277.92	MKWh		14. Maximum Temperature in Dhaka was : 32.5° C											
	By Gas = 133.835 MKWH		By Oil = 91.357 MKWh			15. Export through East-West interconnections :											
	By Coal = 25.637 MKWH		By Hydro = 3.501 MKWh			At evening peak-hour : 10112 MW, at 21:00 hrs											
	By Solar= 0.995 MKWH					Maximum : 825 MW, at 21:00 hrs											
11.	Total Gas Supplied	:	1014.44	MMCFD		Energy : 0 MKWh											
(D) Forecast of 07.09.22 (Today) Wednesday :																	
01.	Maximum Demand	:	13800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	13805	MW	(Generation end)	05.	Total Generation	:	287.46	MKWh							
03.	Reserve / Shortage	:	5	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.4° C								

* Cative Power ** Imported