

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022					Day : Thursday				Date : 08.09.22			
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 13856 MW							
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.27 ft				Today = 96.26 ft			
					Rule Curve = 100.61 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.09.22 (Yesterday)		08.09.22 (Today)		07.09.22 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation	Machines shut down	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	(MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	200	200			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	280	280	280			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	81	90	90	27	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	200	140	150	150	220	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	195	195	195	255	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	395	340	350	350			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	260	220	220	220	115	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	132	103	110	110	232	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	40	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	75	50	75			
16	Narshingsdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
17	Summit Power,(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	53	49	52	52			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	14	15	15			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	40	16	41			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	48	48	50	50			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	114	16	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	260	260	280			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	132	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	218	225	150	225			
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90			
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	73	17	74			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	15	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	18	0	18	37	Fuel Oil Shortage	
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	80	30	80			
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	41	82	40	80			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	3165	3378	2882	3446	1096	670
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	152	150	150		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	105	105			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	0	25	25			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	55	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	164	211	210	210	89	Fuel Oil Shortage	
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	32	90	33	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	11	45	11	45	57	Fuel Oil Shortage	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	24	24	24			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			6	0	5	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	86	12	85			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	35	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	92	110	110			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	100	38	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	65	33	65			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
Chattogram Zone Total					2442	2382	891	1256	1016	1315	146	555
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	33	44	40	45			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	205	205	205	206			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	280	285	300	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	355	300	300	300			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		On test	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	55	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	137	135	135			
68	Titao 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	33	34	34			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	50	50	50	50			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	85	17	100			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	0	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	42	8	42			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+68x1.516+15x1.086	200	200	120	193	100	193			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	52			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	97	107	105	107			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	96	34	96			
**	Import (Tirupura)	India		160	160	146	156	143	166			
Cumilla Zone Total					3193	3169	1726	2028	1702	2040	187	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	67	102	70	100		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	86	86	80	90			
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0			
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total					622	614	330	315	329	317	122	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.09.22 (Yesterday)		08.09.22 (Today)		07.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	50	50	50				
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	5	8	8				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	62	62				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.	
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
100	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	310	310	310				
101	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	404	400	400				
102	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	395	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	23	26	25	25	24		Gas Shortage	
105	Fenchuganji 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	30	45	45	45				
Sylhet Zone Total				2522	2477	1413	1497	1499	1499	44	900		
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	185	225	205	225	185		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	35				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	50	0	50				
110	Khulna 225 MW CAPP	HSD (NWPGCL)	1 x 150+1x75	230	230	223	226	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	92	90	90				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	74	35	70				
113	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	15	32	15	32				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	92	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	115		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				148	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	900	903	919	919				
Khulna Zone Total				2388	2384	1598	1636	1589	1646	340	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	16	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	31	17	30				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	64	65	65	65	129		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	1100	1110	1110				
121	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	225	220	220				
Barishal Zone Total				1958	1958	1081	1469	1428	1490	129	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24		18	Turbocharger problem	
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	10	121	60	164				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	80				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
131	Santalaha 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		24	Under maint.	
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	204	196	194	200				
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	195	214	220	220	220		Running on HSD	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	206	206	195	205				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	400	415	414	414				
136	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	18	18	18	18				
137	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
139	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	95	60	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	50	94	50	94				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	5	0	6	0				
Raishahi Zone Total				2129	2129	1182	1541	1252	1591	391	60		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	75	80				
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	92	55	92				
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majpara, Talulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	90	0	90				
	Intraco Solar 30 MW	Solar (IPP)				29	0	12	0				
Rangpur Zone Total				800	720	419	511	400	512	0	85		
Sub-total: Plants in operation				22058	21680	11805.0	13631	12097	13856	2455	2270		
(B) Plants under long term maintenance/ contract expired													
148	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	11805	13631	12097	13856	2455	2270		
(C) Actual data of 07.09.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14300 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13779 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13761 MW, at =	22:00 hrs	Dhaka	4892	4732	160	Mymensingh	1155	928	227	
04.	Minimum Generation (Generation end)	:	10924 MW, at =	7:00 hrs	Chattogram	1392	1392	0	Sylhet	563	518	45	
05.	Day-peak Generation (Generation end)	:	11805 MW, at =	10:00 hrs	Khulna	1745	1745	0	Barishal	423	423	0	
06.	Evening-peak Generation (Generation end)	:	13631 MW, at =	21:00 hrs	Rajshahi	1442	1362	80	Rangpur	900	820	80	
07.	Evening Peak Load-shed (Sub-station end)	:	617 MW, at =	21:00 hrs	Cumilla	1267	1242	25					
08.	Minimum Generation Forecast up to 8.00 hrs.	:	11547 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
a)	Gas limitation	:	2455 MW		13.	Fuel cost :	(a) Gas = 165845868 Taka	(c) Coal = 257762866 Taka					
d)	Coal supply Limitation	:	0 MW				(b) Oil = 1330444746 Taka	Total = 1754053480 Taka					
b)	Low water level in Kaptai lake	:	0 MW										
c)	Plants under shut down/ maintenance	:	2270 MW		14.	Maximum Temperature in Dhaka was :	35.0° C						
10.	Total Energy (Generation + India Import)	:	304.60 MKWh		15.	Export through East-West interconnections :							
	By Gas = 144.676 MKWH	By Oil = 89.350 MKWh				At evening peak-hour	:	11805 MW, at	21:00 hrs				
	By Coal = 41.516 MKWH	By Hydro = 2.081 MKWh				Maximum	:	825 MW, at	21:00 hrs				
	By Solar= 1.624 MKWH					Energy	:	0 MKWh					
11.	Total Gas Supplied	:	1058.74 MMCFD										
(D) Forecast of 08.09.22 (Today) Thursday :													
01.	Maximum Demand	:	14200 MW	(Generation end)	04.	Maximum Load-shed	:	317 MW	At evening peak (Sub-station end)				
02													

* Cative Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00