

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Friday				Date : 09.09.22					
Probable Maximum Demand : 13700 MW				Probable Maximum Generation : 13445 MW				Rule Curve = 100.84 ft					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.26 ft				Today = 96.02 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.09.22 (Yesterday)		09.09.22 (Today)		08.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation	09.09.22 (Today) Probable Peak Generation (MW)	08.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation	09.09.22 (Today) Probable Peak Generation (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Under maint.
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	270	250	250	250				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	80	80	80	28			Gas Shortage
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	161	142	150	150	218			Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	195	185	195	200	265			Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	361	339	350	350	73			Gas Shortage
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	232	221	220	220	114			Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	122	110	110	110	225			Gas Shortage
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	75	50	75				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	19	19	22	22				
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x3.73	80	80	48	46	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	25	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	14	13	15	20				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	23	40	16	40				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	32	48	50	50				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	115	16	115				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	276	275	260	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	117	149	132	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	154	140	150	225				
27	Branghangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	90	80	90				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	74	17	74				
32	Manikganj 162MW PP(MPCL)	HFO (IPP)	9x18	162	162	72	162	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0	55			Fuel Oil Shortage
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	27	78	30	80				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	32	73	40	75				
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2914	3277	2870	3415	1188	670		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	150	150	150				Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	0	0				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	38	15	38				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	55	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225		HGPI Ongoing
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	215	214	210	214	86			Fuel Oil Shortage
48	Jaldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	90	33	90				
49	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	8x17.0	102	102	11	51	11	51	51			Fuel Oil Shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	23	0	24				
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	13	13	13	13				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	18	12	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	11	0	11				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	35	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
55	Jaldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	100	38	100				
56	Jaldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	78	33	78				
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total				2442	2382	1012	1274	872	1182	137	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	34	42	40	42				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	201	200	205	206				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	330	305	300	305				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	340	315	0	0				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0				On test
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	53	54	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	75	75	187			Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	120	120	135	135				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	33	30	33				
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	50	50	0	0				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	85	17	85				
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	21	22	15	22				
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	0	25	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.588	200	200	190	100	100	184				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	17	17	17	17	97			Fuel Oil Shortage
78	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	102	114	105	113				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115				
**	Impoport (Tripura)	India		160	160	160	156	143	166				
Cumilla Zone Total				3193	3169	1819	1903	1412	1728	284	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	63	99	80	100	103			Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	86	107	115	115				
84	Myensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	114	97	100	100				
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	55	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Myensing Zone Total				622	614	332	315	359	327	125	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.09.22 (Yesterday)		09.09.22 (Today)		08.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	33	30	33				
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	62	62				
94	Shajibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0		231	Under maint.	
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shehjanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	320	310	320				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	404	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	378	386	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	26	25	26	24		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	30	30	30	30				
Sylhet Zone Total						2522	2477	1436	1467	1464	1478	44	900
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	225	280	250	280	130		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	50	0	50				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	75	0	75				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	119	222	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	91	20	90	90				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	74	35	74				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	99	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	115		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	902	902	918	918				
Khulna Zone Total						2388	2384	1486	1673	1633	1762	285	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	48	16	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	31	22	31				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	65	64	65	65	130		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	930	1070	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	219	220	220				
Barisal Zone Total						1958	1958	1274	1432	1433	1491	130	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24		18	Turbocarger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	161	50	60	164				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	0	81				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage	
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		24	Under maint.	
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	196	200	194	200				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	214	217	220	220	220		Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	183	156	150	160	64		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	419	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	18	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
138	Bagura 11.3 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	60	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total						2129	2129	1315	1431	1207	1547	549	60
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	83	75	83				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	92	55	92				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgonj 115MW PP (Energyrac)	HFO (IPP)	6*20	115	115	0	90	0	90				
	Intraco Solar 30 MW	Solar (IPP)				19	0	12	0				
Rangpur Zone Total						800	720	411	515	400	515	0	85
Sub-total: Plants in operation						22058	21680	11999.0	13287	11650	13445	2742	2270
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		85	Under Overhauling	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22482	21680	11999	13287	11650	13445	2742	2270
(C) Actual data of 08.09.22 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	14370	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13816	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13608	MW, at =	22:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	11547	MW, at =	8:00 hrs	Dhaka	4859	4652	207	Mymensingh	1151	886	265
05.	Day-peak Generation (Generation end)	:	11999	MW, at =	12:00 hrs	Chattogram	1449	1449	0	Khulna	633	505	128
06.	Evening-peak Generation (Generation end)	:	13287	MW, at =	19:30 hrs	Chattogram	1696	1677	19	Barishal	417	417	0
07.	Evening Peak Load-shed (Sub-station end)	:	998	MW, at =	19:30 hrs	Rajshahi	1360	1249	111	Rangpur	907	774	133
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10481	MW, at =	5:00 hrs	Cumilla	1343	1208	135				
09.	Generation shortfall at evening peak due to :	:											
	a) Gas limitation	:	2742	MW									
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kapta lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2270	MW									
10.	Total Energy (Generation + India Import)	:	297.51	MKWh									
	By Gas =	140.207	MKWh	By Oil =	92.717								
	By Coal =	34.262	MKWh	By Hydro =	3.441								
	By Solar=	1.451	MKWh										
11.	Total Gas Supplied	:	1051.93	MMCFD									
(D) Forecast of 09.09.22 (Today) Friday :													
01.	Maximum Demand	:	13700	MW	(Generation end)	04.	Maximum Load-shed	:	255	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13445	MW	(Generation end)	05.	Total Generation	:	299.52	MKWh			
03.	Reserve / Shortage	:	-255	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	36.5 ° C				