

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 9-Sep-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
			Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.	
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	230	5394000		
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	260	6164018	Machine problem	
	Ghorashal 78.5 MW PP(MAX)	ORPP	2'40	0	0	0	Contract Expired	
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	91	2056409	Machine problem	
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.	
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	369	412	399	9318400	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	207	4572000	Gas shortage	
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	4781100	GT-2 S/D due to dirty gas	
9	Meghnaghat 100 MW(IE/L)	NENP	12'8.9	100	80	838080	Engine problem	
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	128	3460538	Gas shortage	
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.	
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	55	1336007		
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8'13.45	0	0	0	Contract Expired	
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	0	362052		
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.	
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage	
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	80	836160	Fuel shortage	
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	268	6219412	Gas shortage	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	75	815328	Engine problem	
20	Katpotti 52 MW PP (Sirha)	IPP	7'7.9	0	0	0	Fuel shortage	
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	637920	Fuel shortage	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	130	1129920	Engine problem	
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	915722	Engine problem	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	848655		
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0		
26	Summit Power (Madhabati+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	53	1157640	Engine problem	
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	727000		
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	8	311400	Engine problem	
29	Gazipur 52 MW PP	RPCL	6'8.9	52	40	931877	#REF!	
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.	
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	258	6290291	Engine problem	
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	101	2483703	Low demand	
33	Bramhanganjan 100 MW PP (Aggreko)	IPP	114'0.959	100	0	1111552	Reserve	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	1083955	Reserve	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	3451968		
36	Gazipur 100 MW PP	RPCL	6'17.5	105	65	1372800	Fuel shortage	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	73	966720	Fuel shortage	
38	Manikganj 162MW PP (MPGL)	IPP	9'18	162	162	1766320		
39	Spectra Solar Plant Ltd.	IPP	35	35	0	238660		
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	0	0	Fuel shortage	
Dhaka area Total				5847	3295	71581607		
41	Chattogram TPP-1	PDB	1'210	180	105	1700000	Machine problem	
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage	
43	Raozan 25 MW PP	RPCL	3'8.9	25	25	476398		
44	Teknaf 20MW PP (Solartech)	IPP	0	20	0	90720		
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	0	0	Engine problem	
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	148	2805745	Low water level	
47	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI	
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.	
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	1731272		
50	Hathazari 100 MW peaking PP	PDB	11'8.9	98	23	364835	Fuel shortage	
51	Dohazari-Kalashah 100 MW Peaking	PDB	8'17	102	51	433874	Fuel shortage	
52	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	78	898920	Engine problem	
53	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	76	1031040	Engine problem	
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	10	226128	Engine problem	
*	Malancha, Clg. EPZ (Unlited)		5'8.73+3'9.34	0	15	542880		
55	Chattogram 108 MW PP (ECVP)	IPP	16'7	108	12	218880	Engine problem	
56	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25439		
57	Anwara 300 MW PP (Unlited)	IPP	17'17+24	300	214	4940400	Fuel shortage	
58	Jodac Power	IPP	3'18.55+1'3.6	54	36	673987	Engine problem	
59	Karnaphuli Power Ltd.	IPP	18.41'5+6+5	110	105	2235598		
60	Juidah unit-2 (Acorn)	IPP	8'13.6	100	100	1062720	Engine problem	
61	Anilma Energy Ltd.	IPP	6'21.2	116	107	2358545		
Mrshara 150 MW				BPDB-RPCL	18.5'9	0	0	
Chattogram area Total				2382	1210	21871781	On test.	
61	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired	
	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired	
	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage	
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	211	4901000	#REF!	
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	0	1140600	Gas shortage	
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	305	7561000	FGMO	
	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	0	0	On test.	
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	45	1004040	Machine problem	
66	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	50	1289760		
67	Ashuganj 195MW PP (APSCL-Unlited)	IPP	20'9.73+1'16	195	110	2057454	Gas shortage	
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1182169		
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	135	3057745	Engine problem	
70	Titas 50 MW Peaking PP	PDB	6'8.92	50	35	780528	Engine problem	
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Machine problem	
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	85	931680	Fuel shortage	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	320688		
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	0	110160		
**	Importot (Tripura)	Imported power	0	160	148	2942400		
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	454200		
76	Jangalia 52 MW PP (Lakdorevi)	IPP	8'8.92	52	37	322978	Fuel shortage	
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	365640	Engine problem	
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	2073792	Reserve	
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	80	802560	Fuel shortage	
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	116	2538480		
81	Bhairab 54.5 MW	IPP	3'18.2	54	17	447840	33 kV feeder problem.	
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	115	1346880		
Cumilla Area Total				3169	1616	35631594		
83	RPCL 210MW CCPP	IPP	4'95+1'70	202	133	2354880	Gas shortage	
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	0	Gas shortage	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.	
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	15100		
87	Mymensingh 200 MW PP (Unlited)	IPP	9'78.21	200	167	2944800	Fuel shortage	
88	Jamalpur 115 MW PP (Unlited)	IPP	9'78.12	115	88	2154000	Engine problem	
89	Sutiaikhalhi 50 MW Solar PP	IPP	50	50	0	381030		
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	297360	Engine problem	
Mymensingh Area Total				614	400	8147170		
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	1022000	Machine problem	
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	41	954664	Machine problem	
93	Kushihara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage	
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.	
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	11	731400		
	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	10	738864		
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	168214	Engine problem	
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	62	1488192		
98	Shahjibazar 80MW PP (Shahjibazar)	RPP	3'22.90	86	81	1927680		
99	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.	
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	75	520960	Machine problem	
101	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage	
	Sylhet 50MW PP (EPL)	NENP	27'2	50	11	510000	Gas shortage	
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	496128		
103	Bibiana-I 341 MW CCPP (Summit)	IPP	1'222+1'119	341	290	7018000	FGMO	
104	Bibiyan-II- 400 MW CCPP	PDB	400 MW	400	401	9588000		
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	234360		
106	Bibiyan South 400 MW	PDB	400 MW	383	400	9319200		
Sylhet Area Total				2477	1451	34717662		
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0		
**	Bheramara (HVDC)	Imported power	2'500	1000	900	21792727		
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	0	0	Fuel shortage	
109	Fardpur 50 MW Peaking PP	PDB	8'6.98	54	22	190080	Engine problem	
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	219	4960320		
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	60	303488	Engine problem	
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	280	6675840	Gas shortage	
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage	
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	601920	Engine problem	
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	76	761280	Fuel shortage	
115	Madhumati 100 MW PP	NWPGCL	6'18	105	32	514656	Fuel shortage	
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	465840		
	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.	