

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Saturday				Date : 10.09.22						
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 14009 MW				Rule Curve = 101.07 ft						
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.02 ft				Today = 96.00 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.09.22 (Yesterday)		10.09.22 (Today)		09.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	10.09.22 (Yesterday) Probable Peak Generation (MW)	10.09.22 (Today) Probable Peak Generation (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)							
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	260	260	260					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	87	91	85	85	17		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	210	207	200	200	153		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	210	225	225	225	225		Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	399	380	380					
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	256	268	250	250	67		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	148	128	130	130	207		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	0	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	75	50	75					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	0	22	22					
17	Summit Power,(Madhabdi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x8.73	80	80	51	53	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	11	8	15	20					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	31	40	40	40					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	66	65	65	65					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	30	130	16	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	258	275	275					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	225	101	150	225					
27	Branganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	0	80	90					
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	0	80	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	73	17	74					
32	Manikganj 162MW PP(MPCL)	HFO (IPP)	9x18	162	162	72	162	72	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0	55		Fuel Oil Shortage		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	23	80	24	80					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	24	80	24	82					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total				6004	5847	3203	3295	3039	3622	934	670			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	138	148	150	150			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	105	105	105					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	0	38					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	105	70	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI Ongoing		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	214	214	214	214	86		Fuel Oil Shortage		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	32	76	33	90					
49	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	8x17.0	102	102	15	51	11	51	51		Fuel Oil Shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	23	24	24					
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			40	15	12	30					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	12	5	11	96		Fuel Oil Shortage		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	100	38	100					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	78	33	78					
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107					
Chattogram Zone Total				2442	2382	963	1210	1003	1279	233	555			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	43	45	45	45					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	205	211	205	206					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	305	305	320	320					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	55	50	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	102	110	120	120	85		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	122	135	135	135					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	35	35	35					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	85	17	85					
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	22	22	15	22					
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	10	0	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	11	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	37	8	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.588	200	200	167	0	150	190					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	80	17	17	34		Fuel Oil Shortage		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	103	116	105	113					
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115					
**	Impoport (Tripura)	India		160	160	108	148	143	166					
Cumilla Zone Total				3193	3169	1447	1616	1537	1799	119	0			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	69	133	80	100	69		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage		
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	88	115	115					
84	Myensingh 200 MW PP (United)													

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.09.22 (Yesterday)		10.09.22 (Today)		09.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	11	0	11				
91	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	62	62	62				
94	Shajibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	75	150	220		156	Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shehjanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	16	24	24				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	310	320				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	401	401	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	27	11	21	21	39		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	30	10	0	10				
Sylhet Zone Total				2522	2477	1455	1451	1550	1651	59	825		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	260	280	280	280	130		Gas Shortage	
108	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	22	0	50				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	68				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	194	219	225	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	30	0	90	90				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	76	35	70				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	32	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	87	0	100	0				
115	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	0	0	0	115		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	902	900	918	918				
Khulna Zone Total				2388	2384	1505	1589	1663	1751	285	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	32	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	32	22	31				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	63	86	85	85	108		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	900	1080	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	216	220	220				
Barisal Zone Total				1958	1958	1207	1446	1469	1511	108	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	31	0	24		18	Turbocarger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	60	164				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	81				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	24		Fuel Oil Shortage	
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		24	Under maint.	
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	198	195	190	190				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	210	214	220	220	220		Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	153	177	190	190				
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	401	417	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	6	18	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
138	Bagura 11.3 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	55	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2129	2129	1073	1388	1238	1567	459	60		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	85	81	83				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	92	55	92				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgonj 115MW PP (Energyrac)	HFO (IPP)	6*20	115	115	34	90	0	90				
	Intraco Solar 30 MW	Solar (IPP)				15	0	12	0				
Rangpur Zone Total				800	720	437	517	406	515	0	85		
Sub-total: Plants in operation				22058	21680	11629.0	12912	12251	14009	2288	2195		
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		85	Under Overhauling	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
152	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
153	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22482	21680	11629	12912	12251	14009	2288	2195		
(C) Actual data of 09.09.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	13141	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12602	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13278	MW, at =	23:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	10481	MW, at =	8:00 hrs	Dhaka	4558	4558	0	Mymensingh	1034	823	211
05.	Day-peak Generation (Generation end)	:	11629	MW, at =	12:00 hrs	Chattogram	1188	1188	0	Sylhet	407	407	0
06.	Evening-peak Generation (Generation end)	:	12912	MW, at =	21:00 hrs	Khulna	1596	1596	0	Barisal	421	421	0
07.	Evening Peak Load-shed (Sub-station end)	:	211	MW, at =	21:00 hrs	Rajshahi	1359	1359	0	Rangpur	876	876	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10634	MW, at =	5:00 hrs	Cumilla	1163	1163	0				
09.	Generation shortfall at evening peak due to :	:								Total	12602	12391	211
a)	Gas limitation	:	2288	MW		13.	Fuel cost :	(a) Gas = 157136887 Taka	(c) Coal = 280235404 Taka				
d)	Coal supply Limitation	:	0	MW				(b) Oil = 1186070985 Taka	Total = 1623443277 Taka				
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2195	MW									
10.	Total Energy (Generation + India Import)	:	282.93	MKWh		14.	Maximum Temperature in Dhaka was :	36.6° C					
	By Gas = 137.760 MKWh			By Oil = 82.045 MKWh		15.	Export through East-West interconnections :						
	By Coal = 34.296 MKWh			By Hydro = 2.806 MKWh			At evening peak-hour	11629	MW, at	21:00 hrs			
	By Solar= 1.291 MKWh						Maximum	1030	MW, at	18:30 hrs			
							Energy	0	MK				