

21:00 Hrs on 16-Apr-22

Today's Actual Min Gen. & Probable Gen. & Demand

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Cost of the Consumed Fuel (PDE	Gas :	Tk160,569,244			
:	Coal :	Tk267,293,523	Oil :	Tk1,219,098,679	Total : Tk1,646,961,446

Area	Yesterday		Estimated Demand (S/S end)	Today		Rates of Shedding (On Estimated Demand)
	MW			Estimated Shedding (S/S end)	MW	
Dhaka	76	0:00	4547	0	0	0%
Chittagong Area	0	0:00	1288	0	0	0%
Khulna Area	0	0:00	1700	0	0	0%
Rajshahi Area	0	0:00	1508	0	0	0%
Cumilla Area	0	0:00	1284	0	0	0%
Mymensingh Ar	145	0:00	1061	0	0	0%
Sylhet Area	0	0:00	474	0	0	0%
Barisal Area	0	0:00	387	0	0	0%
Rangpur Area	0	0:00	838	0	0	0%
Total	221		13086	0		

Planned Shut- Down

- 1) Barapukuria ST: Unit-2
- 2) Ghorasal-3,
- 3) Ashuganj-5
- 4) Baghabari-71,100 MW
- 5) Raozan unit-2
- 6) Siddhirganj 210 MW .
- 7) Sikalbaha 225 MW
- 8) Shajibazar 330 MW

- a) Ashuganj-Sirajganj 230 kV Ckt-2 was under shut down from 09:01 to 12:32 for R/H maintenance.
- b) Madunaghat 132/33 kV T-1 transformer was under shut down from 08:54 to 11:06 due to 33 kV CB change.
- c) Ullon-Siddhirganj 132 kV Ckt-1 and Ullon-Dhamondhi 132 kV cable-3 was shut down at 09:11 for equipment testing at Ullon and was switched on at 14:00.
- d) Keraniganj 132/33 kV T-1 transformer was shut down at 09:47 for D/W.
- e) Bogura-Sirajganj 230 kV Ckt was under shut down from 08:40 to 10:22 for R/H maintenance.
- f) Bakulia-Skalabaha 132 kV Ckt-1 was under shut down from 11:06 to 13:50 for protection test.
- g) Cumilla(N) 132/33 kV T-4 transformer was under shut down from 10:52 to 14:08 for R/H maintenance.
- h) Saidpur 132/33 kV T-1 transformer was under shut down from 11:02 to 13:25 for R/H maintenance.
- i) Payra 400/132 kV T-02 transformer was shutdown at 09:41 for C/M by PGCB.
- j) Payra 132 kV Bus-2 was shutdown at 10:00 for C/M at S/S end.
- k) Netrokona 132/33 kV T-3 transformer was under shut down from 20:57 to 21:39 for R/H maintenance by PBS.
- l) Shariatpur 132/33 kV T-2 transformer was under shut down from 15:36 to 17:00 for R/H maintenance by PBS.
- m) Halishahar 132/33 kV T-3 transformer along with 33 kV Bus were under shut down from 16:39 to 17:23 for C/M by PDB.
- n) Rampal 400 kV 80 MVA reactor was switched on at 18:19.
- o) Shajadpur-Sirajganj 132 kV Ckt was opened at 23:54 from Shajadpur end.
- p) Chuadanga 132/33 kV T-1 transformer along with 33 kV Bus were shut down at 07:10(11/09/2022) for R/H maintenance by PBS.
- q) Tangail-Kaliakoir 132 kV Ckt-1 was closed at 17:28.
- r) Hasnabad 33 kV reserve Bus was under shut down from 16:32 to 17:49 for C/M by PBS.
- s) Madunaghat 132/33 kV T-1 transformer tripped at 03:11(11/09/2022) due to 33 kV Noapara feeder CT burst.

About 40 MW power interruption has been occurring under Madunaghat S/S area since 03:11(11/09/2022).

Superintendent Engineer
Load Despatch Circle