

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW			
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1'210	180	210	497000	
3	Ghorasal TPP Unit-1	PDB	1'210	190	0	0	Under maint.
3	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	240	6157955	Machine problem
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2'40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	74	1917364	Machine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	347	8489860	Gas shortage
7	Haripur 360 MW CAPP(HPL)	IPP	1'235+1'125	360	153	3788000	Gas shortage
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	190	4534000	GT-2 S/D due to dirty gas
9	Meghnaghat 100 MW(IEL)	NENP	1'2'8	100	57	464640	Engine problem
10	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	335	110	2796800	Gas shortage
11	Madanganj 102 PPI(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj 55 MW PPI(Summit)	IPP	3'17.08+1'111.3	55	55	1276750	
13	Keraniganj 100 MW PP (Powerpac)	GRPP	8'13.45	0	0	0	Contract Expired
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	9'2.90	22	22	433268	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'20 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PPI(Dutch Bangla)	NENP	12'8.9	100	64	494909	Fuel shortage
18	Siddhirgonj 335 MW CAPP	EGCB	1'217+1'118	335	236	5628730	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	65	450720	Engine problem
20	Katpali 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Karnalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	35	568800	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	128	1032480	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	909038	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	885326	
25	Bosila 108MW PPI(CLO)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi-Ashulia)	SIPP, REB	33.67+4'8.73	80	42	1105440	Engine problem
27	Maona 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	33	789480	
28	Rupganj 33 MW PPI(Summit)	SIPP, REB	4'8.73	33	6	163100	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	50	974880	#REF!
30	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	258	6089561	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	26'11.4	300	150	2837165	Engine problem
33	Bramhaniganj 100 MW PP (Aggreko)	IPP	114'0.959	100	70	1546817	Engine problem
34	Aurahat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	90	1522616	Engine problem
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	149	3570192	
36	Gazipur 100 MW PP	RPCL	6'17.5	105	84	1398000	Fuel shortage
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	55	668160	Fuel shortage
38	Manikganj 162MW PPI(MPL)	IPP	9'18	162	162	1759680	
39	Spectra Solar Plant Ltd	IPP	35	35	0	193286	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	0	0	Fuel shortage
Dhaka area Total			5847	3245	67381497		
41	Chattogram TPP-1	PDB	1'210	180	100	2400000	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Raozan 20 MW PP	RPCL	3'8.9	25	25	498585	
44	Teknaf 20MW PP (Solartech)	IPP	20	20	0	71415	
44	Patenga 50MW PP (Baraka)	IPP	9'8.98	50	38	537120	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	148	3565638	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	0	0	HGPI
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	1809990	
49	Hathazari 100 MW peaking PP	IPP	11'8.9	98	24	502080	Fuel shortage
50	Dhazari-Kalshah 100 MW Peaking	PDB	8'17	102	51	162038	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	85	991080	Engine problem
52	Juidah 100 MW Unit-3 (Acorn)	IPP	8'13.5	100	90	1092480	Engine problem
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	13	308496	Engine problem
*	Malancha, Ctg. EPZ (United)	IPP	5'8.73+3'9.34	0	5	384480	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	5	131520	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	2511	
56	Arwara 300 MW PP (United)	IPP	17'1+24	300	214	5151164	Fuel shortage
57	Jidac Power	IPP	3'18.55+1'3.6	54	36	791375	Engine problem
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	105	2565962	
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	100	1195200	
60	Anilma Energy Ltd.	IPP	6'21.2	116	107	2583109	Engine problem
	Mirshara 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
Chattogram area Total			2382	1251	24786793		
61	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit-4	APSCL	1'150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CAPP	APSCL	1'142+1'175	221	197	4803000	#REF!
63	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	130	2495900	Gas shortage
64	Ashuganj 450 MW CAPP(South)	APSCL	1'360	360	280	7478000	FGMO
65	Ashuganj 420 MW CAPP(East)	APSCL	284'1.36'1	0	284	0	On test.
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	46	1036512	
66	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	54	1324320	
67	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'116	195	8	1973818	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1223413	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	130	2836945	Engine problem
70	Titas 50 MW Peaking PP	PDB	6'8.92	50	39	637162	Engine problem
71	Chandpur 150 MW CAPP	PDB	11'08+1'157	163	83	1900050	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	70	792960	Fuel shortage
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	464328	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	234540	
**	Imported (Tripura)	Imported power	0	160	156	3247680	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	30	615700	
76	Jangalia 50 MW Peaking PP (Lakshmi)	IPP	6'8.92	52	43	357883	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	479210	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	115	2659392	Low demand
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	52	564300	Fuel shortage
80	Chowmahani 113 MW	IPP	12'9.78+2'3.1	113	116	2559480	
81	Bharosh 54.5 MW	IPP	3'18.2	54	17	443680	33 KV feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	115	1344980	
Cumilla Area Total			3169	1773	38533423		
83	RPCL 210MW CAPP	IPP	4'35+1'70	202	103	1951680	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	0	Gas shortage
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	13000	
87	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	107	2629000	Fuel shortage
88	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	98	2241600	Engine problem
89	Sutakhal 50 MW Solar PP	IPP	50	50	0	263940	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	294240	Engine problem
Mymensingh Area Total			614	320	7392460		
91	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	43	1023000	Machine problem
92	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	41	965344	Machine problem
93	Kushnara 163 MW CAPP (KP)	IPP	1'109+1'154	163	0	0	Gas shortage
94	Shajibazar 330 MW CAPP	PDB	3'110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	0	0	Gas shortage
	Fenchugonj 44MW (Energysigma)	NENP	12'3.3+5'2	50	0	0	Gas shortage
96	Hobiganj 11 MW PP Confidence-E	SIPP, REB	4'2.90	11	0	0	Gas shortage
97	Shajibazar GTPP Unit-8 & 9	PDB	2'35	66	61	1419936	
98	Shajibazar 98MW PP (Shajibazar)	RPP	32'2.90	86	80	1398720	
99	Shajibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CAPP	PDB	1'142+1'189	231	220	4971620	
101	Sylhet 20 MW GTPP	PDB	1'20	20	18	429000	
102	Sylhet 50MW PP (EPL)	NENP	27'2	50	0	0	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	0	0	Gas shortage
103	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	290	7146500	FGMO
104	Bibiana-III 400 MW CAPP	PDB	400	400	401	953000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	234720	
106	Bibiana South 400 MW	PDB	400 MW	383	400	9451500	
Sylhet Area Total			2477	1564	36578340		
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	
**	Bheramara (HVDC)	Imported power	2'500	1000	889	21583272	
108	Khuila 115 PP MW (KPCL-2)	NENP	7'17	115	0	0	Fuel shortage
109	Fardpur 50 MW Peaking PP	PDB	9'8.99	54	38	180480	Engine problem
110	Khuila 225 MW CAPP	NWPGCL	1'150+1'175	230	228	4333440	
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	60	356480	Engine problem
112	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	250	6388416	Gas shortage
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	403200	Line O/L
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	58	613440	Fuel shortage
115	Madhumati 100 MW PP	NWPGCL	6'18	105	50	631728	Fuel shortage
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	284400	
	Khuila 330 MW CAPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.
	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
Khuila Area Total			2384	1571	34774856		
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	32	366816	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	24	481743	Engine problem
119	Bhola 225 MW CAPP	PDB	2'63+1'169	194	86	2085399	Gas shortage