

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel - 9564667, 9551095

Month September, 2022					Day : Wednesday				Date : 14.09.22						
Probable Maximum Demand : 12500 MW					Probable Maximum Generation : 14186 MW										
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.21 ft				Today = 96.32 ft				Rule Curve = 101.99 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.09.22 (Yesterday)		14.09.22 (Today)		13.09.22 (Yesterday)		13.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation	Machines shut down	Description/ Remarks				
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	220	200	220						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	290	262	270	270						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	80	76	50	76	32		Gas Shortage			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	193	212	170	212	148		Gas Shortage			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	175	175	175	175	275		Gas Shortage			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	379	371	335	370						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	253	250	225	250	85		Gas Shortage			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	126	125	100	125	210		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	50	8	65						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22						
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x7.3	80	80	41	47	50	50						
18	Maons 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	7	6	8	8						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	49	25	50						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	86	105	85	105						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	105	16	105						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	145	253	260	260						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	50	144	149	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	150	225						
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	80	90						
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	80	90						
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	17	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	75	17	55						
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162						
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	1	0	30	0						
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	55	0	55						
35	Siddhirganj 100 MW PP(Dutch Bangle)	HFO (NENP)	12x8.9	100	100	7	48	8	60						
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	8	55	8	55						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0						
Dhaka Zone Total				6004	5847	2266	3100	2750	3556	960	670				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	148	149	146	149			Unit 1 under rehabilitation			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110						
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	2	0	5	0	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	32	25	32						
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	80	70	105						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	HGPI Ongoing			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	155	269	214	280						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	90	33	90						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51	51		Fuel Oil Shortage			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	17	0	17						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	13	15						
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			11	18	10	18						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	2	0	6	106		Fuel Oil Shortage			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36						
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	105	105	105						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	64	38	90						
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	66	33	66						
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107						
Chattogram Zone Total				2442	2382	788	1236	990	1302	157	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0						
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	45	45	45						
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*175	221	221	177	181	172	181						
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	335	265	260	300						
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	360	300	300	300						
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	56	55	55						
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	80	135	135	135						
68	Titias 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35						
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	80	80	80						
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	60	17	60						
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19	19						
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10						
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	24	33	33						
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	23	8	35						
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	21	21	21						
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.036	200	200	0	0	150	190						
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	17	114						
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	108	113	97	113						
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	108	35	115						
**	Impoport (Tripura)	India		160	160	100	124	143	165						
Cumilla Zone Total				3193	3169	1498	1754	1673	2082	187	0				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	44	74	70	80	128		Gas Shortage			
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	99	100	100						
84	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	45	150	87	150						
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0						
86	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	1	0	50	0						
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12						
Myensingh Zone Total				622	614	177	335	321	342	150	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.09.22 (Yesterday)		14.09.22 (Today)		13.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation			
						Day	Evening	Day	Evening	MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	5	5				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	28	30	30	30				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	81	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	219	220	220				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	19	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	8	8				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	255	280	280				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	374	400	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	386	380	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	6	6	50		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	5	5	50		Gas Shortage	
Sylhet Zone Total				2522	2477	1446	1477	1547	1547	100	669		
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	230	300	230	300	110		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	68				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	120	120	130	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	90	90				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	2	53	35	70				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	6	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	0	115		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
**	Bheramara (HSDC)	India		1000	1000	903	903	920	920				
Khulna Zone Total				2388	2384	1276	1426	1520	1773	265	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	5	16	16	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	18	20	20				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	56	65	65	138		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	650	710	1110	1110				
121	Potua khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	171	174	220	220				
Barishal Zone Total				1958	1958	903	974	1431	1480	138	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	60	164				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	82				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	9	8	0		41	Under maint.	
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	42	42				
130	Santalhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33		17	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	160	150	170	180				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	190	110	220	220	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	150	180	180				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	368	258	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	18	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	35	8	40				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	50	55	90				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	86	50	86				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total				2129	2129	903	1066	1246	1596	391	76		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	78	78	78				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	249	250	250	250				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	60	55	90				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgonj 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	34	34	0	90				
148	Lalmohanhat 30 MW Solar (Intenco)	Solar (IPP)	1*30	30	30	17	0	12	0				
Rangpur Zone Total				830	750	384	422	403	508	0	85		
Sub-Total: Plants in operation				22088	21710	9641.0	11790	11881	14186	2348	2055		
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22512	21710	9641	11790	11881	14186	2348	2055		
(C) Actual data of 13.09.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	11790 MW, at = 19:00 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11494 MW, at = 19:00 hrs			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11790 MW, at = 19:00 hrs			Dhaka	4352	4352	0	Mymensingh	937	937	0
04.	Minimum Generation (Generation end)	:	9163 MW, at = 8:00 hrs			Chattogram	1311	1311	0	Sylhet	483	483	0
05.	Day-peak Generation (Generation end)	:	9641 MW, at = 12:00 hrs			Khulna	1303	1303	0	Barishal	269	269	0
06.	Evening-peak Generation (Generation end)	:	11790 MW, at = 19:00 hrs			Rajshahi	1095	1095	0	Rangpur	734	734	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at = 19:00 hrs			Cumilla	1010	1010	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8905 MW, at = 5:00 hrs							Total	11494	11494	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 156654300 Taka	(c) Coal = 217989482 Taka				
	a) Gas limitation	:	2348 MW					(b) Oil = 767778158 Taka	Total = 1142421940 Taka				
	d) Coal supply Limitation	:	0 MW										
	b) Low water level in Kaptai lake	:	0 MW										
	c) Plants under shut down/ maintenance	:	2055 MW			14.	Maximum Temperature in Dhaka was :	26.5° C					
10.	Total Energy (Generation + India Import)	:	251.09 MKWh			15.	Export through East-West interconnections :						
	By Gas = 138.960 MKWH		By Oil = 56.467 MKWh				At evening peak-hour	:	9641 MW, at 19:00 hrs				
	By Coal = 27.380 MKWH		By Hydro = 3.512 MKWh				Maximum	:	1030 MW, at 19:00 hrs				
	By Solar= 0.424 MKWH						Energy	:	0 MKWh				
11.	Total Gas Supplied	:	1046.46 MMCFD										
(D) Forecast of 14.09.22 (Today) Wednesday :													
01.	Maximum Demand	:	12500 MW (Generation end)			04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	14186 MW (Generation end)			05.	Total Generation	:	266.21 MKWh				
03.	Reserve / Shortage	:	1686 MW (Generation end)			06.	Probable Max. Temperature in Dhaka :	:	31.9° C				

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation