

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022					Day : Thursday					Date : 15.09.22				
Probable Maximum Demand : 12600 MW					Probable Maximum Generation : 14440 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.32 ft			Today = 96.43 ft			Rule Curve = 101.99 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.09.22 (Yesterday)		15.09.22 (Today)		14.09.22 (Yesterday)		15.09.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	196	200	220					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	260	300	300					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	77	75	50	76	33		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	199	180	170	212	180		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	180	180	180	270		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	385	368	340	380					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	260	245	225	250	90		Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	130	120	100	125	215		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	65	8	65					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22					
17	Summit Power,(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	48	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	7	6	8	8					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	49	25	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	86	105	85	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	83	16	32					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	215	265	260	260					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	101	129	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	150	225					
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	80	90					
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	80	90					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	75	17	55					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	9	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	37	0	55					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	47	8	60					
36	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	7	37	8	40					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	2534	2991	2828	3513	998	670				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	149	146	146	149			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	110					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0					
41	Raccon 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	7	18	25	32					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	36	86	70	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI Ongoing		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	215	283	214	280					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	90	33	90					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	23	0	17					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	13	15					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			13	20	15	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	6	108		Fuel Oil Shortage		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	41	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	90	38	90					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	72	33	72					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	106	89	107	107					
Chattogram Zone Total			2442	2382	914	1264	1012	1310	108	555				
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	41	42	45	45					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	155	177	191	191					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	280	260	300					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	285	290	360	360					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			On test		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	56	55	55					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	100	147	100	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	84	82	83	83					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	72	100	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19	19					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	8	35					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.519+15x1.086	200	200	0	0	150	190					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	17	17	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	101	117	97	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.518+2x25.428	115	115	35	93	35	115					
**	Import (Tirupura)	India		160	160	118	128	143	165					
Cumilla Zone Total			3193	3169	1438	1668	1803	2310	187	0				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	42	72	70	80	130		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage		
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	86	98	100	100					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	152	154	80	154					
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0					
87	Tangail 22 MW PP(PGL)	HFO (IPP)	4x6.7	22	22	1	12	12	12					
Mymensingh Zone Total			622	614	321	336	314	346	152	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.09.22 (Yesterday)		15.09.22 (Today)		14.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Machines shut down (MW)	Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	MW							
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.					
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5								
91	Kushlara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0								
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	33	34	30	30								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	25	81	30	81								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220								
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	19	19	19								
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	4	8	8	21		Gas Shortage					
100	Bibiara-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	300	300								
101	Bibiara-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	400	400	400								
102	Bibiara South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	367	400	400								
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	6	6	6	6	44		Gas Shortage					
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5	45		Gas Shortage					
Sylhet Zone Total						2522	2477	1508	1517	1568	110	669					
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	285	280	300	125		Gas Shortage					
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50								
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	68								
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	120	130	225								
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	90	90								
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	33	17	70								
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	67								
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0								
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	25	16	49	90		Fuel Oil Shortage					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage					
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0								
**	Bheramara (HVDC)	India		1000	1000	903	903	915	915								
Khulna Zone Total						2388	2384	1334	1433	1563	1834	255	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	48								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	23	20	20								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	51	65	65	143		Gas Shortage					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	630	830	1110	1110								
121	Potua Khali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17			Line Overload					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220								
Barishal Zone Total						1958	1958	948	1140	1431	1480	143	0				
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32		18	Turbocharger problem					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	160								
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0								
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	82								
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	16	32		50	Under maint.					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	0	42	42								
130	Sanlahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	33		50	Under maint.					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	177	194	198	198								
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	130	130	130	220		Running on HSD					
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	172	170	180	180								
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	360	426	414	414								
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22								
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11								
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	8	43								
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	50	55	95								
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	100	50	100								
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0								
Raishahi Zone Total						2129	2129	876	1224	1132	1574	391	118				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	75								
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250								
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	70	55	90								
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Majpara, Talaria 8 MW Solar PP (Sypma Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0								
147	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)	6*20	115	115	0	34	0	90								
148	Jainmunsahi 30 MW Solar (Intracon)	Solar (IPP)	1*30	30	30	8	0	12	0								
Rangpur Zone Total						830	750	260	354	325	505	0	85				
Sub-total: Plants in operation						22088	21710	10133.0	11915	11925	14440	2344	2097				
(B) Plants under long term maintenance/ contract expired																	
149	Jamalganj 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
150	Kalipoliti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020					
154	Amritnagar 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022					
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0						
Gross Total						22512	21710	10133	11915	11925	14440	2344	2097				
(C) Actual data of 14.09.22 (Yesterday) Wednesday :																	
01.	Max. Demand at eve. peak (Generation end)	:	11975	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):											
02.	Max. Demand at eve. peak (Sub-station end)	:	11588	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	11915	MW, at =	19:00 hrs		MW	MW	MW		MW	MW	MW				
04.	Minimum Generation (Generation end)	:	8905	MW, at =	7:00 hrs	Dhaka	4285	4265	20	Mymensingh	999	964	35				
05.	Day-peak Generation (Generation end)	:	10133	MW, at =	12:00 hrs	Chattogram	1209	1209	0	Sylhet	482	482	0				
06.	Evening-peak Generation (Generation end)	:	11915	MW, at =	19:00 hrs	Khulna	1363	1363	0	Barishal	305	305	0				
07.	Evening Peak Load-shed (Sub-station end)	:	55	MW, at =	19:00 hrs	Rajshahi	1179	1179	0	Rangpur	726	726	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8864	MW, at =	5:00 hrs	Cumilla	1040	1040	0								
09.	Generation shortfall at evening peak due to :	:								Total	11588	11533	55				
	a) Gas limitation	:	2344	MW													
	d) Coal supply Limitation	:	0	MW													
	b) Low water level in Kaptai lake	:	0	MW													
	c) Plants under shut down/ maintenance	:	2097	MW													
10.	Total Energy (Generation + India Import)	:	248.98	MKWh		14. Maximum Temperature in Dhaka was : 27.4 °C											
	By Gas = 141.166 MKWh			By Oil = 52.746 MKWh		15. Export through East-West interconnections :											
	By Coal = 26.437 MKWh			By Hydro = 3.508 MKWh		At evening peak-hour : 10133 MW, at 19:00 hrs											
	By Solar= 0.597 MKWh					Maximum : 970 MW, at 13:00 hrs											
11.	Total Gas Supplied	:	1052.60	MMCFD		Energy : 0 MKWh											
(D) Forecast of 15.09.22 (Today) Thursday :																	
01.	Maximum Demand	:	12600	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	14440	MW (Generation end)		05.	Total Generation	:	263.30	MKWh							
03.	Reserve / Shortage	:	1840	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.4 ° C								