

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Monday				Date : 19.09.22					
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 13908 MW				Rule Curve = 102.91 ft					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.70 ft				Today = 96.72 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.09.22 (Yesterday)		19.09.22 (Today)		18.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation				
					Day	Evening	Day	Evening	MW	(MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	215	220	220				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	280	0	0				
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	32	11	91	100	97	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	276	172	170	170	188	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	185	190	190	265	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	358	330	330	54	Gas Shortage		
11	Siddhirganj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	130	125	130	130	210	Gas Shortage		
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	92	40	92				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x3.73	80	80	50	49	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	14	14	24	24				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	49	49				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	111	16	115				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	273	275	275	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	135	149	149	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	155	225	150	225				
27	Branghangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	75	90				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	75	90				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	91	50	90				
32	Manikganj 162MW PP(MPCL)	HFO (IPP)	9x18	162	162	72	162	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	15	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	55	0	55				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	46	95	45	90				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	42	89	42	85				
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2927	3338	2572	3157	1024	1005		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	150	150	151	151		Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	110	110	110				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	35	38	38	45				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI Ongoing		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	248	292	250	300				
48	Jaldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	90	33	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	8x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	22	22	22				
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	17	17	17	17				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	24	5	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel Oil Shortage		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	32	36	36	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	105	68	105				
55	Jaldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	100	38	100				
56	Jaldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	80	33	80				
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	107	107	107				
Chattogram Zone Total				2442	2382	939	1352	1080	1364	108	555		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	43	41	40	40				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	162	183	180	185				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	250	250	250	300	110	Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	280	300	320	80	Gas Shortage		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0	284	Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	30	20	30				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	138	142	138	143				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	27	29	29				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	82	83	83				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	173	200	120	200				
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	19	19	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	16	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Daudkandi 200 MW PP (B.Tec)	HSD (IPP)	88x1.4+40x1.515+15x1.588	200	200	181	120	150	190				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	34	17	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	96	115	97	113				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	100	35	115				
**	Impoport (Tripura)	India		160	160	136	158	143	165				
Cumilla Zone Total				3193	3169	1834	1929	1769	2229	661	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	41	100	70	100	102	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	14	14	14	8	Gas Shortage		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	71	93	97	105				
84	Mymsensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	163	162	150	162				
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymsensing Zone Total				622	614	314	381	395	393	110	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.09.22 (Yesterday)		19.09.22 (Today)		18.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : r Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	41	41	41		49	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	63	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	78	40	78				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	213	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	300	300				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	397	403	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	393	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2522	2477	1460	1557	1532	1570	179	669
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	225	220	230	230	190		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	0	38				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	45	0	50				
110	Khuina 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	145	140	150	225				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	97	50	97				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	30	55	17	56				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	100	0				
115	Khuina 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	32	16	32	83		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
**	Bheramara (HVDCL)	India		1000	1000	893	893	902	902				
Khuina Zone Total						2388	2384	1399	1562	1480	1680	313	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	28	18	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	85	85	85	109		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1050	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	222	220	220				
Barishal Zone Total						1958	1958	1204	1417	1466	1489	109	0
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32	18		Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	1	168	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	81				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32	18		Under maint.	
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26	24		Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	185	181	180	180				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	206	219	180	220	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	157	156	150	150	64		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	339	322	350	350	92		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	95	95	70	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total						2129	2129	1136	1463	1206	1532	591	60
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	77	75	76				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	78	70	78				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majura, Tatabia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	90	94	70	90				
148	Lalmohanthal 30 MW Solar (Itraco)	Solar (IPP)	1*30	30	30	26	0	12	0				
Rangpur Zone Total						830	750	519	499	485	494	0	85
Sub-total: Plants in operation						22088	21710	11732.0	13498	11985	13908	3095	2374
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpali 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0				
Gross Total						22512	21710	11732	13498	11985	13908	3095	2374
(C) Actual data of 18.09.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	13960	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13399	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13498	MW, at =	20:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	10466	MW, at =	7:00 hrs	Dhaka	4795	4795	0	Mymensingh	1110	934	176
05.	Day-peak Generation (Generation end)	:	11732	MW, at =	12:00 hrs	Chattogram	1298	1298	0	Sylhet	591	581	10
06.	Evening-peak Generation (Generation end)	:	13498	MW, at =	20:00 hrs	Khuina	1568	1512	56	Barishal	371	371	0
07.	Evening Peak Load-shed (Sub-station end)	:	426	MW, at =	20:00 hrs	Rajshahi	1415	1310	105	Rangpur	954	900	54
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10447	MW, at =	5:00 hrs	Cumilla	1297	1272	25				
09.	Generation shortfall at evening peak due to :	:				Total 13399 12973 426							
a)	Gas limitation	:	3095	MW		13. Fuel cost : (a) Gas = 150703441 Taka (c) Coal = 263334292 Taka							
d)	Coal supply Limitation	:	0	MW		(b) Oil = 1366205647 Taka Total = 1780243379 Taka							
b)	Low water level in Kapta lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2374	MW		14. Maximum Temperature in Dhaka was : 32.0° C							
10.	Total Energy (Generation + India Import)	:	290.20	MKWh		15. Export through East-West interconnections :							
	By Gas = 133.825 MKWh			By Oil = 94.675 MKWh		At evening peak-hour : 11732 MW, at 20:00 hrs							
	By Coal = 32.390 MKWh			By Hydro = 3.557 MKWh		Maximum : 750 MW, at 24:00							
	By Solar= 0.969 MKWh					Energy : 0 MKWh							
11.	Total Gas Supplied	:	991.27	MMCFD									
(D) Forecast of 19.09.22 (Today) Monday :													
01.	Maximum Demand	:	14000	MW (Generation end)		04.	Maximum Load-shed	:	85	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13908	MW (Generation end)		05.	Total Generation	:	300.99	MKWh			
03.	Reserve / Shortage	:	-92	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	32.3 ° C				