

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Thursday				Date : 22.09.22				
Probable Maximum Demand : 14200 MW				Probable Maximum Generation : 14218 MW				Rule Curve = 103.84 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.98 ft				Today = 96.96 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.09.22 (Yesterday)		22.09.22 (Today)		21.09.22 (Yesterday)		22.09.22 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	200	230	230			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	180	180	180	10	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	42	41	41	41			
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	248	213	250	250	147	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	190	225	225	260	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	356	390	400			
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	135	142	145	145	193	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	84	40	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22			
17	Summit Power,Madhabadi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	51	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	13	12	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	32	49			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	85	16	100			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	258	275	275	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	119	124	149	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	221	225	200	225			
27	Brannhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	75	90			
28	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	50	75	90			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	73	55	94			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	55	0	55			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	46	87	45	90			
36	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	24	82	40	80			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total					6004	5847	2786	3177	2938	3475	1145	855
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	152	151	151		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	47	40	47			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	102	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	154	150	150			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	250	286	282	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	90	33	90			
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	26	31	20	30			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			8	30	11	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel Oil Shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	100	38	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	78	33	80			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
Chattogram Zone Total					2442	2382	1135	1412	1193	1422	288	330
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	43	40	44			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	177	204	210	221			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	290	310	350	360	50	Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	200	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	13	13	13	271	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	10	55	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20x9.73+1x16	195	195	45	26	55	80	169	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	145	135	145			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	27	36	36	36			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	82	83	83			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	178	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+69x1.05+15x1.08	200	200	180	188	150	190			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	17	17	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12x9.78+2x3.1	113	113	85	105	97	105			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115			
**	Import (Tirupura)	India		160	160	152	158	143	166			
Cumilla Zone Total					3193	3169	1779	1856	1781	1992	850	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	40	101	70	100	101	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	14	14	8	Gas Shortage	
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	86	88	97	100			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	161	160	150	180			
85	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
87	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	12	6	12	12			
Mymensingh Zone Total					622	614	360	369	395	406	109	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.09.22 (Yesterday)		22.09.22 (Today)		21.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	42	42		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5	46		Gas Shortage	
91	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	61	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	78	15	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	330	285	290	330				
101	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	403	400	400				
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	395	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	5	5	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	5	5	5	5	45		Gas Shortage	
Sylhet Zone Total						1505	1535	1495	1601	177	680		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	225	220	235	235	190		Gas Shortage	
108	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	49				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	55				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	224	150	210				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	95	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	74	93	75	93				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	15	67				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	40	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	28	16	24	87		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				100	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	906	900	922	922				
Khulna Zone Total						2388	2384	1496	1670	1563	1750	317	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	27	16	27				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	84	87	84	87	107		Gas Shortage	
120	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	690	1040	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	17			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	224	220	220				
Barishal Zone Total						1958	1958	1032	1410	1463	1493	107	0
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	173	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	80	0	81				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	16	32		26	Under maint.	
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		24	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	189	176	192	192				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	130	216	150	210	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	163	155	165	165	65		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	336	335	352	352	79		Gas Shortage	
135	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	60	113	50	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	113	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total						2129	2129	1064	1510	1219	1561	579	68
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	249	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	70	78	50	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	75	34	75				
148	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	29	0	12	0				
Rangpur Zone Total						830	750	472	482	434	518	0	85
Sub-total: Plants in operation						22088	21710	11629.0	13421	12481	14218	3572	2018
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpolti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/1/2020	
154	Amfura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	11629	13421	12481	14218	3572	2018
(C) Actual data of 21.09.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13832	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13349	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13430	MW, at =	22:00 hrs	Dhaka	4762	4662	100	Mymensingh	1119	948	171
04.	Minimum Generation (Generation end)	:	10377	MW, at =	8:00 hrs	Chattogram	1338	1338	0	Sylhet	551	531	20
05.	Day-peak Generation (Generation end)	:	11629	MW, at =	12:00 hrs	Khulna	1603	1603	0	Barishal	380	380	0
06.	Evening-peak Generation (Generation end)	:	13421	MW, at =	21:00 hrs	Rajshahi	1423	1423	0	Rangpur	888	838	50
07.	Evening Peak Load-shed (Sub-station end)	:	379	MW, at =	21:00 hrs	Cumilla	1286	1248	38				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10903	MW, at =	5:00 hrs					Total	13349	12970	379
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :	(a) Gas =	145334317	Taka	(c) Coal =	249541754	Taka	
	a) Gas limitation	:	3572	MW			(b) Oil =	1320860442	Taka	Total =	1715736513	Taka	
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2018	MW		14. Maximum Temperature in Dhaka was :				34.4° C			
10.	Total Energy (Generation + India Import)	:	290.72	MKWh		15. Export through East-West interconnections :							
	By Gas =	130.117	MKWh	By Oil =	99.186	MKWh							
	By Coal =	30.875	MKWh	By Hydro =	3.641	MKWh							
	By Solar=	1.443	MKWh										
11.	Total Gas Supplied	:	991.97	MMCFD									
(D) Forecast of 22.09.22 (Today) Thursday :													
01.	Maximum Demand	:	14200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14218	MW	(Generation end)	05.	Total Generation	:	307.39	MKWh			