

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Saturday				Date : 24.09.22					
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 13467 MW				Rule Curve = 104.32 ft					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.87 ft				Today = 96.79 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.09.22 (Yesterday)		24.09.22 (Today)		23.09.22 (Yesterday) Gen. shortfall for : Gas/Coal/oil/Water Limitation (MW)	24.09.22 (Today) Gen. shortfall for : Gas/Coal/oil/Water Limitation (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	220	230	230				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	0	0				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	66	83	105				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	281	278	340	300	82	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	373	409	0	0				
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	10	300	335	Gas Shortage		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	137	136	138	138	199	Gas Shortage		
14	Madangarj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	75	40	75				
16	Narshingsi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	19	22	19	22				
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x8.73	80	80	52	51	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	18	15	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	41	49	49				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	119	16	115				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	268	270	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	99	109	115	133				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	30	222	200	225				
27	Branghangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	70	90				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	40	50	50	50				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	74	50	70				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	147	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	24	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	37	0	35				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	46	88	45	90				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	42	91	42	92				
37	Madangarj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total				6004	5847	2683	3362	2438	3212	1051	845		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	151	152	152		Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	40	40	47	47				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	137	140	20	220				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	250	280	300	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	33	33	33	33				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	8x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	8	27	30	30				
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	15	15	16	16				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			34	37	10	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel Oil Shortage		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	88	105	105	105				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	33	33	33	33				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33				
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total				2442	2382	1083	1236	1075	1341	288	330		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	43	43	44	44				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	190	206	200	200				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	320	305	320	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360	Gas Shortage		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	13	13	14	14	271	Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	55	55	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	73	82	102	102	113	Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	108	132	135	135				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	29	30	30				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	80	82	82				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	177	200	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	0	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	8	8	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	20	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	88x1.4+40x1.515+15x1.588	200	200	25	182	150	190				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	57	96	60	95				
79	Bhairob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	7	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115				
**	Impoport (Tripura)	India		160	160	110	158	143	166				
Cumilla Zone Total				3193	3169	1448	1898	1749	1972	744	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	42	102	50	100	100	Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	14	14	14	14	8	Gas Shortage		
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	105	95	100	100				
84	Myensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	149	174	180	185				
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	33	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Myensing Zone Total				622	614	350	391	402	405	108	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.09.22 (Yesterday)		24.09.22 (Today)		23.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gen. shortfall for : Machines shut down (MW)			
98	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
99	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	16	16	16	16	35		Gas Shortage	
91	Kushiar 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	5	81	10	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	310	300	310				
101	Bibiyan-IIII 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	398	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	397	397	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	16	16	16	16	34		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	15	15	15	15	35		Gas Shortage	
Sylhet Zone Total				2522	2477	1483	1575	1490	1579	132	710		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	240	235	200	200	175		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	60				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	170	223	160	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	57	94	75	93				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	57	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	32	16	16	83		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFFCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas+HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	900	899	921	921				
Khulna Zone Total				2388	2384	1439	1653	1537	1655	298	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	26	18	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	85	85	85	109		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	770	1040	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas+HSD (IPP)	2x75+1x70	220	220	223	222	220	220				
Barishal Zone Total				1958	1958	1097	1389	1449	1472	109	0		
123	a) Baghabani 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabani 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabani 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24		18	Turbocharger problem	
125	Baghabani 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	55	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	73	0	75				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		18	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	168	189	170	170				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	144	212	130	210	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	124	147	130	130	73		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	350	270	270	64		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	0	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	80	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2129	2129	986	1352	1018	1355	572	54		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	80	80	80		85	Under Overhauling	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	249	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	71	71	71	71				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	0	75				
148	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	16	0	12	0				
Rangpur Zone Total				830	750	421	476	421	476	0	85		
Sub-total: Plants in operation				22088	21710	10990.0	13332	11579	13467	3302	2024		
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpolti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Arinchara 30 MW PP(Sinha)	HFO (QRPP)	7x7.75	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22512	21710	10990	13332	11579	13467	3302	2024		
(C) Actual data of 23.09.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	13487	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13029	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13332	MW, at =	20:00 hrs	Dhaka	4587	4587	0	Mymensingh	1140	1007	133
04.	Minimum Generation (Generation end)	:	10535	MW, at =	9:00 hrs	Chattogram	1306	1306	0	Sylhet	570	570	0
05.	Day-peak Generation (Generation end)	:	10990	MW, at =	12:00 hrs	Khulna	1613	1613	0	Barishal	374	374	0
06.	Evening-peak Generation (Generation end)	:	13332	MW, at =	20:00 hrs	Rajshahi	1358	1358	0	Rangpur	844	844	0
07.	Evening Peak Load-shed (Sub-station end)	:	143	MW, at =	20:00 hrs	Cumilla	1237	1227	10				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10585	MW, at =	5:00 hrs					Total	13029	12886	143
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 147146581 Taka (b) Oil = 1324847149 Taka	(c) Coal = 263975481 Taka Total = 1735968210 Taka				
	a) Gas limitation	:	3302	MW									
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kapali lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2024	MW									
10.	Total Energy (Generation + India Import)	:	285.11	MKWh		14.	Maximum Temperature in Dhaka was :	34.9° C					
	By Gas = 130.721 MKWH			By Oil = 92.178 MKWh		15.	Export through East-West interconnections :						
	By Coal = 32.493 MKWH			By Hydro = 3.492 MKWh			At evening peak-hour	:	10990	MW, at	20:00 hrs		
	By Solar= 1.306 MKWH						Maximum	:	990	MW, at	21:00 hrs		
							Energy	:	0	MKWh		</	