

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022				Day : Sunday				Date : 25.09.22				
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 13016 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.79 ft				Today = 96.84 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.09.22 (Yesterday)		25.09.22 (Today)		24.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation			
					Day	Evening	Day	Evening	MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	86	95	95	95			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	311	237	300	280	123	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	200	225	225	250	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	126	0	0	0			
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	1	250	320	300	85	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	142	140	138	138	195	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	75	40	75			
16	Narshingsi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power,(Madhabadi-Ashulia)	Gas (SIIPP, REB)	6x3.67+7x8.73	80	80	51	51	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	20	24	22	22			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	48	48	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	88	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	125	16	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	258	268	258	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	107	35	105			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	229	227	200	225			
27	Branganjan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	70	90			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	51	50	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	92	54	93			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	14	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	18	0	18			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	47	87	45	90			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	41	88	42	92			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	2446	3019	2617	3149	863	845	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	116	151	152	152			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	30	47	47	47			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	62	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	141	140	140			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	11	11	11			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	8x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	24	23	30			
51	Barabkunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	16	16	16	16			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			7	27	5	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel Oil Shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	80	105	105	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	33	10	10	10			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	10	10	10			
57	Chattogram 116 MW PP (Anlime Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	105	107	107			
Chattogram Zone Total				2442	2382	857	1164	1134	1175	288	330	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	42	44	44	44			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	201	205	200	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	335	310	320	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0	360		Gas Shortage
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	13	13	14	14	271		Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	56	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	102	73	8	8	122		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	137	135	140			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	35	35	35			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	81	82	82	82			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	8	8	8	8			
73	Jangalia 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	25	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67+2x6.97	25	25	15	21	21	21			
76	Daudkandi 200 MW PP (B.Tec)	HSD (IPP)	88x1.4+40x1.515+15x1.586	200	200	185	184	150	190			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	0	0	0			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	96	106	105	105			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	38	115	35	115			
**	Impoport (Tripura)	India		160	160	132	156	143	166			
Cumilla Zone Total				3193	3169	1799	1876	1686	1844	753	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	69	121	50	100	81		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	14	22	22	22	0		Gas Shortage
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	97	100	100			
84	Mymsensing 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	147	160	170	180			
85	Sarishabati 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0			
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymsensing Zone Total				622	614	346	406	400	408	81	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.09.22 (Yesterday)		25.09.22 (Today)		24.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Day	Evening		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	16	16	16	16	35		Gas Shortage	
91	Kushiar 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	62	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIIP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	285	300	310				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	394	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	16	16	16	16	34		Gas Shortage	
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	15	15	15	15	35		Gas Shortage	
Sylhet Zone Total						2522	2477	1500	1558	1490	1579	132	710
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	190	175	180	180	235		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	26	0	26				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	63	30	30				
110	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	140	223	220	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	80	95	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	55	93	55	90				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	102	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16	99		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFFCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas+HSD (BPDB)				0	0	0	0				
**	Bheramara (HVCDC)	India		1000	1000	904	902	920	920				
Khulna Zone Total						2388	2384	1486	1643	1586	1627	374	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	29	18	29				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	83	84	85	85	110		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	890	1090	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas+HSD (IPP)	2x75+1x70	220	220	220	222	220	220				
Barishal Zone Total						1958	1958	1227	1457	1449	1476	110	0
123	a) Baghabani 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabani 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabani 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	24		18	Turbocharger problem	
125	Baghabani 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	141	172	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	75	0	75				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	26		18	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	168	151	150	150	59		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	132	217	210	210	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	131	123	120	120	97		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	256	230	230	230	184		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	18	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total						2129	2129	1020	1301	1036	1285	775	54
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	81	80	80		85	Under Overhauling	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	71	71	71	71				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	76	0	72				
148	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	10	0	12	0				
Rangpur Zone Total						830	750	417	478	421	473	0	85
Sub-total: Plants in operation						22088	21710	11098.0	12902	11819	13016	3376	2024
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpolti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Arinchara 30 MW PP(Sinha)	HFO (QRPP)	7x7.75	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0			
Gross Total						22512	21710	11098	12902	11819	13016	3376	2024
(C) Actual data of 24.09.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13651	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13149	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12964	MW, at =	22:00 hrs	Dhaka	4673	4531	142	Mymensingh	1107	965	142
04.	Minimum Generation (Generation end)	:	10585	MW, at =	8:00 hrs	Chattogram	1189	1189	0	Sylhet	548	548	0
05.	Day-peak Generation (Generation end)	:	11098	MW, at =	12:00 hrs	Khulna	1698	1521	177	Barisal	383	383	0
06.	Evening-peak Generation (Generation end)	:	12902	MW, at =	21:00 hrs	Rajshahi	1440	1306	134	Rangpur	893	785	108
07.	Evening Peak Load-shed (Sub-station end)	:	703	MW, at =	21:00 hrs	Cumilla	1218	1218	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10810	MW, at =	5:00 hrs					Total	13149	12446	703
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 138438568 Taka (b) Oil = 1406759610 Taka	(c) Coal = 274590304 Taka Total = 1819788482 Taka				
	a) Gas limitation	:	3376	MW									
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2024	MW									
10.	Total Energy (Generation + India Import)	:	283.67	MKWh		14.	Maximum Temperature in Dhaka was :	34.2° C					
	By Gas = 124.341 MKWH			By Oil = 95.565 MKWh		15.	Export through East-West interconnections :						
	By Coal = 33.663 MKWH			By Hydro = 3.606 MKWh			At evening peak-hour	:	11098	MW, at	21:00 hrs		
	By Solar= 1.272 MKWH						Maximum	:	1230	MW, at	3:00 hrs		
							Energy	:	0	MKWh			
11.	Total Gas Supplied	:	952.94	MMCFD									