

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022					Day : Monday				Date : 26.09.22				
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 13035 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.84 ft		Today = 96.98 ft		26.09.22		Rule Curve = 104.80 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.09.22 (Yesterday)		26.09.22 (Today)		25.09.22 (Yesterday)		26.09.22 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/Oil/Water Limitation	Machines shut down	Description/ Remarks			
											Day	Evening	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	215	230	230	230				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	94	95	95				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	314	272	300	280	88		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	335	289	320	300	46		Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	140	143	140	140	192		Gas Shortage	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	45	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	75	40	75				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	19	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	52	52	52	52				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	21	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	49	48	48				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	100	88	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	115	16	115				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	258	270	258	275				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	106	35	105				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	225	223	225	225				
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	90	70	90				
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	50	50				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	73	54	93				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	66	162	72	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	19	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	30	0	17				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	47	88	45	90				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	41	93	42	92				
37	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total					6004	5847	2615	3083	2646	3152	761	1035	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	158	152	158			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	3	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	18	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.69	50	50	47	46	47	47				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	56	148	140	140				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	300	300	300	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	11	11	11				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	23	23	24				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	24	5	20				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel Oil Shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
Chattogram Zone Total					2442	2382	1017	1175	1134	1165	288	330	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	40	44	44	44				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	205	195	200	200				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	325	320	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360		Gas Shortage	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	13	13	0	0	271		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	53	54	55	55				
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	140	135	140				
68	Titab 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	35	35	35				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	81	82	82	82				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	189	179	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	9	8	8				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.015+1x1.08	200	200	176	189	150	190				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	97	106	105	105				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115				
**	Import (Tirupura)	India		160	160	130	150	143	166				
Cumilla Zone Total					3193	3169	1635	1796	1672	1830	818	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	72	132	70	100	70		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	107	100	100				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	170	182	170	180				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0				
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	0	0	0				
Mymensingh Zone Total					622	614	421	443	414	402	70	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.09.22 (Yesterday)		26.09.22 (Today)		25.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	16	16	16	16	35		Gas Shortage	
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	3	5	5	8		Gas Shortage	
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	57	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	300	310				
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	399	400	400				
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	397	380	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	16	16	16	16	34		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	15	15	15	15	35		Gas Shortage	
Sylhet Zone Total						2522	2477	1502	1538	1495	1584	129	710
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	180	180	180	180	230		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	38				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	27	50	30	50				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	169	223	220	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	19	95	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	56	95	55	90				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	66	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	32	16	16	83		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDCL)	India		1000	1000	902	902	911	911				
Khulna Zone Total						2388	2384	1434	1682	1577	1650	353	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	28	18	29				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	81	85	85	113		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	920	1070	1110	1110				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	227	218	220	220				
Barishal Zone Total						1958	1958	1266	1429	1449	1476	113	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	15	172	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	75	0	75				
128	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		18	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	163	161	160	160	49		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	170	217	210	210	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	126	121	120	120	99		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	224	201	230	230	213		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
Rajshahi Zone Total						2129	2129	897	1285	1046	1303	796	54
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	83	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	71	71	71	71				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Maipara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	76	0	72				
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	18	0	12	0				
Rangpur Zone Total						830	750	421	480	421	473	0	85
Sub-total: Plants in operation						22088	21710	11208.0	12911	11854	13035	3328	2214
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilla 108MW PP(ICC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amfura 30 MW PP(Sinhal)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0	0	0
Gross Total						22512	21710	11208	12911	11854	13035	3328	2214
(C) Actual data of 25.09.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	13649	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13148	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12916	MW, at =	22:00 hrs	Dhaka	4550	4442	108	Mymensingh	1086	967	119
04.	Minimum Generation (Generation end)	:	10810	MW, at =	7:00 hrs	Chattogram	1304	1304	0	Sylhet	555	555	0
05.	Day-peak Generation (Generation end)	:	11208	MW, at =	10:00 hrs	Khulna	1685	1517	168	Barishal	383	383	0
06.	Evening-peak Generation (Generation end)	:	12911	MW, at =	21:00 hrs	Rajshahi	1397	1305	92	Rangpur	878	800	78
07.	Evening Peak Load-shed (Sub-station end)	:	680	MW, at =	21:00 hrs	Cumilla	1310	1195	115				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10614	MW, at =	5:00 hrs					Total	13148	12468	680
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 135091715 Taka (c) Coal = 277150357 Taka							
	a) Gas limitation	:	3328	MW						(b) Oil = 1444059183 Taka	Total =	1856301254	Taka
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2214	MW									
10.	Total Energy (Generation + India Import)	:	283.11	MW						14. Maximum Temperature in Dhaka was :	33.6° C		
	By Gas = 121.227 MKWh			By Oil = 97.885 MKWh						15. Export through East-West interconnections :			
	By Coal = 33.960 MKWh			By Hydro = 3.617 MKWh						At evening peak-hour	11208	MW, at	21:00 hrs
	By Solar= 1.291 MKWh									Maximum	1280	MW, at	14:00 hrs
11.	Total Gas Supplied	:	950.88	MMCFD						Energy	0	MW	
(D) Forecast of 26.09.22 (Today) Monday :													
01.	Maximum Demand	:	14200	MW	(Generation end)	04.	Maximum Load-shed	:	1074	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13035	MW	(Generation end)	05.	Total Generation	:	311.26	MW			
03.	Reserve / Shortage	:	-1165	MW	(Generation end)	06.</							