

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	230	5501000	
	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	92	2082545	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	0	0	Under maint.
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	329	7472000	Machine problem
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	5049100	GT-2 S/D due to dirty gas
9	Meghnaghat 100 MW(IE/L)	NENP	12'8.9	100	92	1264320	Engine problem
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	145	3261818	Gas shortage
11	Meghnaghat 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	40	1017351	Engine problem
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	398952	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	87	1328640	Fuel shortage
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	340	7808294	
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	92	1201104	Engine problem
20	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	675360	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	129	1095840	Fuel shortage
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	918748	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	907998	Fuel shortage
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	52	1217760	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	579960	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	21	586800	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	48	1148640	#REF!
30	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	245	6122182	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	225	4775738	Engine problem
33	Bramhanaganj 100 MW PP (Aggreko)	IPP	114'0.959	100	90	948574	Engine problem
34	Auraihati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	1199677	Fuel shortage
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	88	1290816	Engine problem
36	Gazipur 100 MW PP	RPCL	6'17.5	105	100	2175600	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	92	1495920	Engine problem
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1758240	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	194598	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	18	235800	Fuel shortage
Dhaka area Total				5847	3183	63716975	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Razcan 25 MW PP	RPCL	3'8.9	25	25	595521	
44	Teknaf 20MW PP (Solarteck)	IPP	20	20	0	74655	
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	47	978240	Engine problem
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	158	3749055	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	210	2153296	ST under shutdown
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2529999	
49	Hafiznari 100 MW peaking PP	PDB	11'8.9	98	31	700176	Fuel shortage
50	Dohazari-Kataish 100 MW Peaking	PDB	6'17	102	51	613910	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	10	251280	Fuel shortage
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	11	262080	Fuel shortage
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	17	366288	Engine problem
*	Malancha, Ctg. EPZ (Unlited)		5'8.73+3'9.34	0	25	314400	
54	Chattogram 108 MW PP (ECVP)	IPP	16'7	108	0	0	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	20400	
56	Anwara 300 MW PP (Unlited)	IPP	17'17+24	300	300	5083418	
57	Jodai Power	IPP	3'18.55+1'3.6	54	36	765674	Engine problem
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	105	2265699	
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	10	251520	Engine problem
60	Anlima Energy Ltd.	IPP	6'21.2	116	107	2563036	Engine problem
Mirshara 150 MW				BPDB-RPCL	18.5'9	0	On test.
Chattogram area Total				2382	1248	23538647	
61	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	206	4705000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	0	0	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	305	7845000	FGMO
65	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	9	191600	On test.
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	40	978192	Engine problem
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	55	1289760	
67	Ashuganj 195MW PP (APSCL-Unlited)	IPP	20'9.73+1'16	195	36	635636	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	2626181	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	123	2626181	Engine problem
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	31	813088	Engine problem
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	80	1948130	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	178	4400640	Engine problem
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	508716	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	9	218340	
**	Import (Tripura)	Imported power	0	160	168	3647200	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	698100	
76	Jangalia 52 MW PP (Lakdorew)	IPP	6'8.92	52	8	201542	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	511410	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	186	3948480	Engine problem
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	9120	Fuel shortage
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	112	2524200	
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	650880	33 kV feeder problem.
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	115	1058840	
Cumilla Area Total				3169	1823	42037236	
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	133	2630400	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	447840	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	14250	
87	Mymensingh 200 MW PP (Unlited)	IPP	9.78'21	200	140	2229600	Fuel shortage
88	Jamalpur 115 MW PP (Unlited)	IPP	9.78'12	115	105	2421600	Engine problem
89	Sutiakhali 50 MW Solar PP	IPP	50	50	0	308250	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	0	0	Engine problem
Mymensingh Area Total				614	400	8051940	
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	1021000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	30	329800	Machine problem
93	Kushinara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	5	323400	Gas shortage
96	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	5	352440	Gas shortage
97	Hobiganj 11MW PP Confidene-E	SIPP, REB	4'2.90	11	5	101808	Gas shortage
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	66	1550492	
98	Shahjibazar 80MW PP (Shahjibazar)	RPP	3'2.2.90	86	81	864960	
99	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	220	5220420	
101	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage
101	Sylhet 50MW PP (EPL)	NENP	27'2	50	0	88040	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	54048	Gas shortage
103	Bibiyan-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	7410500	FGMO
104	Bibiyan-I 400 MW CCPP	PDB	400 MW	400	402	9542000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	102420	
106	Bibiyan South 400 MW	PDB	400 MW	383	380	9125400	
Sylhet Area Total				2477	1525	36086728	
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	
**	Bheramara (HVDC)	Imported power	2'500	1000	795	21178181	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	24	222480	Fuel shortage
109	Fandipur 100 MW Peaking PP	PDB	8'6.89	54	33	222720	
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	229	4957440	
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	78	549504	Engine problem
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	185	4614048	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	95	1030080	Engine problem
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	94	1403040	Engine problem
115	Madhumati 100 MW PP	NWPGCL	6'18	105	67	722592	Fuel shortage
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	6177	