

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2022					Day : Tuesday				Date : 27.09.22					
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 13368 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.98 ft		Today = 97.10 ft		Rule Curve = 105.04 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.09.22 (Yesterday)		27.09.22 (Today)		26.09.22 (Yesterday)		27.09.22 (Today)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW		(MW)			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	220	230	230	230					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	92	95	95					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	290	329	346	350					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225			Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412			Gas Shortage	
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	339	340	320	335					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	120	145	140	140	190			Gas Shortage	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	40	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	40	92					
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	52	52	52	52					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	21	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	48	48	48					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	100	88	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	129	16	115					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	259	245	258	275					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	88	35	105					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	215	225	225	225					
27	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	90	75	90					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	50	50					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	92	54	93					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	72	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	18	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	18	0	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	46	87	45	90					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	42	92	42	92					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total					6004	5847	2446	3183	2705	3282	1037	1035		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	158	158	152	158				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	15	0	20	0	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.9	50	50	40	47	47	47					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	28	210	140	140					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	197	300	300	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	11	11	11					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	31	30	30					
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	16	16					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	25	5	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108			Fuel Oil Shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	88	105	105	105					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
Chattogram Zone Total					2442	2382	871	1248	1141	1171	288	330		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	40	40	44	44					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	205	206	200	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	305	320	330					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0	360			Gas Shortage	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	13	9	8	8	275			Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	51	55	55	55					
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	36	8	8	159			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	123	135	140					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	31	35	35					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	80	80	82	82					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	179	178	200	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.015+15x1.08	200	200	184	186	150	190					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	17					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	99	112	105	105					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	115	35	115					
**	Import (Tripura)	India		160	160	124	168	143	166					
Cumilla Zone Total					3193	3169	1631	1823	1699	1875	794	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	106	133	70	100	69			Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22					
83	Jamulpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	105	100	100					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	86	140	170	180					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0					
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	0	0	0					
Mymensingh Zone Total					622	614	345	400	414	402	69	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.09.22 (Yesterday)		27.09.22 (Today)		26.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	5	16	16	46		Gas Shortage	
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5	6		Gas Shortage	
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	66	60	60				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	20	81	10	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	8	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	270	300	310				
101	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400				
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	380	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	20	5	15	15	45		Gas Shortage	
Sylhet Zone Total						2522	2477	1513	1525	1509	1598	164	680
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	205	185	210	210	225		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	0	38				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	78	30	78				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	225	229	220	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	10	95	50	95				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	57	94	55	90				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	65	0	100	0				
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	24	16	24	91		Fuel Oil Shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel Oil Shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDF)				0	0	0	0				
**	Bheramara (HVDCL)	India		1000	1000	891	795	906	906				
Khulna Zone Total						2388	2384	1468	1600	1602	1711	356	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	18	29				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	77	85	85	117		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	930	1070	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	222	220	220				
Barishal Zone Total						1958	1958	1256	1412	1449	1476	117	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	32		18	Turbocharger problem	
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	50	171	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	27	0	75				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32		18	Under maint.	
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26		18	Under maint.	
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	172	162	160	176	48		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	213	219	210	210	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	135	126	120	133	94		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	289	230	276	276	184		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8	44		Fuel Oil Shortage	
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	95	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	94	50	94				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total						2129	2129	1042	1261	1092	1378	761	54
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	82	80	82	82				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	71	71	71	71				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	76	75	72				
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	5	0	12	0				
Rangpur Zone Total						830	750	410	477	498	475	0	85
Sub-total: Plants in operation						22088	21710	10982.0	12929	12109	13368	3586	2184
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilla 108MW PP(ICC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amfura 30 MW PP(Sinhal)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0	0	0
Gross Total						22512	21710	10982	12929	12109	13368	3586	2184
(C) Actual data of 26.09.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	14200	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13568	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12934	MW, at =	22:00 hrs	Dhaka	4803	4443	360	Mymensingh	1120	1027	93
04.	Minimum Generation (Generation end)	:	10614	MW, at =	7:00 hrs	Chattogram	1424	1390	34	Sylhet	596	496	100
05.	Day-peak Generation (Generation end)	:	10982	MW, at =	9:00 hrs	Khulna	1654	1480	174	Barishal	383	383	0
06.	Evening-peak Generation (Generation end)	:	12929	MW, at =	21:00 hrs	Rajshahi	1350	1220	130	Rangpur	869	759	110
07.	Evening Peak Load-shed (Sub-station end)	:	1171	MW, at =	21:00 hrs	Cumilla	1369	1199	170				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10614	MW, at =	5:00 hrs					Total	13568	12397	1171
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 139826240 Taka (c) Coal = 274512174 Taka							
	a) Gas limitation	:	3586	MW						(b) Oil = 1346036394 Taka	Total =	1760374808	Taka
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2184	MW									
10.	Total Energy (Generation + India Import)	:	279.54	MkWh		14. Maximum Temperature in Dhaka was :	33.8° C						
	By Gas = 124.879 MKWh			By Oil = 90.921 MKWh		15. Export through East-West interconnections :							
	By Coal = 33.663 MKWh			By Hydro = 3.749 MKWh		At evening peak-hour	:	10982	MW, at	21:00 hrs			
	By Solar= 1.505 MKWh					Maximum	:	615	MW, at	12:00 hrs			
11.	Total Gas Supplied	:	954.61	MMCFD		Energy	:	0	MkWh				
(D) Forecast of 27.09.22 (Today) Tuesday :													
01.	Maximum Demand	:	14200	MW (Generation end)	</								