

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022					Day : Saturday					Date : 01.10.22				
Probable Maximum Demand : 14300 MW					Probable Maximum Generation : 13585 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 97.06 ft					Today = 96.97 ft				
					Rule Curve = 106.00 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.09.22 (Yesterday)		01.10.22 (Today)		30.09.22 (Yesterday)		01.10.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation		(MW)			
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	230	230	230	230					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	53	90	90					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	281	223	320	320		137		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225		225		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412		Gas Shortage	
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	322	288	320	320					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	138	150	140	150		185		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	0	40	40	40					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	92	40	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	25	51	51					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	24	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	48	48	48	48					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	90	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	130	16	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	275	95	290					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	117	134	133	149					
26	Karaganga 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	153	231	200	220					
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	97	50	95					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	17	55					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	72	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	46	54	54	54					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	87	40	90					
36	Meghnaghat 100 MW(WIEL)	HFO (NENP)	12x8.9	100	100	41	83	42	84					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total					6004	5847	2504	3206	2686	3420	1169	845		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	114	150	116	149				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	44	44					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	82	228	220	220					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	196	285	195	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	11	11	11					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	23	23	23					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			35	36	15	35					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	18	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	104	105	105	105					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	10	10	10					
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0					
Chattogram Zone Total					2442	2382	883	1199	1063	1248	180	330		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0		134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	36	36	35	35					
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1775	221	221	193	198	200	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	250	300	310					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	280	300	310					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0		284		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	20	45	20	45					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8		187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	117	127	130	135					
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	22					
69	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	81	81	80	80					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	178	177	180	180					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	16	8	16					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	90	100	100	100					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	97	113	108	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	35	115					
**	Imporpt (Tripura)	India		160	160	142	118	143	166					
Cumilla Zone Total					3193	3169	1728	1837	1827	2015	605	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	38	97	70	100		105		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	86	97	100	100					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	96	149	86	150					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0					
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensinga Zone Total					622	614	300	377	342	384	105	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.09.22 (Yesterday)		01.10.22 (Today)		30.09.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
89	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	41	41		49	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	0	0	0	51		Gas Shortage	
91	Kushlara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	55	62	60	62				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	81				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	214	220	220	220				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0	17		Gas Shortage	
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	320	290	320				
101	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	392	400	400				
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	392	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	5	5	5	45		Gas Shortage	
Sylhet Zone Total						2322	2477	1461	1574	1479	1582	303	560
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	185	195	200	200	215		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	33	6	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	35	45	60				
110	Khulna 225 MW CCPP	HSD (NWPGLCL)	1 x 150+1x75	230	230	120	219	220	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	50	50	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	57	94	55	94				
113	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	15	32	15	50				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	81	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas+HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	911	911	928	928				
Khulna Zone Total						2388	2384	1399	1585	1635	1658	215	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	32				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	28	20	25				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	81	82	85	85	112		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	880	1100	1110	1110				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas+HSD (IPP)	2x75+1x70	220	220	216	219	220	220				
Barishal Zone Total						1958	1958	1196	1445	1451	1472	112	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	24				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	173	100	170				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	9	84	0	84				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	16	32				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	8	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	25				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	172	169	175	175	41		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	130	199	210	210	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	128	127	130	130	93		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	259	264	270	270	150		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	18	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6'18.55	113	113	113	113	113	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	113	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total						2129	2129	954	1407	1178	1425	675	0
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	0	0	0				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	249	250	250				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	56	56	56	56				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Maipara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	30	75	50	75				
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	22	0	12	0				
Rangpur Zone Total						830	750	444	380	376	381	0	85
Sub-total: Plants in operation						22088	21710	10869.0	13010	12037	13585	3364	1820
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilla 108MW PP(ICC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amfura 30 MW PP(Sinhal)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	10869	13010	12037	13585	3364	1820
(C) Actual data of 30.09.22 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	13921	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13306	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13010	MW, at =	20:00 hrs	Dhaka	4663	4570	93	Mymensingh	1127	949	178
04.	Minimum Generation (Generation end)	:	10467	MW, at =	8:00 hrs	Chattogram	1243	1243	0	Sylhet	624	545	79
05.	Day-peak Generation (Generation end)	:	10869	MW, at =	12:00 hrs	Khulna	1687	1464	223	Barishal	393	393	0
06.	Evening-peak Generation (Generation end)	:	13010	MW, at =	20:00 hrs	Rajshahi	1343	1203	140	Rangpur	849	762	87
07.	Evening Peak Load-shed (Sub-station end)	:	840	MW, at =	20:00 hrs	Cumilla	1378	1338	40				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10525	MW, at =	5:00 hrs					Total	13306	12466	840
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 147442530 Taka (c) Coal = 274537912 Taka							
	a) Gas limitation	:	3364	MW						(b) Oil = 1277623736 Taka	Total =	1699604178	Taka
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	1820	MW									
10.	Total Energy (Generation + India Import)	:	282.15	MKWh		14. Maximum Temperature in Dhaka was : 35.6° C							
	By Gas = 130.536 MKWh			By Oil = 88.010 MKWh		15. Export through East-West interconnections :							
	By Coal = 33.437 MKWh			By Hydro = 3.485 MKWh		At evening peak-hour	:	10869	MW, at	20:00 hrs			
	By Solar= 1.422 MKWh					Maximum	:	615	MW, at	12:00 hrs			
						Energy	:	0	MKWh				
11.	Total Gas Supplied	:	990.59	MMCFD									
(D) Forecast of 01.10.22 (Today) Saturday :													
01.	Maximum Demand	:	14300	MW (Generation end)		04.	Maximum Load-shed	:	659	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13585	MW (Generation end)		05.	Total Generation	:	310.12	MKWh			
03.	Reserve / Shortage	:	-715	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	36 ° C				