

Date : 3-Oct-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enervoy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	220	5236000	
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4284000	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
4	Ghorashal 78.5 MW PP (MAX)	ORPP	2'40	0	0	0	Contract Expired
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	52	1644500	Engine problem
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	0	0	Under maint.
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	133	3902000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	120	3201200	GT-2 S/D due to dirty gas
9	Meghnaghat 100 MW(IEL)	NENP	12'8.9	100	0	794880	Line trip
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	95	2997527	Gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	15	369749	Fuel shortage
13	Keraniganj 100 MW PP (Powerpac)	ORPP	8'13.45	0	0	0	Contract Expired
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	400608	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12'8.9	100	75	1183680	Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	175	5030520	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	92	1300752	Engine problem
20	Katpohi 52 MW PP (Sinha)	IPP	17'7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	657000	
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	132	1826400	Fuel shortage
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	916899	
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	35	907381	Fuel shortage
25	Bosila 108MW PP(ELCL)	IPP	12'8.775+1'3.5	0	0	0	
26	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	49	1133160	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	586500	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	16	441800	Engine problem
29	Gazipur 52 MW PP	RPCL	6'8.9	52	49	1096800	#REF!
30	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	293	3991964	Engine problem
32	Keranigonj 300 MW PP (APR)	IPP	256'1.4	300	154	587142	Fuel conservation
33	Bramhangonj 100 MW PP (Aggreko)	IPP	114'0.959	100	50	300996	Fuel conservation
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	292587	Fuel conservation
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	125	2004624	Fuel shortage
36	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2275200	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	53	667200	Fuel shortage
38	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	162	1756240	
39	Spectra Solar Plant Ltd.	IPP	35	35	0	87944	
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	54	1274760	
Dhaka area Total				5847	2637	51152013	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	510190	
43	Teknaf 20MW PP (Solarteck)	IPP	20	20	0	96255	
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	43	1069440	33 kV feeder problem.
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	150	3646502	Low water level
46	Sikalbaha 225MW	PDB	1'150+1'175	225	229	5339863	
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2453890	
49	Hathazari 100 MW peaking PP	PDB	11'8.9	98	21	532368	Fuel shortage
50	Dohazari-Katlaash 100 MW Peaking	PDB	8'17	102	51	597807	Fuel shortage
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	52	386640	Fuel shortage
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	11	372480	Fuel shortage
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	16	392016	Engine problem
*	Malancha, Ctg. EPZ (Unlited)		5'8.73+3'9.34	0	28	449760	
54	Chattogram 108 MW PP (ECVP)	IPP	16'7	108	0	0	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	29762	
56	Anwara 300 MW PP (Unlited)	IPP	17'17+24	300	285	4975527	Engine problem
57	Jodiac Power	IPP	3'18.55+1'3.6	54	36	783145	Engine problem
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	105	2499880	
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	45	367680	
60	Anlima Energy Ltd.	IPP	6'21.2	116	107	2581855	Engine problem
Mirshara 150 MW				BPDB-RPCL	18.5'9	0	28436 On test.
Chattogram area Total				2382	1309	27113496	
61	Ashuganj TPP Unit- 3	APSCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit- 4	APSCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Gas shortage
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	181	4481000	#REF!
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	280	7983500	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	200	4188000	ST under S/D
65	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	0	0	On test
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	37	838512	Engine problem
66	Ashuganj 55 MW PP (Precision)	ORPP	15'4	55	10	494400	Gas shortage
67	Ashuganj 195MW PP (APSCL-Unlited)	IPP	20'9.73+1'16	195	8	200727	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1147366	
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	133	3184872	Engine problem
70	Titas 50 MW Peaking PP	PDB	8'8.9	52	44	940400	Fuel shortage
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	69	1283860	Machine problem
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	200	3239040	
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	491976	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	9	210240	Engine problem
**	Importot (Tripura)	Imported power	0	160	136	2864640	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	447200	Engine problem
76	Jangalia 52 MW PP (Lakshnaw)	IPP	8'8.92	52	8	27758	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	464060	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Fuel shortage
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	0	Fuel shortage
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	115	2548560	
81	Bhairab 54.5 MW	IPP	3'18.2	54	54	1006560	
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	115	1387200	
Cumilla Area Total				3169	1717	37428971	
83	RPCL 210MW CCPP	IPP	4'95+1'70	202	103	1978560	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	407916	
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	5700	
87	Mymensingh 200 MW PP (Unlited)	IPP	9.78'21	200	163	2496400	Fuel shortage
88	Jamalpur 115 MW PP (Unlited)	IPP	9.78'12	115	86	1954800	Engine problem
89	Sutiakhal 50 MW Solar PP	IPP	50	50	0	206160	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	291840	Engine problem
Mymensingh Area Total				614	384	7343376	
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	1024000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	41	951640	Machine problem
93	Kushihara 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	0	0	Gas shortage
96	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	0	43272	Gas shortage
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	5	41360	Gas shortage
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	68	1495392	
98	Shahjibazar 80MW PP (Shahjibazar)	RPP	3'22.90	86	78	806400	
99	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	220	5172700	
101	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage
102	Sylhet 50MW PP (EPL)	NENP	27'2	50	5	88860	Gas shortage
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	8	56496	Gas shortage
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	7361000	FGMO
104	Bityanah-II 400 MW CCPP	PDB	400 MW	400	401	9427000	
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	241200	
106	Bityanah South 400 MW	PDB	400 MW	383	400	9182000	
Sylhet Area Total				2477	1559	35891320	
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Fuel shortage
**	Bheramara (HVDC)	Imported power	2'500	1000	919	22400727	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	16	120000	Fuel shortage
109	Fandipur 225 MW Peaking PP	PDB	8'8.98	54	22	145440	Engine problem
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	2684160	Tripped at 18.56
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	53	375680	Engine problem
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	210	5254848	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	50	245760	Fuel conservation
114	Rupsha 108 MW PP (Orion rupsha)	IPP	6'18.445	105	75	1387680	Engine problem
115	Madhumati 100 MW PP	NWPGCL	6'18	105	32	524592	Fuel shortage
116	Mongla Orion 100 MW Solar PP	IPP	100	1			