

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 4-Oct-22

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | | Peak Hour Generation | Energy Generated | Remarks |
|-------------------------------|--|----------------|--------------------|---------------------|-------------|----------------------|------------------|---|
| | | | | Unit No. X Capacity | MW | | | |
| 1 | Ghorasal Repowered CCPP-Unit-3 (GT) | PDB | 1'260 | 260 | 0 | 0 | 0 | Under maint. |
| 2 | Ghorasal Repowered CCPP-Unit-4 | PDB | 1'210 | 180 | 100 | 4122000 | 0 | Eastern Grid Blackout at 14:04. |
| 3 | Ghorasal TPP Unit-5 | PDB | 1'210 | 190 | 0 | 2331000 | 0 | Eastern Grid Blackout at 14:04. |
| 4 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1'243+1'122 | 365 | 0 | 0 | 0 | Under maint. |
| 5 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2'40 | 0 | 0 | 0 | 0 | Contract Expired |
| 6 | Ghorasal 108MW PP (Regent) | IPP | 34'3.35 | 108 | 89 | 1315181 | 0 | Engine problem |
| 7 | Harpur GT PP | SBU, PDB | 2'30 | 0 | 0 | 0 | 0 | Under maint. |
| 8 | Harpur 412 MW CCPP | EGCB | 1'273+1'139 | 412 | 135 | 819680 | 0 | Under maint. |
| 9 | Harpur 360MW CCPP(HPL) | IPP | 1'235+1'125 | 360 | 95 | 3064000 | 0 | Gas shortage |
| 10 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2'150+1'150 | 450 | 0 | 1763000 | 0 | GT-2 S/D, Eastern Grid Blackout at 14:04. |
| 11 | Meghnaghat 100 MW(EL) | NENP | 12'9.9 | 100 | 0 | 0 | 0 | Eastern Grid Blackout at 14:04. |
| 12 | Meghnaghat CCPP(Summit) | IPP | 2'110+1'110 | 335 | 0 | 1407767 | 0 | Eastern Grid Blackout at 14:04. |
| 13 | Madanganj 102 PP(Summit) | NENP | 6'17 | 102 | 0 | 0 | 0 | Under maint. |
| 14 | Madanganj-55 MW PP(Summit) | IPP | 3'17.08+1'11.3 | 55 | 20 | 347972 | 0 | Fuel shortage |
| 15 | Keraniganj 100 MW PP (Powerpac) | QRPP | 8'13.45 | 0 | 0 | 0 | 0 | Contract Expired |
| 16 | Nashingdi 22 MW PP (Doreen) | SIPP, REB | 8'2.90 | 22 | 19 | 366228 | 0 | 0 |
| 17 | 120 MW Siddhigangj TPP | PDB | 1'210 | 0 | 115 | 0 | 0 | Under maint. |
| 18 | Siddhigangj 2'120 MW GTPP | EGCB | 2'105 | 210 | 120 | 784000 | 0 | Eastern Grid Blackout at 14:04. |
| 19 | Siddhigangj 100 PP(Dutch Bangla) | NENP | 12'9.9 | 100 | 48 | 827520 | 0 | Engine problem |
| 20 | Siddhigangj 335 MW CCPP | EGCB | 1'217+1'118 | 335 | 0 | 3194492 | 0 | Eastern Grid Blackout at 14:04. |
| 21 | Gagnagar 102 MW PP (Digital Power) | IPP | 12'8.924 | 102 | 50 | 905328 | 0 | Eastern Grid Blackout at 14:04. |
| 22 | Kalipoti 52 MW PP (Sinha) | IPP | 7'7.9 | 0 | 0 | 0 | 0 | Fuel shortage |
| 23 | Kamatnagar 54 MW PP(Banco Energy) | IPP | 3'19 | 54 | 35 | 424980 | 0 | Engine problem |
| 24 | Kodda 150MW PP | BPDB-RPCL | 9'17.06 | 149 | 130 | 1613280 | 0 | Fuel shortage |
| 25 | Manikganj 55 MW PP (Northern) | IPP | 3'19.3 | 55 | 0 | 506957 | 0 | Eastern Grid Blackout at 14:04. |
| 26 | Nababganj 55 MW PP (Southern power) | IPP | 3'19.3 | 55 | 55 | 812581 | 0 | 0 |
| 27 | Boisla 108MW PP(CLC) | IPP | 12'8.775+1'3.5 | 0 | 0 | 0 | 0 | 0 |
| 28 | Summit Power (Madhabdi+Ashulia) | SIPP, REB | 33.67+4'8.73 | 80 | 52 | 1072140 | 0 | 0 |
| 29 | Matca 33 MW PP(Summit) | SIPP, REB | 4'8.73 | 33 | 26 | 914140 | 0 | Engine problem |
| 30 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4'8.73 | 33 | 26 | 444500 | 0 | Engine problem |
| 31 | Gazipur 52 MW PP | RPCL | 6'8.9 | 52 | 49 | 879360 | 0 | #REF! |
| 32 | Tongi 80 MW GTPP | PDB | 1'105 | 105 | 0 | 0 | 0 | Under maint. |
| 33 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18'17.076 | 300 | 250 | 2845309 | 0 | 0 |
| 34 | Kwaranganj 300 MW PP (Agreko) | IPP | 28'9.4 | 300 | 45 | 401053 | 0 | Eastern Grid Blackout at 14:04. |
| 35 | Bramhangang 100 MW PP (Agreko) | IPP | 11'40.959 | 100 | 50 | 130576 | 0 | Eastern Grid Blackout at 14:04. |
| 36 | Aurahati 100MW PP (Agreko) | IPP | 0.85'23+0.95'91 | 100 | 50 | 243545 | 0 | Eastern Grid Blackout at 14:04. |
| 37 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 8'18.45+8.97 | 149 | 133 | 1514016 | 0 | Eastern Grid Blackout at 14:04. |
| 38 | Gazipur 100 MW PP | RPCL | 6'17.5 | 105 | 105 | 2120000 | 0 | 0 |
| 39 | Meghnaghat 104 MW PP (OPCL) | IPP | 18'5.76 | 104 | 17 | 513600 | 0 | Fuel shortage |
| 40 | Manikganj 162MW PP(MPL) | IPP | 9'15 | 162 | 72 | 953280 | 0 | Eastern Grid Blackout at 14:04. |
| 41 | Spectra Solar Plant Ltd. | IPP | 35 | 35 | 0 | 172634 | 0 | 0 |
| 42 | Kanchan Purbaschal Power Generation Ltd. | IPP | 18.4'3 | 55 | 54 | 1059480 | 0 | 0 |
| Dhaka area Total | | | | 5847 | 1779 | 37487999 | | |
| 43 | Chattoagram TPP-1 | PDB | 1'210 | 180 | 0 | 0 | 0 | Machine problem |
| 44 | Chattoagram TPP-2 | PDB | 1'210 | 180 | 0 | 0 | 0 | Gas shortage |
| 45 | Chaozin 25 MW PP | RPCL | 3'8.9 | 25 | 10 | 436996 | 0 | 0 |
| 46 | Teknaf 20MW PP (SolarTech) | IPP | 20 | 20 | 0 | 92745 | 0 | 0 |
| 47 | Patenga 50MW PP (Baraka) | IPP | 8'6.98 | 50 | 27 | 627840 | 0 | 33 kV feeder problem. |
| 48 | Kapla Hydro Unit-1,2,3,4, 5 | PDB | 2'40+3'50 | 230 | 150 | 2966411 | 0 | Low water level |
| 49 | Sikalbaha 225MW | PDB | 1'150+1'175 | 225 | 37 | 3387563 | 0 | Eastern Grid Blackout at 14:04. |
| 50 | Sikalbaha Peaking GT | PDB | 1'150 | 0 | 150 | 0 | 0 | Under maint. |
| 51 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP | 6'17.5 | 105 | 102 | 1841672 | 0 | 0 |
| 52 | Hathazari 100 MW peaking PP | PDB | 11'8.9 | 98 | 0 | 201040 | 0 | Fuel shortage |
| 53 | Dohazari -Kataish 100 MW Peaking | PDB | 6'17 | 102 | 68 | 552779 | 0 | Fuel shortage |
| 54 | Juldah 100 MW Unit-1 (Accom) | NENP | 8'13.45 | 100 | 33 | 317280 | 0 | Fuel shortage |
| 55 | Juldah 100 MW PP Unit-3 (Accom) | IPP | 8'13.5 | 100 | 31 | 308160 | 0 | Fuel shortage |
| 56 | 124kunda 22 MW PP (Regent) | SIPP, PDB | 8'2.90 | 22 | 0 | 266464 | 0 | Engine problem |
| 57 | Malancha, Ctg, EPZ (Unlited) | IPP | 5'8.73+3'9.34 | 0 | 27 | 453120 | 0 | 0 |
| 58 | Chattoagram 108 MW PP (ECPV) | IPP | 16'7 | 108 | 0 | 0 | 0 | Fuel shortage |
| 59 | Kapla 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 22773 | 0 | 0 |
| 60 | Anwara 300 MW PP (Unlited) | IPP | 17'17.24 | 300 | 175 | 3751091 | 0 | Eastern Grid Blackout at 14:04. |
| 61 | Jodiad Power | IPP | 3'18.55+1'3.6 | 54 | 26 | 575614 | 0 | 0 |
| 62 | Kamaghat Power Ltd | IPP | 18.4+6+6.5 | 110 | 64 | 1629955 | 0 | 0 |
| 63 | Juldah Unit-2 (Accom) | IPP | 8'13.6 | 100 | 38 | 337920 | 0 | 0 |
| 64 | Anilima Energy Ltd. | IPP | 6'21.2 | 116 | 68 | 1794000 | 0 | Eastern Grid Blackout at 14:04. |
| 65 | Mirsharai 150 MW | BPDB-RPCL | 18.5'9 | 0 | 0 | 0 | 0 | On test. |
| Chattoagram area Total | | | | 2382 | 876 | 19863423 | | |
| 66 | Ashuganj TPP Unit-3 | APSCCL | 1'150 | 0 | 0 | 0 | 0 | Contract Expired |
| 67 | Ashuganj TPP Unit-4 | APSCCL | 1'150 | 0 | 0 | 0 | 0 | Contract Expired |
| 68 | Ashuganj TPP Unit-5 | APSCCL | 1'150 | 134 | 0 | 0 | 0 | Gas shortage |
| 69 | Ashuganj 225 MW CCPP | APSCCL | 1'142+1'175 | 221 | 0 | 2717000 | 0 | #REF! |
| 70 | Ashuganj 450 MW CCPP(North) | APSCCL | 1'360 | 360 | 0 | 5127000 | 0 | Eastern Grid Blackout at 14:04. |
| 71 | Ashuganj 450 MW CCPP(South) | APSCCL | 1'360 | 360 | 225 | 2969000 | 0 | ST under S/D |
| 72 | Ashuganj 420 MW CCPP(East) | APSCCL | 284'1+136'1 | 284 | 0 | 0 | 0 | On test. |
| 73 | Ashuganj 50 MW PP | APSCCL | 14'3.968 | 45 | 37 | 744120 | 0 | Engine problem |
| 74 | Ashuganj 55 MW PP (Precision) | QRPP | 15'4 | 55 | 53 | 497760 | 0 | 0 |
| 75 | Ashuganj 195MW PP (APSCCL-United) | IPP | 20'9.73+1'116 | 195 | 185 | 1237818 | 0 | 0 |
| 76 | Ashuganj 51 MW PP (Midland) | IPP | 6'9.34 | 51 | 51 | 965752 | 0 | 0 |
| 77 | Ashuganj 150MW PP (Midland) | IPP | 23'7.015 | 150 | 0 | 1172672 | 0 | Eastern Grid Blackout at 14:04. |
| 78 | 8'18.50 MW Peaking PP | PDB | 6'18.92 | 52 | 45 | 374384 | 0 | Fuel shortage |
| 79 | Chandpur 150 MW CCPP | PDB | 11'06+1'157 | 150 | 50 | 1324600 | 0 | Machine problem |
| 80 | Chandpur 200MW (Desh energy) | IPP | 12'18.4 | 200 | 200 | 2293920 | 0 | 0 |
| 81 | Feni 22MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 22 | 408276 | 0 | 0 |
| 82 | Feni 11 MW PP (Doreen) | SIPP, REB | 4'2.90 | 11 | 9 | 180900 | 0 | Engine problem |
| 83 | Impoort (Tripura) | Imported power | 0 | 160 | 160 | 3267840 | 0 | 0 |
| 84 | Jangala 33MW PP (Summit) | SIPP, PDB | 4'8.73 | 33 | 25 | 431000 | 0 | Engine problem |
| 85 | Jangala 52 MW PP (Lakshadivi) | IPP | 6'8.92 | 52 | 8 | 39014 | 0 | Fuel shortage |
| 86 | Cumilla 25 MW PP (Summit) | SIPP, REB | 3'3.67+2'6.97 | 25 | 21 | 448810 | 0 | Engine problem |
| 87 | Daudkandi 200 MW PP (B.Trac) | IPP | 154'1.4 | 200 | 0 | 226944 | 0 | Fuel shortage |
| 88 | Feni Lanka Power | IPP | 7'18.415+1'9.78 | 114 | 0 | 95760 | 0 | Fuel shortage |
| 89 | Chowmuhani 113 MW | IPP | 12'9.78+2'3.1 | 113 | 105 | 1790400 | 0 | 0 |
| 90 | Barabara 54.5 MW | IPP | 3'18.2 | 54 | 35 | 738200 | 0 | 0 |
| 91 | Chandpur 115(Doreen) | IPP | 4'18.5+2'22.5 | 115 | 86 | 983840 | 0 | 0 |
| Cumilla Area Total | | | | 3169 | 1317 | 28548550 | | |
| 92 | RPCL 210MW CCPP | IPP | 4'35+1'70 | 202 | 102 | 1834560 | 0 | Gas shortage |
| 93 | Tangal 22 MW PP (Doreen) | SIPP, PDB | 8'2.90 | 22 | 22 | 398700 | 0 | 0 |
| 94 | Jamalpur 195 MW PP(Powerpac) | IPP | 12'8.924 | 0 | 0 | 0 | 0 | Under maint. |
| 95 | Sainshabari 3 MW Solar Plant | IPP | 3 | 3 | 0 | 9000 | 0 | 0 |
| 96 | Mymensingh 200 MW PP (Unlited) | IPP | 9'78+2'1 | 200 | 77 | 2272800 | 0 | Fuel shortage |
| 97 | Jamalpur 115 MW PP (Unlited) | IPP | 9'78+1'2 | 115 | 83 | 1551600 | 0 | Engine problem |
| 98 | Suliakhali 50 MW Solar PP | IPP | 50 | 50 | 0 | 297560 | 0 | 0 |
| 99 | Tangal Pali Power Gen 22 MW | IPP | 4'6.7 | 22 | 12 | 262320 | 0 | Engine problem |
| Mymensingh Area Total | | | | 614 | 296 | 6626540 | | |
| 100 | Fenchugonj CC Phase-1 | PDB | 2'32+1'33 | 70 | 29 | 637000 | 0 | Machine problem |
| 101 | Fenchugonj CCPP Phase-2 | PDB | 2'35+1'35 | 90 | 0 | 589556 | 0 | Machine problem |
| 102 | Kushlaria 163 MW CCPP (KP) | IPP | 1'109+1'54 | 163 | 0 | 0 | 0 | Gas shortage |
| 103 | Shajibazar 330 MW CCPP | PDB | 3'110 | 330 | 0 | 0 | 0 | Under maint. |
| 104 | Fenchugonj 51 MW PP (Barakatalah) | RPP | 19'2.90 | 51 | 39 | 188400 | 0 | 0 |
| 105 | Fenchugonj 44MW PP (Energyprima) | NENP | 12'3.3+2'2 | 50 | 13 | 866400 | 0 | Eastern Grid Blackout at 14:04. |
| 106 | Hobiganj 11MW PP Colddance-E | SIPP, REB | 4'2.90 | 11 | 0 | 106352 | 0 | Eastern Grid Blackout at 14:04. |
| 107 | Shajibazar GTTP Unit- 8 & 9 | PDB | 2'35 | 66 | 20 | 1085568 | 0 | Eastern Grid Blackout at 14:04. |
| 108 | Shajibazar 86MW PP (Shajibazar) | RPP | 32'2.90 | 86 | 78 | 877440 | 0 | 0 |
| 109 | Shajibazar 100 MW GTTP | PDB | 1'100 | 100 | 0 | 0 | 0 | Under maint. |
| 110 | Syhet 225 MW CCPP | PDB | 1'142+1'89 | 231 | 0 | 3079430 | 0 | Eastern Grid Blackout at 14:04. |
| 111 | Syhet 20 MW GTTP | PDB | 1'120 | 0 | 120 | 0 | 0 | Gas shortage |
| 112 | Syhet 50MW PP (EPL) | NENP | 27'2 | 50 | 14 | 138620 | 0 | Gas shortage |
| 113 | Shajahanulla 25 MW PP | SIPP, REB | 3'9.34 | 25 | 16 | 116160 | 0 | Gas shortage |
| 114 | Bitiana-II 341 MW CCPP (Summit) | IPP | 1'222+1'119 | 341 | 0 | 4496350 | 0 | Eastern Grid Blackout at 14:04. |
| 115 | Bitiyana-III 400 MW CCPP | PDB | 400 MW | 400 | 0 | 5549000 | 0 | Eastern Grid Blackout at 14:04. |
| 116 | Syhet (10MW PP -Desh) | RPP | 6'1.95 | 10 | 5 | 138660 | 0 | 0 |
| 117 | Bitiyana South 400 MW | PDB | 400 MW | 383 | 0 | 5553400 | 0 | Eastern Grid Blackout at 14:04. |
| Syhet Area Total | | | | 2477 | 214 | 22714278 | | |
| 118 | Bheramara GTTP Unit-3 | PDB | 1'20 | 16 | 0 | 0 | 0 | Fuel shortage |
| 119 | Bheramara (HVDC) | Imported power | 2'500 | 1000 | 855 | 2198545 | 0 | 0 |
| 120 | Khulna 115 PP MW (PKCL-2) | NENP | 7'17 | 115 | 16 | 125760 | 0 | Fuel shortage |
| 121 | Rajapur 50 MW Peaking PP | PDB | 8'6.98 | 50 | 28 | 226080 | 0 | Engine problem |
| 122 | Khulna 225 MW CCPP | NWPGCL | 1'150+1'175 | 230 | 229 | 2751360 | 0 | 0 |
| 123 | Gopalganj 100 MW Peaking PP | PDB | 16'6.98 | 109 | 64 | 673152 | 0 | Engine problem |
| 124 | Bheramara 410 MW CCPP | NWPGCL | 1'278+1'132 | 410 | 295 | 5395392 | 0 | Gas shortage |
| 125 | Noapara 40 MW PP (Khanjahan Aji) | NENP | 5'8.5 | 40 | 0 | 0 | 0 | Fuel shortage |
| 126 | Noapara 100 MW PP (Bangla Trac) | IPP | 70'1.4 | 100 | 10 | 353280 | 0 | Frequency control |
| 127 | Russha 105 MW PP (Non russha) | IPP | 6'18.45 | 105 | 57 | 1166880 | 0 | Engine problem |
| 128 | Madhumati 100 MW PP | NWPGCL | 8'18 | 105 | 32 | 566352 | 0 | Fuel shortage |
| 129 | Mongla Onon 100 MW Solar PP | IPP | 100 | 100 | 0 | 506160 | 0 | 0 |
| 130 | Khulna 330 MW CCPP (OIL) | BPDB | 1'220+1'110 | 0 | 0 | 0 | 0 | On test. |
| 131 | Rampal 1320 MW (BIFPCL) | NTPC&BPDB | 0 | 0 | 0 | 0 | 0 | On test. |
| Khulna Area Total | | | | 2384 | 1586 | 33582161 | | |
| 132 | Barisal 110 MW PP (Summit) | IPP | 7'17.076 | 110 | 64 | 566400 | 0 | Line OIL |
| 133 | Bhola 133 MW PP (Wwre) | NENP | 1'34.50 | 133 | 40 | 465000 | 0 | Engine problem |
| 134 | Bhola 225 MW CCPP | PDB | 2'63+1'68 | 194 | 30 | 369000 | 0 | Gas shortage |
| 135 | Bhola 95 MW PP (Agreko) | QRPP | 96'1.10 | 0 | 0 | 0 | 0 | Contract Expired |
| 136 | Payra 1320 MW | BCPCL | 2'622 | 1244 | 620 | 21442300 | 0 | Frequency control |
| 137 | Bhola Nutan Biddul BD LTD | IPP | 220 | | | | | |