

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9546667, 9551094

Month October, 2022				Day : Wednesday				Date : 05.10.22				
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 12398 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.71 ft				Today = 96.76 ft				
				Rule Curve = 106.36 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.10.22 (Yesterday)		05.10.22 (Today)		04.10.22 (Yesterday)		05.10.22 (Today)	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	220	100	220	220			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	0	0	0			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	89	93	93			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	286	95	340	250			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	155	0	0	0			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	135	50	300			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	120	50	50			
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	307	0	220	220			
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	0	0	0			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	20	30	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	50	24	80			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19			
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	52	49	49			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	26	26	26			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	41	49			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	64	132			
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	115	250	165	275			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	133	144	144			
26	Karaganga 300 MW PP (APRC)	HSD (IPP)	25x11.4	300	300	0	45	267	267			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	5	50	50			
28	Aurahiati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	100	100			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	0	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	55	55			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	72	17	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	37	54	54	54			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	48	41	80			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	24	80			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	2143	1779	2354	3079	0	845	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	150	150	150			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	10	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	39	27	40	43			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	102	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	223	37	150	150			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	196	175	195	285			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	31	11	11			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	68	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	21	0	8	24			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	0	16	16			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	27	20	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	26	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	84	105	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	38	10	10			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	33	10	10			
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	68	89	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			
Chattogram Zone Total				2442	2382	1057	876	1012	1148	0	330	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	33	37	37	37			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1775	221	221	165	0	35	35			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	160	225	210	200			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	350	0	210	200			
63	Ashuganj 420 MW CCGP(East) GT	Gas (APSCL)	1x284	284	284	0	0	0	0			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	53	45	45			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	185	8	8			
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	110	0	130	140			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	45	0	44			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	69	50	80	120			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	200	34	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	0	100	100			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	34	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	92	105	105	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	86	17	115			
**	Impoport (Tripura)	India		160	160	130	160	143	166			
Cumilla Zone Total				3193	3169	1378	1317	1359	1808	0	0	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	39	102	80	120			
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	22	20	20			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	56	83	80	84			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	114	77	110	160			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0			
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	55	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	296	296	354	396	0	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.10.22 (Yesterday)		05.10.22 (Today)		04.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	MW	Machines shut down (MW)		
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	29	30	30		41	GT-1 Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	0	0	0		90	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	39	47	47				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	110	110	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	0	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	20	64	64				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	78	78	78				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	220	0	0	0				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	5	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	24	24				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	0	0	0				
101	Bibiya-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	356	0	270	270				
102	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	384	0	50	300				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	5	14	20	20				
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	13	40	40				
Sylhet Zone Total				2522	2477	1448	214	754	1004	109	615		
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	205	295	250	250	115		Gas Shortage	
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	28	0	22				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	64	0	53				
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	229	120	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	10	50	94				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	57	55	75				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	32	15	32				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	30	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	926	855	948	948				
Khulna Zone Total				2388	2384	1332	1586	1554	1710	115	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	16	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	27	12	22				
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	30	40	40	164		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	890	620	1110	1110				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x8.78	150	150	0	35	0	0			Line Overload	
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	216	220	220	220				
Barishal Zone Total				1958	1958	1125	996	1398	1408	164	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	100	175				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	85				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24				
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	165	93	160	160				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	71	130	220	220		Running on HSD	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	122	170	170				
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	320	381	380	380				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	20	18	18				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	113	113	70	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	109	113	70	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total				2129	2129	1060	1192	1165	1577	391	0		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	0	0	0				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	63	100	34	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Maipara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	30	75				
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	5	0	12	0				
Rangpur Zone Total				830	750	322	175	164	268	0	85		
Sub-total: Plants in operation				22088	21710	10161.0	8431	10114	12398	779	1875		
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilla 108MW PP(ICC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Amfura 30 MW PP(Sinhal)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0				
Gross Total				22512	21710	10161	8431	10114	12398	779	1875		
(C) Actual data of 04.10.22 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13200	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12535	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10514	MW, at =	24:00	Dhaka	4501	2499	2002	Mymensingh	1111	446	665
04.	Minimum Generation (Generation end)	:	9533	MW, at =	7:00 hrs	Chattogram	1331	831	500	Sylhet	569	219	350
05.	Day-peak Generation (Generation end)	:	10161	MW, at =	12:00 hrs	Khulna	1481	1469	12	Barishal	323	323	0
06.	Evening-peak Generation (Generation end)	:	8431	MW, at =	21:00 hrs	Rajshahi	1248	1063	185	Rangpur	801	560	241
07.	Evening Peak Load-shed (Sub-station end)	:	4395	MW, at =	21:00 hrs	Cumilla	1170	730	440				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9293	MW, at =	5:00 hrs					Total	12535	8140	4395
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :		(a) Gas = 104987563 Taka	(c) Coal = 212162947 Taka				
	a) Gas limitation	:	779	MW				(b) Oil = 835238618 Taka	Total = 1152389128 Taka				
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	1875	MW		14. Maximum Temperature in Dhaka was :	29.5° C						
10.	Total Energy (Generation + India Import)	:	206.61	MKWh		15. Export through East-West interconnections :							
	By Gas = 92.144 MKWh	By Oil = 60.136 MKWh											
	By Coal = 25.028 MKWh	By Hydro = 2.966 MKWh											
	By Solar= 1.265 MKWh												
11.	Total Gas Supplied	:	765.40	MMCFD									
(D) Forecast of 05.10.22 (Today) Wednesday :													
01.	Maximum Demand	:	13000	MW (Generation end)	04. Maximum Load-shed	:	555	MW	At	evening peak (Sub-station end)			
02.	Maximum Generation	:	12398	MW (Generation end)	05. Total Generation	:	255.46	MKWh					
03.	Reserve / Shortage	:	-602	MW (Generation end)	06. Probable Max. Temperature in Dhaka :	34.1 ° C							