

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022					Day : Thursday				Date : 06.10.22					
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 12808 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 96.76 ft		Today = 97.10 ft		Rule Curve = 106.45 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.10.22 (Yesterday)		06.10.22 (Today)		05.10.22 (Yesterday)		06.10.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Machines shut down			
					Day	Evening	Day	Evening	MW	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	215	211	220	220					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0					
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	97	97	97					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Under maint.	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	313	148	250	250					
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	215	215	215					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	285	343	380	380					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	39	0	0	0					
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	216	85	160	160					
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	30	30	30	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	66	16	64					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	52	49	49					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	22	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	40	32	49					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	129	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	178	293	115	290					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	108	144	72	144					
26	Karimganj 300 MW PP (APRC)	HSD (IPP)	25x11.4	300	300	266	267	250	270					
27	Bramhanganj 100 MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	50	50	50					
28	Aurahiati 100MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	94	96	90	95					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	56	55	55					
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162					
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	35	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	54	54					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	50	25	50					
36	Meghnaghat 100 MW(UEL)	HFO (NENP)	12x8.9	100	100	16	75	24	80					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total				6004	5847	2466	2998	2519	3231	0	845			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	100	147	147	147				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	43	43					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105					
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	150	150	40	220					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	196	300	195	290					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	11	25	11	11					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	8	20	20	20					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			22	38	15	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	25	10	10					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	22	10	10					
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0					
Chattogram Zone Total				2442	2382	948	1216	927	1216	0	330			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0					
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	37	37	37	37					
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1775	221	221	44	140	80	80					
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	190	240	140	140					
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	150	15	280	280					
63	Ashuganj 420 MW CCGP(East) GT	Gas (APSCL)	1x284	284	284	3	9	0	0					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	40	53	50	50					
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8					
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	100	130	135	140					
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	27	30	40	44					
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	30	80	80					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	200	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	25	25					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	80	112	100	110					
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	114	114	114					
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	57	112	55	113					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	115	17	115					
**	Imporpt (Tripura)	India		160	160	136	164	143	166					
Cumilla Zone Total				3193	3169	1162	1514	1650	1848	0	0			
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	72	106	70	110					
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	16	16	16					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	78	80	84					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	115	163	110	160					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0							

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.10.22 (Yesterday)		06.10.22 (Today)		05.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	MW	Machines shut down (MW)				
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.			
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.			
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	50	51	51						
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	113	113	110	110	109	54	STG Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	65	65	65						
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	80	80						
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0						
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	16	24	24						
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0						
101	Bibiyan-Ill 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	290	280	80	400						
102	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	25	370	400	400						
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	24	24	20	20						
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	47	39	40	40						
Sylhet Zone Total				2522	2477	769	1088	921	1241	109	614				
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CCPP	Gas (NWPGLCL)	1 x 278+1 x 132	410	410	250	215	220	220	195		Gas Shortage			
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	0	32						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	75	0	70						
110	Khulna 225 MW CCPP	HSD (NWPGLCL)	1 x 150+1x75	230	230	120	226	120	220						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	45	50	94						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	72	35	70						
113	Madhumati 100 MW PP	HFO (NWPGLCL)	6x18.415	105	105	15	15	15	15						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	100	0	100	0						
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16						
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0						
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0						
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0						
**	Bheramara (HVDC)	India		1000	1000	931	930	944	944						
Khulna Zone Total				2388	2384	1416	1626	1500	1681	195	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	12	22						
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	40	40	50	50	154		Gas Shortage			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	770	1030	1110	1110						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload			
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	191	193	220	220						
Barishal Zone Total				1958	1958	1035	1322	1408	1434	154	0				
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	88	100	175						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	0	85						
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24						
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42						
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	26						
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGLCL)	1x150+1x75	210	210	170	163	170	160						
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGLCL)	1x150 + 1x75	220	220	178	217	130	220	220		Running on HSD			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGLCL)	1x141+1x79	220	220	173	148	150	150						
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	418	338	335	330						
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	18	18						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8						
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	50	113	113	113						
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	37	113	113	113						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGLCL)	1x6	6	6	6	0	6	0						
Rajshahi Zone Total				2129	2129	1061	1426	1188	1507	391	0				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	79	80	80						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0						
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	43	71	55	113						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Maipara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	37	75	30	75						
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	12	0						
Rangpur Zone Total				830	750	192	225	185	268	0	85				
Sub-total: Plants in operation				22088	21710	9390.0	11790	10638	12808	849	1874				
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilla 108MW PP(ICC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020			
154	Amfura 30 MW PP(Sinhal)	HFO (QRPP)	7x7.79	30	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0						
Gross Total				22512	21710	9390	11790	10638	12808	849	1874				
(C) Actual data of 05.10.22 (Yesterday) Wednesday :															
01.	Max. Demand at eve. peak (Generation end)	:	13282	MW,	at =	20:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12694	MW,	at =	20:00	hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11790	MW,	at =	20:00	hrs	Dhaka	4620	3908	712	Mymensingh	1078	848	230
04.	Minimum Generation (Generation end)	:	9279	MW,	at =	9:00	hrs	Chattogram	1197	1197	0	Sylhet	565	466	99
05.	Day-peak Generation (Generation end)	:	9390	MW,	at =	12:00	hrs	Khulna	1493	1493	0	Barishal	372	372	0
06.	Evening-peak Generation (Generation end)	:	11790	MW,	at =	20:00	hrs	Rajshahi	1285	1285	0	Rangpur	810	676	134
07.	Evening Peak Load-shed (Sub-station end)	:	1375	MW,	at =	20:00	hrs	Cumilla	1275	1075	200				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9738	MW,	at =	5:00	hrs					Total	12694	11319	1375
09.	Generation shortfall at evening peak due to :	:						13.	Fuel cost :	(a) Gas = 123791627 Taka	(c) Coal = 224123646 Taka				
	a) Gas limitation	:	849	MW					(b) Oil = 1231317834 Taka		Total = 1579233107 Taka				
	d) Coal supply Limitation	:	0	MW											
	b) Low water level in Kaptai lake	:	0	MW											
	c) Plants under shut down/ maintenance	:	1874	MW											
10.	Total Energy (Generation + India Import)	:	248.00	MKWh				14.	Maximum Temperature in Dhaka was :	34.0° C					
	By Gas = 106.691 MKWh				By Oil = 85.216 MKWh			15.	Export through East-West interconnections :						
	By Coal = 25.395 MKWh				By Hydro = 3.280 MKWh				At evening peak-hour	:	9390	MW,	at	20:00	hrs