

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 6-Oct-22									Page 2
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks		
				Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CCPP Unit-3 (GT	PDB	1'260	260	0	0	Under maint.		
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	130	4403000	Line O/L		
3	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.		
	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired		
4	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	94	2205909	Engine problem		
5	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.		
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	315	8927230	Gas shortage		
7	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	163	5004000	Gas shortage		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	175	4456000	Gas shortage		
9	Meghnaghat 100 MW(IEL)	NENP	12'8.9	100	83	820800	Engine problem		
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	0	0	Gas shortage		
11	Madanganj 102 PP(Summit)	NENP	6'17	102	0	0	Under maint.		
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	30	734988	Fuel shortage		
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired		
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	304740	Engine problem		
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.		
16	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage		
17	Siddhirganj 100 PP(Dutch Bangla)	NENP	12'8.9	100	49	667200	Fuel shortage		
18	Siddhirganj 335 MW CCPP	EGCB	1'217+118	335	131	3123820	Gas shortage		
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	67	688464	Fuel shortage		
20	Katpolti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage		
21	Kamalgahat 54 MW PP(Banco Energy)	IPP	3'18	54	54	466200			
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	115	1400640	Fuel shortage		
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	551685	Fuel shortage		
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	544662			
25	Bosila 108MW PP(CLLC)	IPP	12'8.775+1'3.5	0	0	0			
26	Summit Power (Madhabdi-Ashulia)	SIPP, REB	3'3.67+4'8.73	80	48	1162880	Engine problem		
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	609300	Engine problem		
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	16	513200	Engine problem		
29	Gazipur 52 MW PP	PDB	6'8.9	52	48	901920	#REF!		
30	Tongi 80 MW GTPP	RPCL	1' 105	105	0	0	Under maint.		
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	290	3828873	Engine problem		
32	Keraniganj 300 MW PP (ABR)	IPP	258'1.4	300	250	4854549	Engine problem		
33	Bramhangonj 100 MW PP (Aggreko)	IPP	114'0.959	100	50	1178964	Fuel shortage		
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	95	2057227	Engine problem		
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	108	1818288	Engine problem		
36	Gazipur 100 MW PP	RPCL	6'17.5	105	88	2154000	Engine problem		
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	72	1002240	Fuel shortage		
38	Manikganj 162MW PP(MPGL)	IPP	9'18	162	156	829440			
39	Spectra Solar Plant Ltd.	IPP	35	35	0	171541			
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4'3	55	54	816840			
Dhaka area Total				5847	2815	56198400			
41	Chattogram TPP-1	PDB	1'210	180	0	0	Machine problem		
	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage		
42	Raozan 25 MW PP	RPCL	3'8.9	25	25	539866			
43	Teknaf 20MW PP (Solarteck)	IPP	20	20	0	100980			
44	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	44	1056480	Engine problem		
45	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2'40+3'50	230	146	3521256	Low water level		
46	Sikalbaha 225MW	PDB	1'150+1'175	225	230	3725167	ST under S/D		
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.		
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	2542545			
49	Hafizazari 100 MW peaking PP	PDB	11'8.9	98	23	423408	Fuel shortage		
50	Dohazari-Katish 100 MW Peaking	PDB	8'17	102	51	616846	Fuel shortage		
51	Juidah 100 MW Unit-1 (Acorn)	NENP	8'13.45	100	10	254280	Fuel shortage		
52	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8'13.5	100	11	267840	Fuel shortage		
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	16	388704	Engine problem		
*	Malancha, Ctg. EPZ (Unlited)		5'8.73+3'9.34	0	27	587040			
54	Chattogram 108 MW PP (ECVP)	IPP	16'7	108	0	0	Fuel shortage		
55	Kaptai 7 MW Solar PP	PDB	7.4	7	0	28441			
56	Anwara 300 MW PP (Unlited)	IPP	17'17+24	300	300	5085527			
57	Jodai Power	IPP	3'18.55+1'3.6	54	36	789686	Engine problem		
58	Karnaphuli Power Ltd.	IPP	18.415'6+6.5	110	105	2548389			
59	Juidah unit-2 (Acorn)	IPP	8'13.6	100	10	252480	Engine problem		
60	Anlima Energy Ltd.	IPP	6'21.2	116	107	2579345	Engine problem		
Mirshara 150 MW				BPDB-RPCL	18.5'9	0	On test.		
Chattogram area Total					1246	25306580			
61	Ashuganj TPP Unit- 3	APSCL	1'1150	0	0	0	Contract Expired		
	Ashuganj TPP Unit- 4	APSCL	1'1150	0	0	0	Contract Expired		
	Ashuganj TPP Unit- 5	APSCL	1'1150	134	0	0	Gas shortage		
62	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	109	2082000	#REF!		
63	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	280	7159500	Gas shortage		
64	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	40	2358000	Gas shortage		
	Ashuganj 420 MW CCPP(East)	APSCL	284'1+136'1	284	9	345000	On test		
65	Ashuganj 50 MW PP	APSCL	14'3.968	45	36	840898	Engine problem		
66	Ashuganj 55 MW PP (Precision)	QRPP	15'4	55	35	1080960	Gas shortage		
67	Ashuganj 195MW PP (APSCL-Unlited)	IPP	20'9.73+1'16	195	8	200727	Gas shortage		
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1167130			
69	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	120	2955709	Engine problem		
70	Titas 50 MW Peaking PP	PDB	6'8.9.6	50	44	92328	Engine problem		
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	82	1959810	Machine problem		
72	Chandpur 200MW (Desh energy)	IPP	12'18.4	200	200	4459200			
73	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	500436			
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	9	210960	Engine problem		
**	Import (Tripura)	Imported power	0	160	156	3283200			
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	470400	Engine problem		
76	Jangalia 52 MW PP (Lakshnaw)	IPP	8'8.92	52	43	562571	Fuel shortage		
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	483800	Engine problem		
78	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	106	2566672	Fuel shortage		
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	96	1810320	Fuel shortage		
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	117	1765680			
81	Bhairab 54.5 MW	IPP	3'18.2	54	35	886680	Engine problem		
82	Chandpur 115(Doreen)	IPP	4'18.5+2'22.5	115	71	870720	Fuel shortage		
Cumilla Area Total				3169	1715	38952691			
83	RPCL 210MW CCPP	IPP	4'95+1'70	202	100	2393280	Gas shortage		
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	13	357192	Engine problem		
85	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0	Under maint.		
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	11900			
87	Mymensingh 200 MW PP (Unlited)	IPP	9'8.721	200	162	3002400	Fuel shortage		
88	Jamalpur 115 MW PP (Unlited)	IPP	9'8.712	115	88	1861200	Engine problem		
89	Sulatakhal 50 MW Solar PP	IPP	50	50	0	274450			
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	12	298560	Engine problem		
Mymensingh Area Total				614	375	8198982			
91	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	30	712000	Machine problem		
92	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	0	58920	Machine problem		
93	Kushmara 163 MW CCPP (KP)	IPP	1'109+1'54	163	113	2651481	ST under maint		
94	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.		
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1259400			
	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	45	1012536			
96	Hobiganj 11MW PP Confidene-E	SIPP, REB	4'2.90	11	11	238100			
97	Shajibazar GTPP Unit- 8 & 9	PDB	2'35	66	65	1536576			
98	Shajibazar 86MW PP (Shajibazar)	RPP	3'2.90	86	81	1950720			
99	Shajibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.		
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	0	0	Under maint.		
101	Sylhet 20 MW GTPP	PDB	1'20	20	0	0	Gas shortage		
	Sylhet 50MW PP (EPL)	NENP	27'2	50	24	560940	Gas shortage		
102	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	482400	Gas shortage		
103	Bibiiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	1920500	FGMO		
104	Bibiyan-III 400 MW CCPP	PDB	400 MW	400	402	5600000			
105	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	9	198540			
106	Bibiyan South 400 MW	PDB	400 MW	383	400	9498200			
Sylhet Area Total				2477	1529	27680313			
107	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Fuel shortage		
**	Bheramara (HVDC)	Imported power	2'500	1000	925	22442909			
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	16	96000	Fuel shortage		
109	Fandipur 50 MW Peaking PP	PDB	8'6.88	54	22	34100	Engine problem		
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'75	230	180	3924480	Line O/L		
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	70	489472	Engine problem		
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	235	5373504	Gas shortage		
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	8625	Fuel shortage		
113	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	66240	Line O/L		
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	76	1160640	Fuel shortage		
115	Madhumati 100 MW PP	NWPGCL	6'18	105	15	421056	Fuel shortage		
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	325440			
	Khulna 330 MW CCPP (OIL)	BPDB	1'220+1'110	0	0	0	On test.		
	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.		
Khulna Area Total				2384	1539	34485486			
117									