

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022				Day : Sunday				Date : 09.10.22				
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 12925 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.92 ft Today = 97.99 ft				Rule Curve = 106.72 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.10.22 (Yesterday)		09.10.22 (Today)		08.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	87	95	95	95			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Hanpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired	
7	Hanpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	339	335	340			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hanpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	280	412	Gas Shortage	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	206	208	217	217		STG Under maint.	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15	40	Fuel oil shortage	
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	84	32	84			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	19	19			
17	Summit Power(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x1.67+1x4.73	80	80	51	49	52	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	13	14	30	30			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	40	41	41			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	88	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	32	130			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	180	291	115	290			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	52	16	50			
26	Keraniganj 300 MW PP (ABR)	HSD (IPP)	25x81.4	300	300	105	156	100	156			
27	Birangbanjan 100 MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50			
28	Aunahat 100MW PP (Agreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	47	92	55	92			
32	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	66	162	72	162			
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	54	54	54			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	25	32	17	32	68	Fuel oil shortage	
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	29	74	24	80			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total				6004	5847	1885	2606	1848	2945	1370	845	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	150	151	151		Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	43	43			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	105	87	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	224	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	195	285	195	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	20	20	20	20	80	Fuel oil shortage	
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51	51	Fuel oil shortage	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	30	23	30			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			6	23	27	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	31	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	88	105	105	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	20	20	20	80	Fuel oil shortage	
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22	78	Fuel oil shortage	
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	91	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			
Chattogram Zone Total				2442	2382	1043	1263	1139	1286	577	330	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	40	37	40			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	198	206	180	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	340	310	310			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	340	320	320			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	10	10	284	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	30	30	30			
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	110	108	110	120			
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	27	36	37	37			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	82	80	80			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	25	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	52	43	52			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.06	200	200	0	60	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	99	98	114			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	28	29	9	9			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	35	54			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	76	17	76			
**	Import (Tirupura)	India		160	160	136	164	143	166			
Cumilla Zone Total				3193	3169	1644	2042	1795	2054	471	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	37	70	85	100	132	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	87	107	108	108			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	95	141	86	155	59	Fuel oil shortage	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
87	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	300	343	359	391	191	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.10.22 (Yesterday)		09.10.22 (Today)		08.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening					MW			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.					
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.					
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	10	10	46		Gas Shortage					
91	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	0	11	11	11		Gas Shortage					
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	57	65	65								
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80								
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140								
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10								
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	330	310	310								
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	404	400	400								
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	395	400	400								
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage					
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	5	5	10	10	45		Gas Shortage					
Sylhet Zone Total				2522	2477	1389	1486	1426	1496	306	584						
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
107	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	210	220	220	210	190		Gas Shortage					
108	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	0	32								
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	78	0	78								
110	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	220	120	220								
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	0	50								
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	1	75	35	75	30		Fuel oil shortage					
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	0	67	38		Fuel oil shortage					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	100	0								
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16	99		Fuel oil shortage					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel oil shortage					
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0								
	Khulna 330 MW CCPP	Gas/HSD (BPDB)				0	0	0	0								
**	Bheramara (HVC)	India		1000	1000	928	929	947	947								
Khulna Zone Total				2388	2384	1369	1652	1438	1695	397	0						
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	32								
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	17	22								
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	20	83	86	86	111		Gas Shortage					
120	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	840	990	1000	1000								
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			Line Overload					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	219	218	165	220								
Barishal Zone Total				1958	1958	1113	1334	1284	1360	111	0						
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage					
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	32								
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	10	0	100								
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0								
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	84	0	85								
128	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	24								
129	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	0	0								
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	26								
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	170	166	178	180	44		Gas Shortage					
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	215	160	220	220		Running on HSD					
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	154	166	166	66		Gas Shortage					
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	308	334	330	330	80		Gas Shortage					
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22								
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8								
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	113	50	113								
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	113	35	113								
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0								
Rajshahi Zone Total				2129	2129	845	1296	958	1430	581	0						
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	80	80		85	Under Overhauling					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0								
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0								
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	113	56	113								
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
146	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0								
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	0	75								
148	Lalmourihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	12	0								
Rangpur Zone Total				830	750	149	267	156	268	0	85						
Sub-total: Plants in operation				22088	21710	9737.0	12289	10403	12925	4004	1844						
(B) Plants under long term maintenance/ contract expired																	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
151	Bosila 108MW PP(CPCLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0								
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020					
154	Amirnara 30 MW PP(Sinhi)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022					
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0								
Gross Total				22512	21710	9737	12289	10403	12925	4004	1844						
(C) Actual data of 08.10.22 (Yesterday) Saturday :																	
01.	Max. Demand at eve. peak (Generation end)	:	13872	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	13250	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	12289	MW, at =	19:30 hrs	Dhaka	4763	4163	600	Mymensingh	1134	779	355				
04.	Minimum Generation (Generation end)	:	9561	MW, at =	9:00 hrs	Chattogram	1366	1088	278	Sylhet	608	441	167				
05.	Day-peak Generation (Generation end)	:	9737	MW, at =	12:00 hrs	Khulna	1607	1607	0	Barishal	357	357	0				
06.	Evening-peak Generation (Generation end)	:	12289	MW, at =	19:30 hrs	Rajshahi	1322	1304	18	Rangpur	741	741	0				
07.	Evening Peak Load-shed (Sub-station end)	:	1459	MW, at =	19:30 hrs	Cumilla	1353	1312	41								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9522	MW, at =	5:00 hrs					Total	13250	11791	1459				
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :		(a) Gas = 137464394 Taka	(c) Coal = 223154719 Taka								
	a) Gas/LF limitation	:	4004	MW				(b) Oil = 1039926640 Taka	Total = 1400545754 Taka								
	d) Coal supply Limitation	:	0	MW													
	b) Low water level in Kaptai lake	:	0	MW													
	c) Plants under shut down/ maintenance	:	1844	MW													
10.	Total Energy (Generation + India Import)	:	255.67	MKWh		14. Maximum Temperature in Dhaka was :	35.5° C										
	By Gas = 124.537 MKWh			By Oil = 74.354 MKWh		15. Export through East-West interconnections :											
	By Coal = 25.445 MKWh			By Hydro = 3.638 MKWh		At evening peak-hour	:	9737	MW, at	19:30 hrs							
	By Solar= 1.681 MKWh					Maximum	:	665	MW, at	18:00 hrs							
11.	Total Gas Supplied	:	946.85	MMCFD		Energy	:	0	MKWh								
(D) Forecast of 09.10.22 (Today) Sunday :																	
01.	Maximum Demand	:	13800	MW	(Generation end)	04.	Maximum Load-shed	:	807	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	12925	MW	(Generation end)	05.	Total Generation	:	287.11	MKWh							
03.	Reserve / Shortage	:	-875	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	33.9° C									