

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month October, 2022				Day: Monday				Date: 10.10.22			
Probable Maximum Demand: 14200 MW				Probable Maximum Generation: 12686 MW				Rule Curve = 106.72 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.99 ft				Today = 98.12 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.10.22 (Yesterday)		10.10.22 (Today)		09.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	100	100	100	100	80	Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	88	96	92	92		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	332	250	250		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	350	300	300	100	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	300	300	412	Gas Shortage
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	34	0	0	176	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	201	216	215	215		STG Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15	40	Fuel oil shortage
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	84	32	84		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	52	52	52	52		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	24	24	24		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	32	40	40	40		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	78	132	32	130		
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	54	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	243	275	115	275		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	53	16	50		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	152	100	156		
27	Bramhangaan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50		
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	0	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	17	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	56	76	55	90		
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	70	162	72	162		
33	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	51	54	54	54		
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	17	17	17	17	83	Fuel oil shortage
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	33	80	24	80		
37	Madanganj 102 PP (Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	1883	2635	2163	2890	1226	1035
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	153	152	145	145		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	43	43		
44	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	229	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	195	268	195	265		
48	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	20	31	20	30	69	Fuel oil shortage
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	10	51	17	51	51	Fuel oil shortage
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	22	22	22	22		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
53	Sikalbaha 54 MW PP (Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	31	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	105	105		
55	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	20	38	10	10	62	Fuel oil shortage
56	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	22	33	10	10	67	Fuel oil shortage
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	107	107	107		
58	Mirsharal 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		
Chattogram Zone Total				2442	2382	1111	1295	1111	1215	537	330
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0		
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	36	40	37	40		
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	156	212	170	200		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	335	270	280	280		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	345	280	280	280		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	10	10	10		
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	113	113	110	113		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	43	30	44		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	82	83	80	80		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.058	200	200	0	100	0	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	98	98	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	28	9	28		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	35	54		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	75	17	75		
**	Import (Tripura)	India		160	160	140	168	143	166		
Cumilla Zone Total				3193	3169	1687	1918	1643	1972	471	0
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	69	108	70	100	94	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	16	16		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	108	108	108		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	87	134	86	150	66	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	28	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	309	375	344	386	160	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.10.22 (Yesterday)		10.10.22 (Today)		09.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	MW			
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	21	41	40	40		49	G1-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	5	5	5	5	46		Gas Shortage	
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	63	65	65				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	270	280	280				
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	410	408	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	397	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	5	5	5	5	45		Gas Shortage	
Sylhet Zone Total													
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	230	230	230	180		Gas Shortage	
108	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	0	27				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	57	0	56				
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	40	220	120	220				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	10	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	86	35	93	19		Fuel oil shortage	
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	0	67	38		Fuel oil shortage	
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	96	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16	99		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0	40		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC) India		1000	1000	930	930	936	936					
Khulna Zone Total													
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	28	12	20				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	84	87	86	86	107		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	610	1050	1000	1050				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	6x18.415+1x9.78	150	150	0	0	0	0			Line Overload	
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	201	222	222	222				
Barishal Zone Total													
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	82				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	24				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	25				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	168	186	170	180	24		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	190	130	200	220		Running on HSD	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	161	163	161	59		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	398	356	330	330	58		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	21	21				
136	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	60	113	113	113				
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	113	113	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
Rajshahi Zone Total													
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	80	80	80				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0				
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	56	113	56	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Haopara, Taulia 51MW Solar PP (Simpa Power)	Solar (IPP)	1 x 9	9	9	0	0	8	0				
147	Thakurgaon 119MW PP (Energygas)	HFO (IPP)	6*20	115	115	0	76	0	75				
148	lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	12	0				
Rangpur Zone Total													
Sub-total: Plants in operation													
22088 21710 9703.0 12383 10643 12686 3704 2023													
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Boogra 20 MW PP (Energyprime)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammhura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired													
424 0 0 0 0 0 0 0 0													
Gross Total													
22512 21710 9703 12383 10643 12686 3704 2023													
(C) Actual data of 09.10.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 13452 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 12826 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 12383 MW, at = 21:00 hrs											
04.	Minimum Generation (Generation end)	: 9440 MW, at = 9:00 hrs											
05.	Day-peak Generation (Generation end)	: 9703 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 12383 MW, at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 985 MW, at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9990 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 3704 MW											
d)	Coal supply Limitation	: 0 MW											
b)	Low water level in Kaptai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2023 MW											
10.	Total Energy (Generation + India Import)	: 252.76 MCKWh											
	By Gas = 123.648 MKWh	By Oil = 74.090 MKWh											
	By Coal = 24.105 MKWh	By Hydro = 3.661 MKWh											
	By Solar = 1.320 MKWh												
11.	Total Gas Supplied	: 991.34 MCKWh											
(D) Forecast of 10.10.22 (Today) Monday :													
01.	Maximum Demand	: 14200 MW (Generation end)											
02.	Maximum Generation	: 12686 MW (Generation end)											
03.	Reserve / Shortage	: -1514 MW (Generation end)											
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	4515	4159	356	Mymensingh	1113	851	262					
	Chattogram	1256	1256	0	Sylhet	567	456	111					
	Khulna	1606	1606	0	Barishal	368	368	0					
	Rajshahi	1373	1373	0	Rangpur	719	719	0					
	Cumilla	1311	1055	256									
					Total	12826	11841	985					
13.	Fuel cost :												
	(a) Gas = 137164019 Taka	(c) Coal = 212593404 Taka											
	(b) Oil = 1026090862 Taka	Total = 1375848284 Taka											
14.	Maximum Temperature in Dhaka was :	34.4° C											
15.	Export through East-West interconnections :												
	At evening peak-hour	: 9703 MW, at 21:00 hrs											
	Maximum	: 370 MW, at 18:00 hrs											
	Energy	: 0 MCKWh											
(E) Maximum Load-shed : 1395 MW At evening peak (Sub-station end)													
04. Total Generation : 289.85 MCKWh													
05. Probable Max. Temperature in Dhaka : 33.4° C													

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation