

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022					Day : Tuesday				Date : 11.10.22					
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 12867 MW				Rule Curve = 106.90 ft.					
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.12 ft				Today = 98.53 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.10.22 (Yesterday)		11.10.22 (Today)		10.10.22 (Yesterday)		11.10.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	(MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	160	100	100					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	50	110	110					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.		
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	92	89	92					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	291	231	270	240	129		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	285	225	225	225	225		Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	340	401	400	380					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	216	195	210	190			STG Under maint.		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	45	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	83	48	8	16	54		Fuel Oil Shortage		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	50	49	51	51					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	19	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	42	40	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	132	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	240	293	250	295					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	90	90	90	59		Fuel Oil Shortage		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	154	0	150					
27	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	92	0	50					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	85	74	54	74	30		Fuel Oil Shortage		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	162	90	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	0	0	0					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	94	40	0	8	60		Fuel oil shortage		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	75	83	16	72	17		Fuel oil shortage		
37	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total					6004	5847	2498	2998	2403	2885	1119	845		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	155	155	155			Unit 1 under rehabilitation		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	43	43					
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	105	105	87	105					
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	229	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	195	282	195	285					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	21	63	63	76	37		Fuel oil shortage		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51	51		Fuel oil shortage		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	22	22	22	22					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16					
*	Malancha, Ctp EP2 (United)	Gas	5x8.73+3x9.34			3	8	10	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	0	96		Fuel oil shortage		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	36	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	105	105	88	105					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	76	70	70	24		Fuel oil shortage		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	66	66	66	34		Fuel oil shortage		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0					
Chattogram Zone Total					2442	2382	1141	1420	1250	1425	422	330		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	36	50	37	40					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	204	161	200	170	60		Gas Shortage		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	275	280	300	85		Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	320	270	300					
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284		Gas Shortage		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	10	10	5	5	45		Gas Shortage		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	112	120	115	120					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	44	44	35	44					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	82	82	82					
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	200	50	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	9	9	9					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	25	25	25					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	8	52					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.058	200	200	0	100	0	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	112	0	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9	104		Fuel Oil Shortage		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	39	54	35	54					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	115	35	115					
**	Import (Tripura)	India		160	160	152	168	143	166					
Cumilla Zone Total					3193	3169	1447	2008	1440	2007	899	0		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	42	100	42	100	102		Gas Shortage		
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	16	16					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	108	105	105					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	85	143	100	145	57		Fuel oil shortage		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
86	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	55	0	50	0					
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total					622	614	306	376	327	378	150	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.10.22 (Yesterday)		11.10.22 (Today)		10.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/Coal/oil/ Water Limitation	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 Under maint.	
89	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	40	40	48	GT-4 Under maint.	
90	Fenchugonj	51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5	46	Gas Shortage	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	STG Under maint.	
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	0	0	0	11	Gas Shortage	
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	60	60	60			
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar	66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80			
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140	91	ST Under maint.	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Gas Shortage	
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0	17	Gas Shortage	
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	320	300	300			
101	Bibiyan-II	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	409	400	400			
102	Bibiyan South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
103	Shahjibazar	100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Sylhet	50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50	Gas Shortage	
105	Fenchugonj	44MW (Energyprime)	Gas (NENP)	12'3.3-5'2	50	50	5	5	5	5	45	Gas Shortage	
Sylhet Zone Total						2522	2477	1416	1510	1400	1470	298	663
106	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	230	215	210	210	195	Gas Shortage	
108	Fairpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0	40	15	Fuel oil shortage	
109	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	66	0	60	43	Fuel oil shortage	
110	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	222	120	220			
111	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	0	50			
112	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	75	35	90	30	Fuel oil shortage	
113	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	15	50	55	Fuel oil shortage	
114	Mongla Orion	100 MW Solar PP	Solar (IPP)		100	100	80	0	100	0			
115	Khulna	115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16	99	Fuel oil shortage	
116	Noapara	40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40	Fuel oil shortage	
	Rampal	1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna	330 MW CCPP	Gas/HSD (BPDF)				0	0	0	0			
**	Bheramara (HVCDC)	India		1000	1000	919	914	935	935				
Khulna Zone Total						2388	2384	1381	1607	1431	1671	477	0
117	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16	94	Line Overload	
118	Bhola	33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	16	20			
119	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	87	88	86	86	106	Gas Shortage	
120	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	690	1020	1000	1050			
121	Potukhalhi	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0	150	Line Overload	
122	Bhola	220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	220	222	222			
Barishal Zone Total						1958	1958	1018	1371	1340	1394	106	244
123	a) Baghabari	71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari	100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
124	Baghabari	50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			
125	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	11	0	100			
126	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0	71	Under maint.	
127	Chapainawabganj	100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	85	0	82			
128	Katakhali	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24			
129	Katakhali	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50	Fuel Oil Shortage	
130	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	25			
131	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	160	185	170	170			
132	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	213	130	200	220	Running on HSD	
133	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	146	156	150	150	64	Gas Shortage	
134	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	360	345	320	320	69	Gas Shortage	
135	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	21	21			
136	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
137	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8	44	Fuel Oil Shortage	
138	Bagura	113 MW (Confidence) U-1	HFO (IPP)	6'x18.55	113	113	50	113	113	113			
139	Bagura	113 MW PP (Confidence) U-2	HFO (IPP)	6'x18.55	113	113	39	113	113	113			
140	Sirajgonj	6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total						2129	2129	907	1342	1034	1369	618	71
141	a) Barapukuria	TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	80	80	80	85	Under Overhauling	
	b) Barapukuria	TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	274	Under maint.	
142	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0			
143	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	48	113	56	113			
145	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara	Tatulia 5 MW Solar PP (Sympha Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0			
147	Thakurgaon	119MW PP (Energyprime)	HFO (IPP)	6'x20	115	115	0	76	0	75			
148	Almonirhat	30 MW Solar (Intraco)	Solar (IPP)	1'x30	30	30	10	0	12	0			
Rangpur Zone Total						830	750	142	269	156	268	0	359
Sub-total: Plants in operation						22088	21710	10256.0	12901	10781	12867	4098	2512
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur	95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti	52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosila	108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj	100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Bogura	20 MW PP (Energyprime)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Amhura	30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0		
Gross Total						22512	21710	10256	12901	10781	12867	4098	2512
(C) Actual data of 10.10.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	13923	MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13358	MW, at =	20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12901	MW, at =	20:00 hrs	Dhaka	4867	4485	382	Mymensingh	1139	930	209
04.	Minimum Generation (Generation end)	:	9839	MW, at =	9:00 hrs	Chattogram	1262	1262	0	Sylhet	549	499	50
05.	Day-peak Generation (Generation end)	:	10256	MW, at =	12:00 hrs	Khulna	1612	1612	0	Barisal	369	369	0
06.	Evening-peak Generation (Generation end)	:	12901	MW, at =	20:00 hrs	Rajshahi	1371	1371	0	Rangpur	851	782	69
07.	Evening Peak Load-shed (Sub-station end)	:	942	MW, at =	20:00 hrs	Cumilla	1340	1108	232				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9961	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :						
	a) Gas/LF limitation	:	4098	MW			(a) Gas =	144997938	Taka	(c) Coal =	223966660	Taka	
	d) Coal supply Limitation	:	0	MW			(b) Oil =	1056797754	Taka	Total =	1425762351	Taka	
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2512	MW		14.	Maximum Temperature in Dhaka was :						
	10. Total Energy (Generation + India Import)	:	265.37	MKWh						32.3° C			
	By Gas =	132.182	MKWh	By Oil =	76.891	MKWh	15.	Export through East-West interconnections :					
	By Coal =	25.546	MKWh	By Hydro =	3.423	MKWh		At evening peak-hour	:	10256	MW, at	20:00 hrs	
	By Solar =	1.475	MKWh					Maximum	:	370	MW, at	18:00 hrs	
11.	Total Gas Supplied	:	999.99	MMCFD				Energy	:	0	MKWh		
(D) Forecast of 11.10.22 (Today) Tuesday :													
01.	Maximum Demand	:	14200	MW	(Generation end)	04.	Maximum Load-shed						
02.	Maximum Generation	:	12867	MW	(Generation end)	05.	Total Generation						
03.	Reserve / Shortage	:	-1333	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :						