

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month October, 2022					Day : Thursday				Date : 13.10.22				
Probable Maximum Demand : 12800 MW					Probable Maximum Generation : 12962 MW					Rule Curve = 107.00 ft.			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.58 ft		Today = 98.61 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.10.22 (Yesterday)		13.10.22 (Today)		12.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)			
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	90	0	0	0				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	62	78	75	79				
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	293	288	300	300				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	403	400	400				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	211	200	200	200		STG Under maint.		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	48	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	80	8	80				
16	Narshingsi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	19	19				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	28	50	50	50				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	25	25				
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	14	15	15				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	49	40	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	116	64	116				
23	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	268	295	250	295				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	90	144	90	90				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	300	34	200	150				
27	Bramhangsan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	50	100	50				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	50	100	50				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	93	17	93				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	162	90	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	2	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	0	0				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	89	8	89				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	15	75	15	75				
37	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0				
Dhaka Zone Total					6004	5847	2823	2940	2651	3037	435	1180	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	155	154	154			Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	44	25	44				
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	95	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	228	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	177	282	195	280				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	32	76	32	76				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	22	30	22	22				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16				
*	Malancha, Clp EP2 (United)	Gas	5x8.73+3x9.34			4	4	5	15				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel oil shortage	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	102	105	105	105				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	81	50	80				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	66	66	66				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	90	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				
Chattogram Zone Total					2442	2382	1110	1429	1211	1425	288	330	
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	39	50	38	50				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	192	162	180	192				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	335	330	330	330				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	300	295	300	300				
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284		Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	30	30	30	25		Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	113	118	115	137				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	44				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	83	82	82	82				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	51	17	50				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	22	22	22				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	25	25	25				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	17	43	8	43				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.058	200	200	105	30	100	100				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	112	17	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	11	9	9	9	104		Fuel Oil Shortage	
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	54				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	115	35	115				
**	Import (Tripura)	India		160	160	148	164	143	166				
Cumilla Zone Total					3193	3169	1597	1764	1577	1954	734	0	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	65	65	110	137		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	108	90	100				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	78	126	100	140	74		Fuel oil shortage	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0				
87	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total					622	614	281	324	332	375	211	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.10.22 (Yesterday)		13.10.22 (Today)		12.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
88	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchugonj	51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	5	5	5	46		Gas Shortage	
91	Kushiera	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage	
93	Shahjibazar	GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	64	62	62				
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar	66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	81	10	80				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140	91		ST Under maint.	
97	Sylhet	20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20		Gas Shortage	
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	280	310				
101	Bibiyan-II	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	411	407	400	400				
102	Bibiyan South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	396	400	400	400				
103	Shahjibazar	100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
104	Sylhet	50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchugonj	44MW (Energyprime)	Gas (NENP)	12'3.4-5'2	50	50	5	5	5	5	45		Gas Shortage	
Sylhet Zone Total						2522	2477	1386	1482	1372	1472	306	675	
106	Bheramara	GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	225	215	210	210	195		Gas Shortage	
108	Fairpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	0	40				
109	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	73	0	60				
110	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	130	120	180				
111	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50				
112	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	72	35	90				
113	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	85	15	50				
114	Mongla	Orion 100 MW Solar PP	Solar (IPP)		100	100	25	0	100	0				
115	Khulna	115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	70	16	70				
116	Noapara	40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0	40		Fuel oil shortage	
	Rampal	1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna	330 MW CCPP	Gas/HSD (BPDF)				0	0	0	0				
**	Bheramara	(HVCDC)	India	1000	1000	924	921	935	935					
Khulna Zone Total						2388	2384	1294	1603	1431	1685	235	0	
117	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16		94	Line Overload	
118	Bhola	33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	26	16	20				
119	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	88	88	86	86	106		Gas Shortage	
120	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	630	800	1000	1000				
121	Potukhalhi	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0	150		Line Overload	
122	Bhola	220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	222	222	222				
Barishal Zone Total						1958	1958	959	1152	1340	1444	106	244	
123	a) Baghabari	71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari	100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari	50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0	71		Under maint.	
127	Chapainawabganj	100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86				
128	Katakhal	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24				
129	Katakhal	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0	50		Fuel Oil Shortage	
130	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32				
131	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	187	177	170	177				
132	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	195	130	180	220		Running on HSD	
133	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	152	150	150	68		Gas Shortage	
134	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	355	318	320	320	96		Gas Shortage	
135	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	21	21				
136	Uliapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	0	43				
138	Bagura	113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	70	113	113	113				
139	Bagura	113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	36	113	113	113				
140	Sirajgonj	6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total						2129	2129	979	1318	1034	1402	605	71	
141	a) Barapukuria	TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	80	80	80				
	b) Barapukuria	TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.	
143	Rangpur	20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	39	113	56	113				
145	Saidpur	20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara	Tatula 5 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgaon	119MW PP (Energyprime)	HFO (IPP)	6'20	115	115	0	76	0	75				
148	Lalmohithal	30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	6	0	12	0				
Rangpur Zone Total						830	750	130	269	156	268	0	359	
Sub-total: Plants in operation						22088	21710	10559.0	12281	11104	12962	2920	2859	
(B) Plants under long term maintenance/ contract expired														
149	Jamulpur	95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti	52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila	108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj	100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura	20 MW PP (Energyprime)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
154	Amhura	30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired						424	0	0	0	0	0			
Gross Total						22512	21710	10559	12281	11104	12962	2920	2859	
(C) Actual data of 12.10.22 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	12714	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12207	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12281	MW, at =	19:30 hrs	Dhaka	4530	4386	144	Mymensingh	1091	906	185	
04.	Minimum Generation (Generation end)	:	9719	MW, at =	8:00 hrs	Chattogram	1281	1281	0	Sylhet	452	452	0	
05.	Day-peak Generation (Generation end)	:	10559	MW, at =	12:00 hrs	Khulna	1352	1352	0	Barishal	339	339	0	
06.	Evening-peak Generation (Generation end)	:	12281	MW, at =	19:30 hrs	Rajshahi	1245	1245	0	Rangpur	703	703	0	
07.	Evening Peak Load-shed (Sub-station end)	:	399	MW, at =	19:30 hrs	Cumilla	1214	1144	70					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9623	MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:				Total								
a) Gas/LF limitation	:	2920	MW			(a) Gas = 148416678 Taka								
d) Coal supply Limitation	:	0	MW			(b) Oil = 1013316619 Taka								
b) Low water level in Kaptai lake	:	0	MW			(c) Coal = 190766216 Taka								
c) Plants under shut down/ maintenance	:	2859	MW			Total = 1352499514 Taka								
10.	Total Energy (Generation + India Import)	:	260.66	MKWh		14. Maximum Temperature in Dhaka was : 32.1° C								
	By Gas =	134.247	MKWh	By Oil =	73.889	15. Export through East-West interconnections :								
	By Coal =	21.854	MKWh	By Hydro =	3.795	At evening peak-hour : 10559 MW, at 19:30 hrs								
	By Solar =	1.088	MKWh			Maximum : 640 MW, at 18:00 hrs								
11.	Total Gas Supplied	:	998.43	MMCFD		Energy : 0 MKWh								
(D) Forecast of 13.10.22 (Today) Thursday :														
01.	Maximum Demand	:	12800	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	12962	MW (Generation end)		05.	Total Generation	:	271.67	MKWh				
03.	Reserve / Shortage	:	162	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.5° C					